

EQUIPMENT SUBMITTAL

PyroTech PT-500 Suppression

**Project:** Meridian Data Centre Campus - Phase 1  
**Reference Section:** 21 22 00  
**Package ID:** SUB-212200-03-R0  
**Revision:** R0  
**Reviewed Spec Revision:** Rev 2024  
**Date:** 01-03-2025

ACTIVE

| Rev | Date       | Description       |
|-----|------------|-------------------|
| R0  | 01-03-2025 | Initial Submittal |

Product Technical Parameters

| Parameter                    | Claimed Value                    |
|------------------------------|----------------------------------|
| Model                        | PyroTech PT-500 Suppression      |
| Rated Capacity               | See performance table            |
| Operating Voltage            | 415 V / 3-phase / 50 Hz          |
| Ambient Temperature Range    | 0°C to 40°C                      |
| Efficiency at Full Load      | 96.0%                            |
| Efficiency at 75% Load       | 95.5%                            |
| Efficiency at 50% Load       | 94.8%                            |
| Enclosure Rating             | IP20                             |
| Enclosure Paint Finish       | RAL 7035                         |
| Cooling Method               | Forced air, front-to-top exhaust |
| Noise Level at 1 m           | 72 dBA                           |
| Weight                       | 1800 kg                          |
| Dimensions (W x D x H)       | 1200 x 950 x 1950 mm             |
| Manufacturing Certifications | ISO 9001, ISO 14001              |

<sup>1</sup> Burst disc rating is 45 bar, but burst disc set pressure tolerance is +/- 5 bar, with set point at 40 bar minimum

| Clause ID             | Requirement Summary                       | Response |
|-----------------------|-------------------------------------------|----------|
| 21 22 00 Part 1.1.1.A | Section scope of work requirements        | Comply   |
| 21 22 00 Part 1.2.1.A | Compliance with applicable standards      | Comply   |
| 21 22 00 Part 1.3.1   | Correct specification revision referenced | Comply   |
| 21 22 00 Part 1.3.2.A | Submittal documentation completeness      | Comply   |
| 21 22 00 Part 1.4.1.A | Manufacturer experience requirements      | Comply   |
| 21 22 00 Part 1.4.1.B | ISO certifications                        | Comply   |
| 21 22 00 Part 2.1.1.A | Acceptable manufacturer listing           | Comply   |
| 21 22 00 Part 2.1.2.A | N+1 configuration                         | Comply   |
| 21 22 00 Part 2.2.1.A | Performance standards compliance          | Comply   |
| 21 22 00 Part 2.3.1.A | Enclosure construction requirements       | Comply   |
| 21 22 00 Part 2.3.2.A | Paint finish requirements                 | Comply   |
| 21 22 00 Part 3.4.1.A | Functional test requirements              | Comply   |

**CERTIFICATE OF COMPLIANCE**

This certifies that the equipment described herein complies with the applicable testing and performance requirements.

**Issued by:** PyroTech Quality Assurance

**Certificate No:** QA-4657-242

**Date:** 15-11-2024