

ADDENDUM NO. 3

Date: 2026-06-15

Project: TEST_DATA_CENTRE

Reference: Section 26 33 53, Part 2.3.4

Action: DELETE 'not less than 96.0 percent' and INSERT 'not less than 96.5 percent'

Clause: Inverter efficiency is upgraded to 96.5 percent.