

VoltEdge UPS System Submittal - R0
Reference Section: 26 33 53
Package ID: SUB-263353-01-R0
Revision: R0
Reviewed Spec Revision: Rev 2024
Date: 01-01-2025

Technical Datasheet - VoltEdge UPS System

Parameter	Value	Operating Condition
Inverter Efficiency	95.5%	Full load
Inverter Efficiency	94.2%	50% load
UPS System Redundancy	N+1	Standard config
Battery Runtime	10 min	Full load discharge

Compliance Matrix - VoltEdge UPS System

Clause Reference	Requirement Summary	Stated Response	Stance
26 33 53 Part 2.1.2.A	N+2 Redundancy	Comply	Compliant
26 33 53 Part 2.3.4	Efficiency >= 96.0%	Comply	Compliant