

VoltEdge UPS System Submittal - R1
Reference Section: 26 33 53
Package ID: SUB-263353-01-R1
Revision: R1
Reviewed Spec Revision: Rev 2024
Date: 02-15-2025

Technical Datasheet - VoltEdge UPS System

Parameter	Value	Operating Condition
Inverter Efficiency	96.2%	Full load
UPS System Redundancy	N+2	Standard config
Battery Runtime	10 min	Full load discharge

Compliance Matrix - VoltEdge UPS System

Clause Reference	Requirement Summary	Stated Response	Stance
26 33 53 Part 2.1.2.A	N+2 Redundancy	Comply	Compliant
26 33 53 Part 2.3.4	Efficiency >= 96.0%	Comply	Compliant