

SUBMITTAL TRANSMITTAL

Package ID: SUB-236426-01 · Revision: R1 · Date: 2026-04-06
Reference Section: 23 64 26 — Water-Cooled Centrifugal Chillers
Reviewed Spec Revision: IFC Rev 0 incorporating Addendum No. 1 (ADD-001)
Vendor: CryoCore Climate Pvt Ltd · Equipment: CC-1200H Chillers (CH-A1, CH-A2)
Declared deviations: NONE. Reason for revision: COP uplift to meet Addendum No. 1 Item 1 via high-efficiency impeller trim.

CryoCore CC-1200H — Selection Data at AHRI 550/590 Conditions

Parameter	Value
Cooling capacity	1205 TR, zero fouling allowance deducted
COP at 100% load	6.35
Sound pressure at 1 m (AHRI 575)	84 dBA
Refrigerant	R-1233zd(E), GWP 1
Shaft vibration, all load points	3.8 mils peak-to-peak (ISO 10816-3)