

SUBMITTAL TRANSMITTAL

Package ID: SUB-263353-01 · Revision: R0 · Date: 2026-02-18
Reference Section: 26 33 53 — Static Uninterruptible Power Supply
Reviewed Spec Revision: Issued for Construction Rev 0
Vendor: VoltEdge Power Systems Pvt Ltd · Equipment: PX-1200 UPS Modules (UPS-A1..A4)
Declared deviations: NONE

VoltEdge PX-1200 — Technical Datasheet (extract)

Electrical Performance

Parameter	Value
Rated output	1200 kW / 1200 kVA, unity PF
Efficiency, double-conversion (VFI), 100% load	96.2%
Efficiency, eco-mode	99.1%
Input THDi at 100% load	4.8% [2]
Overload capability	125% for 10 min; 150% for 60 s
Paralleling	Up to 8 units, decentralised N+1

Battery System (supplied with Package SUB-263353-02)

Autonomy at full rated load, end-of-life: 8 minutes at 25 °C. Extended autonomy available with additional cabinet strings (option E2, not included).

Footnote [2]: THDi measured with optional VE-HF harmonic filter module installed. The VE-HF module is not included in the base scope of supply for this contract.

Factory test: heat run and transfer tests per VoltEdge standard procedure VE-FT-11. Certificates attached.