

SUBMITTAL TRANSMITTAL

Package ID: SUB-263353-02 · Revision: R0 · Date: 2026-02-25
Reference Section: 26 33 53 — Static Uninterruptible Power Supply
Reviewed Spec Revision: Issued for Construction Rev 0
Vendor: VoltEdge Power Systems Pvt Ltd · Equipment: VRLA Battery Cabinets (BAT-A1..A4)
Declared deviations: NONE

VoltEdge BC-500 Battery Cabinets — Technical Datasheet (extract)

Parameter	Value
Autonomy at full rated UPS load (end-of-life, 25 °C)	12 minutes
Battery sizing method	IEEE 485, 1.10 ageing factor
Seismic anchorage	IS 1893 (Part 4) Zone III; anchorage calculation VE-SC-204 attached
Anchor torque records	To be submitted as installation quality records prior to energisation
Cabinet construction	2 mm CRCA, powder coated, front-access