

ADDENDUM 3

Date: 15-06-2026

Addendum 3 Changes

The following changes are issued to the contract documents.

Reference: Section 26 33 53, Part 2.3.4

Action: DELETE '96%' and INSERT '96.5%'

Clause: UPS double-conversion efficiency requirement increased from 96.0% to 96.5% at 50%, 75%, and 100% load points.

Reference: Section 23 81 23, Part 2.2.1

Action: DELETE '10°C entering' and INSERT '11°C entering'

Clause: CRAH chilled water design entering temperature increased from 10°C to 11°C, reducing cooling plant chiller energy.