

MEETING MINUTES

Project: Meridian Data Centre Campus, Phase 1 | Navi Mumbai, India

Meeting Date:	March 10, 2026	Time:	2:00 PM - 3:30 PM
Subject:	UPS R0 Submittal Review Coordination	Ref No:	MOM-2026-02-R0
Attendees:	A. Verma (Client), S. Kumar (EPC Lead), R. Sharma (Consultant)		

1. Discussion Notes

Review meeting to address the technical deviations identified in VoltEdge's UPS R0 submittal and coordinate necessary manufacturer modifications.

2. Key Decisions and Action Items

Item No	Discussion / Decision	Action Owner	Target Date
2.1	UPS R0 Rejection: Review VoltEdge UPS R0. Noted double-conversion efficiency at 50% load drops to 95.1% in footnote, violating the 96.0% spec limit. Package rejected.	EPC Lead	Resolved
2.2	Resubmittal Plan: VoltEdge to submit UPS R1 incorporating high-efficiency settings and removing the VFI filter footnote.	VoltEdge	2026-03-15