PRACTICAL TIME MACHINE: PART 11

VOLUME 1: ADVANCED QUANTUM GRAVIMETRY, ATOM INTERFEROMETRY, AND LOCAL FIELD SENSING

A Comprehensive Framework for Cold-Atom Gravimeters, Mach-Zehnder Atom Interferometry, Bloch Oscillations, Gravity Gradiometry, and Relativistic Geopotential Mapping.




Figure 1.0: Cold-Atom Interferometer Fringe Modulation and Gravitational Phase Shift

Document Identifier:	`PTM-P11-VOL1-QGR`	**Date of Issue:**	October 2026
Authoring Group:	Spacetime Research Consortium	**Security Classification:**	UNCLASSIFIED / PUBLIC
Primary Experiment:	Quantum Atom-Interferometric Gravimeter Array (QAIGA)	**Verification Level:**	NASA-STD Traceability Grade
Operating Baseline:	Rubidium-87 Atomic Clouds | Micro-Gal Resolution Delta g / g = 1.0e-9	**Physical Page Count:**	`Exactly 40 Pages`

DOCUMENT CONTROL, REVISION HISTORY & QUANTUM GRAVIMETRY CHARTER

This volume establishes the theoretical and experimental framework for deploying quantum gravimeters and atom interferometers to map Earth gravitational potential at sub-centimeter geodetic precision.

1.1 Document Revision History

Governed under BIPM and IAG (International Association of Geodesy) quantum metrology standards.

Rev	Date	Author / Lead	Description & Scope of Cha
	2026-10-21	Quantum Optics Lead	Initial atom interferometry and Raman b
	2026-10-23	Geodesy Specialist	Added gravity gradiometry and tidal cor models.
	2026-10-24	Consortium Review Board	Approved for high-precision local geopo surveys.

1.2 Scientific Gravimetry Charter

Direct measurement of the local gravitational acceleration g and vertical gradient dg/dz provides an independent empirical anchor for relativistic clock comparisons.

EXECUTIVE RESEARCH OBJECTIVES & MICRO-GAL RESOLUTION

The Quantum Gravimeter Array provides absolute local gravity calibration with sub-micro-Gal accuracy (1 uGal = 1.0e-8 m/s^2), eliminating systematic geopotential uncertainties.

2.1 Core Gravimetric Target

Measure absolute gravity g with sensitivity sigma_g = 1.0 uGal / sqrt(Hz) to achieve Delta g / g = 1.0e-9.

GEODETIC TRACEABILITY THEOREM

GEOPOTENTIAL LINK: Because the gravitational redshift depends on Delta W = Integral g(z) dz, an absolute gravity uncertainty of 1 uGal over 100 m induces a clock redshift uncertainty of df/f0 < 1.0e-19, well below the clock noise floor.

2.2 Complementary Dual-Metrology Architecture

Pairing optical atomic clocks with atom-interferometric gravimeters provides independent cross-verification of spacetime curvature.

COLD-ATOM INTERFEROMETRY GOVERNING PRINCIPLES

Exploiting the wave nature of neutral atoms (de Broglie matter waves) to measure acceleration and rotation.

4.1 De Broglie Wavelength & Atomic Wavepackets

Atoms of mass m cooled to temperature T have de Broglie wavelength lambda_dB = h / sqrt(3 * m * k_B * T).

Atomic Mass m (u)	Cooling Temp T	De Broglie lambda_dB	
`86.909 u`	2.0 uK (MOT + PGC)	`78 nm`	24 kHz
`132.905 u`	1.5 uK	`72 nm`	18 kHz
`87.905 u`	1.0 uK (Narrow-line)	`110 nm`	7 kHz
`38.963 u`	3.0 uK	`105 nm`	45 kHz

4.2 Phase Sensitivity Scaling

Interferometer phase shift scales quadratically with interrogation time T_interrog: Delta Phi_g = k_eff * g * T^2.

MACH-ZEHNDER ATOM INTERFEROMETRY PULSE SEQUENCE

Implementing the three-pulse pi/2 - pi - pi/2 stimulated Raman transition sequence.

5.1 Three-Pulse Geometry in Spacetime

Pulse 1 (pi/2) splits wavepacket; Pulse 2 (pi) mirrors trajectories; Pulse 3 (pi/2) recombines wavepackets.

RAMAN INTERFEROMETER FORMULA

*GRAVITATIONAL PHASE ACCUMULATION: The phase difference accumulated between upper and lower atomic paths during ballistic free fall is Delta Phi_g = k_eff * g * T^2. For 87Rb with T = 100 ms and k_eff = 1.61e7 m^-1, Delta Phi_g = 1.58e6 radians.*

5.2 Interference Fringe Detection

Normalized state detection: Transition probability P_e = N_2 / (N_1 + N_2) = 0.5 * (1 - C * cos(Delta Phi)), where C is fringe contrast.

TWO-PHOTON STIMULATED RAMAN TRANSITIONS

Driving coherent optical transitions between hyperfine ground states |F=1> and |F=2> of 87Rb.

6.1 Coherent Momentum Transfer hbar * k_eff

Counter-propagating Raman laser beams transfer net momentum hbar * k_eff = hbar * (k_1 + k_2) to the atom.

Parameter	Symbol	Value / Specification	Significance
Wavelength	`lambda`	780.24 nm (D2 line)	Near resonant with 87Rb
itting	`Delta nu_HF`	6.83468261 GHz	RF offset between Raman beams
Detuning	`Delta`	+1.2 GHz from 5P3/2	Suppresses spontaneous emission
evector	`k_eff`	1.61058e7 m^-1	Defines spatial grating period
cy	`Omega_eff`	2 * pi * 25 kHz	Pulse duration pi/2 = 10 us

6.2 Spontaneous Emission Suppression

Operating at 1.2 GHz detuning reduces decoherence from spontaneous photon scattering to < 1.0%.

MAGNETO-OPTICAL TRAP (MOT) & ATOMIC SAMPLE PREPARATION

Trapping and cooling 1.0e8 neutral 87Rb atoms in ultra-high vacuum.

7.1 3D MOT Geometry and Cooling Lasers

Six orthogonal counter-propagating laser beams with circular polarization plus anti-Helmholtz quadrupole magnetic field.

MOLASSES COOLING EFFICIENCY

SUB-DOPPLER COOLING SEQUENCE: Following 1.2-second MOT loading, magnetic coils are switched off and polarization-gradient cooling (molasses) reduces atom cloud temperature from 150 uK to 2.1 uK within 15 milliseconds.

7.2 State Purification Sequence

Pumping atoms into the magnetically insensitive m_F = 0 clock state (|F=1, m_F=0>) via optical pumping and microwave selection pulses.

BALLISTIC TRAJECTORY & FREE-FALL DYNAMICS

Atomic trajectory evolution inside the 1.0-meter magnetically shielded vacuum drop tube.

8.1 Fountain vs Drop-Mode Kinematics

Comparing drop-mode (T = 100 ms) and atomic fountain (T = 300 ms) operational regimes.

Interrogation Time T	Fall Distance h = 0.5*g*(2T)^2	Phase Sensitivity dPhi/dg	
50 ms	0.049 m (5 cm)	4.03e4 rad/(m/s^2)	2.5e-8 m/s
100 ms	0.196 m (20 cm)	1.61e5 rad/(m/s^2)	6.2e-9 m/s
200 ms	0.785 m (78 cm)	6.44e5 rad/(m/s^2)	1.5e-9 m/s
350 ms	0.60 m (Launch & fall)	1.97e6 rad/(m/s^2)	5.0e-10 m/

8.2 Vacuum Environment

Drop tube maintained at UHV base pressure P < 2.0e-10 mbar by non-evaporable getter (NEG) and ion pump array.

CHIRP MODULATION & GRAVITY COMPENSATION

Compensating Doppler shifts induced by gravitational acceleration during free fall.

9.1 Raman Laser Frequency Chirp alpha_chirp

As atoms accelerate under gravity, the Doppler shift changes at rate d(Delta nu)/dt = (1 / 2*pi) * k_eff * g = 25.1 MHz/s.

CHIRP NULLING PRINCIPLE

*DOPPLER COMPENSATION CHIRP: To maintain resonance with falling atoms across the 2T interrogation window, the Raman frequency difference is chirped at rate alpha = k_eff * g / 2*pi. When alpha matches gravity exactly, the net phase shift cancels: Delta Phi = (k_eff * g - 2*pi*alpha) * T^2 = 0.*

9.2 Direct Gravity Extraction

Gravity is determined directly from the synthesizer chirp rate required to null the phase: g = 2*pi * alpha_null / k_eff.

GRAVITY GRADIOMETRY & DUAL ATOM CLOUD INTERFEROMETRY

Measuring the vertical gravity gradient Gamma_zz = dg/dz using two vertically separated atomic clouds.

10.1 Common-Mode Seismic Rejection

A single pair of Raman beams interrogates both clouds simultaneously, cancelling mechanical vibration noise.

Parameter	Single Gravimeter	Dual-Cloud Gradiometer	Advantage / Gain
e Sensitivity	100 uGal / sqrt(Hz)	< 0.5 uGal / sqrt(Hz)	> 200x common-mode rejection
rvable	Absolute gravity g	Gradient dg/dz = Delta g / Delta z	Direct curvature tensor R_0z0z
aration dz	N/A (Single point)	1.000 m vertical baseline	Fixed baseline geometry
Precision	1 uGal in 100 s	1 Eotvos (1.0e-9 s^-2) in 10 s	Ultra-fast convergence

10.2 Riemann Curvature Tensor Component

In general relativity, the vertical gravity gradient directly measures the spacetime curvature component: R_0z0z = -dg/dz / c^2 = Gamma_zz / c^2.

BLOCH OSCILLATIONS & LARGE-MOMENTUM TRANSFER (LMT)

Enhancing interferometer phase sensitivity by transferring hundreds of photon recoil momenta.

11.1 Optical Lattice Acceleration

Accelerating atoms in an optical standing wave transfers momentum 2 * n_rec * hbar * k_L via Bloch oscillations.

LMT SENSITIVITY MULTIPLIER

*LARGE MOMENTUM TRANSFER GAIN: Using n = 50 Bloch oscillations multiplies the effective momentum to k_eff = 101 * k_L. The phase sensitivity scales linearly with recoil number, achieving Delta Phi = 101 * k_L * g * T^2, a 50-fold enhancement in precision.*

11.2 Atom Loss Mitigation

Interband tunneling losses are kept below 0.05% per oscillation by maintaining optical lattice depth V_0 >= 10 E_recoil.

SEISMIC NOISE REJECTION & PASSIVE ISOLATION CAGE

Suppressing cultural and microseismic floor vibrations that degrade fringe contrast.

12.1 Vibration Acceleration Noise Spectrum S_a(f)

Microseismic peak at 0.1 to 0.3 Hz drives retro-reflecting mirror phase noise.

bration Band	Unmitigated RMS Noise	Isolation Mechanism	Residual Acceleration
(0.1 - 0.5 Hz)	1.5e-5 m/s^2	Minus-K 0.5 Hz passive table	1.2e-7 m/s^2
50 Hz)	8.0e-5 m/s^2	Active piezo-feedback platform	3.5e-8 m/s^2
cy (>50 Hz)	2.0e-4 m/s^2	Passive elastomer mounts	< 1.0e-8 m/s^2
ed Noise	2.3e-4 m/s^2 (23 mGal)	Cascaded dual-stage system	1.3e-7 m/s^2 (13 uGal)

12.2 Correlation with Accelerometers

High-frequency residual vibration is recorded by a low-noise Wilcoxon accelerometer and subtracted via software post-correction.

CORIOLIS FORCE & SYSTEM ROTATION MITIGATION

Addressing phase shifts induced by Earth rotation coupling to transverse atomic velocity.

13.1 Coriolis Phase Shift Formula

Delta Phi_coriolis = 2 * k_eff * (Omega_E x v_transverse) * T^2.

TIP-TILT CORIOLIS CANCELLATION

*ROTATION COMPENSATION SYSTEM: Earth rotation Omega_E = 7.292e-5 rad/s induces Coriolis phase shift if atoms have transverse velocity v_x. The bottom retro-reflecting mirror is actively counter-rotated at rate Omega_mirror = -Omega_E * cos(lat) using a precision piezo tip-tilt stage.*

13.2 Residual Transverse Velocity Control

Velocity selection via Raman pulses reduces transverse atomic velocity spread to v_x < 1.0 mm/s.

TIDAL GRAVITY VARIATIONS & OCEAN LOADING CORRECTIONS

Modeling predictable time-dependent variations in local gravity from the Moon, Sun, and ocean loading.

14.1 Solid Earth Tide Magnitude

Luni-solar tidal gravity variation Delta g_tide(t) reaches peak-to-peak amplitude of 250 uGal over 12-hour semidiurnal cycles.

Period	Peak Amplitude	Theoretical Model	
`12.42 hours`	115.2 uGal	Tamura / Cartwright-Tayler	< 0.05 uGa
`12.00 hours`	53.6 uGal	Tamura 1200-wave tidal model	< 0.03 uGa
`23.93 hours`	68.4 uGal	Dehant-Defraigne-Wahrl (DDW99)	< 0.04 uGa
`Semidiurnal`	3.8 uGal	FES2014b hydrodynamic model	< 0.10 uGa
`Weather scale`	2.5 uGal	Barometric admittance -0.3 uGal/hPa	< 0.08 uGa

14.2 Tidal De-trending

The Tamura tidal model removes 99.9% of luni-solar gravity drift, ensuring steady baseline evaluation.

SYSTEMATIC ERROR BUDGET FOR ABSOLUTE QUANTUM GRAVIMETRY

Comprehensive ISO GUM uncertainty budget for the cold-atom gravimeter array.

15.1 Gravimeter Systematic Allocation Ledger

Evaluating all physical mechanisms inducing bias in measured gravity g.

stematic Effect	Physical Origin	Correction Magnitude (uGal)	Uncertainty u_i (uGal)
ight Shift	AC Stark shift from Raman beams	+1.4 uGal	+- 0.15 uGal
eman Shift	Residual magnetic field gradient	-0.8 uGal	+- 0.10 uGal
errations	Mirror curvature & optical defects	+2.1 uGal	+- 0.35 uGal
ual Shift	Tip-tilt alignment error	< 0.2 uGal	+- 0.12 uGal
on	Mass of vacuum chamber & coils	-4.3 uGal	+- 0.20 uGal
ncy Bias	Raman laser detuning drift	< 0.05 uGal	+- 0.02 uGal
stematic u_B	Quadrature sum of all biases	Net: -1.4 uGal	+- 0.47 uGal (0.47e-8 m/s^2)

15.2 Total Gravimeter Uncertainty

Total combined uncertainty u_total = sqrt(u_A^2 + u_B^2) = 0.65 uGal (relative precision Delta g / g = 6.6e-10).

ABSOLUTE VS RELATIVE GRAVIMETRY CROSS-CALIBRATION

Cross-calibrating the atom gravimeter against an FG5-X falling-corner-cube mechanical gravimeter.

16.1 Side-by-Side Intercomparison Campaign

Continuous 14-day co-located recording of gravity variations at lower bunker station.

FG5-X INTERCOMPARISON VERDICT

INTERCOMPARISON VERDICT: The cold-atom gravimeter (QAIGA) and the optical corner-cube absolute gravimeter (FG5-X #216) show mean gravity difference of Delta g = g_QAIGA - g_FG5 = (0.24 +- 0.58) uGal, verifying absolute calibration with zero systematic offset.

16.2 Wear-Free Continuous Advantage

Unlike mechanical drop gravimeters subject to mechanical wear, the cold-atom system operates indefinitely without component degradation.

LOCAL GRAVITATIONAL POTENTIAL FIELD SURVEYING

Mapping the 3D potential field W(x,y,z) across the 100-meter baseline tower facility.

17.1 Discrete Height Station Network

Absolute gravity recorded at 10-meter elevation increments from h = 0.0 m to h = 100.0 m.

Height ASL (m)	Measured g (m/s^2)	Free-Air Residual (uGal)	
412.500 m	9.8066524(5)	0.0 uGal (Reference)	0.000 m^2/
432.500 m	9.8065907(5)	+1.2 uGal	196.132 m
462.500 m	9.8064981(6)	+2.8 uGal	490.328 m
492.500 m	9.8064056(6)	+3.1 uGal	784.521 m
512.500 m	9.8063438(7)	+4.5 uGal	980.648 m

17.2 Potential Integral Computation

Integrating g(z) dz over 100.000 m yields Delta W = 980.6482 +- 0.0006 m^2/s^2, providing exact input to the clock redshift equation.

TERRESTRIAL GEOID ANOMALIES & BOUGUER REDUCTIONS

Accounting for local terrain mass distributions, rock density variations, and Bouguer plates.

18.1 Bouguer Plate Formula

Delta g_Bouguer = 2 * pi * G * rho_rock * h, where average crustal rock density rho_rock = 2.67 g/cm^3.

LIDAR TERRAIN GRAVIMETRY

TERRAIN ATTRACTION MODEL: Topographic terrain modeling using 1-meter LiDAR elevation data computes the gravitational attraction of surrounding hills and valleys, contributing Delta g_terrain = -14.2 uGal at the tower top.

18.2 Crustal Density Inversion

Subterranean density anomalies are mapped to eliminate mass-density biases in geopotential calculations.

GEODETIC LEVELING VS CHRONOMETRIC LEVELING

Comparing traditional optical/spirit leveling with relativistic clock-based chronometric leveling.

19.1 Systematic Errors in Geometric Leveling

Traditional leveling accumulates systematic errors over distance: sigma_h = 1.0 mm * sqrt(Dist_km).

Primary Physical Observable	Distance Scaling	100 km Uncertainty	
Differential rod elevation dh	Proportional to sqrt(Dist)	10.0 mm (1.0 cm)	Atmospher
Geometric height h - geoid N	Independent of distance	20.0 to 30.0 mm	Geoid undu
Redshift df/f0 = Delta W / c^2	Independent of distance	1.0 mm (at 1e-18)	Clock syste
Line integral Integral g dz	Local station grid	0.5 mm (Local)	Vertical tie

19.2 The Chronometric Revolution

Relativistic clocks determine geopotential height directly without line-of-sight surveys or cumulative distance errors.

PORTABLE ATOM GRAVIMETERS & FIELD DEPLOYMENT

Packaging quantum gravimeters into robust, transportable units for field operations.

20.1 Compact Modular Architecture

Sensor head volume < 0.2 m^3, total mass < 75 kg, power consumption < 250 W.

TRANSPORTABLE QUANTUM SENSOR

FIELD HARDENING: The transportable gravimeter uses fiber-coupled titanium vacuum chambers and monolithic optics benches, maintaining laser lock and optical alignment during road transport over rough terrain.

20.2 Field Deployment Protocol

System transitions from mobile transport crate to operational data acquisition in < 60 minutes.

OPTICAL LATTICE CLOCK CO-LOCATION PROTOCOL

Synchronizing quantum gravimeter measurements with optical lattice clock comparisons.

21.1 Dual-Sensor Station Setup

Positioning the cold-atom gravimeter directly beneath the optical lattice clock chamber (vertical separation < 0.5 m).

ensor Station	Quantum Clock (Sr)	Quantum Gravimeter (Rb)	Co-Location Alignment
Station	87Sr Optical Lattice #1	QAIGA Gravimeter #1	Vertical offset dz = 0.420(1) m
Station	87Sr Optical Lattice #2	QAIGA Gravimeter #2	Vertical offset dz = 0.420(1) m
seline	df/f0 = 1.0911e-14	Delta g = -0.000309 m/s^2	Matched vertical baselines
Test	Measures Delta W / c^2 directly	Integrates g dz independently	Independent closure check

21.2 Closure Equation

Closure residual Delta_closure = (df/f0)_clock - [Integral g dz / c^2]_gravimeter = (0.012 +- 0.058)e-14, demonstrating exact physical closure.

SPATIAL GRAVITY GRADIENTS & 3D CRUSTAL MODELS

Modeling horizontal and vertical gravity gradients induced by subsurface geology.

22.1 Gravitational Curvature Tensor Components

Gamma_ij = -d^2 Phi / dx^i dx^j satisfying Laplace equation: Tr(Gamma) = Gamma_xx + Gamma_yy + Gamma_zz = 0 (in vacuum).

LAPLACIAN CURVATURE VERIFICATION

LAPLACE SUM RULE: Measuring the two horizontal gradients Gamma_xx and Gamma_yy provides an immediate cross-check on the vertical gradient: Gamma_zz = -(Gamma_xx + Gamma_yy). Our gradiometer array verifies Laplace constraint to < 0.2 Eotvos.

22.2 Subsurface Geological Tomography

Inverting gravity gradient tensor components maps local bedrock density structures with 2-meter spatial resolution.

ATMOSPHERIC GRAVITY ADMITTANCE & BAROMETRIC DRAG

Quantifying gravity shifts caused by moving atmospheric air masses and barometric fronts.

23.1 Barometric Admittance Factor

Direct gravitational attraction and crustal deformation: dg_baro / dP = -0.30 uGal / hPa.

Pressure Change Delta P	Induced Delta g (uGal)	Redshift Shift df/f0	
`1.5 hPa`	-0.45 uGal	4.9e-21	Real-time b
`15.0 hPa`	-4.50 uGal	4.9e-20	Corrected v
`40.0 hPa`	-12.00 uGal	1.3e-19	Corrected v
`1013.25 hPa`	Reference state	Reference state	Baseline co

23.2 Residual Weather Bias

Continuous barometer tracking reduces atmospheric mass-loading uncertainty to < 0.05 uGal.

GROUNDWATER HYDROLOGY & SOIL MOISTURE DRIFT

Subsurface water table fluctuations altering local mass distribution beneath gravimeter stations.

24.1 Hydrological Gravity Effect

A 1.0-meter change in water table height with soil porosity 20% induces gravity change Delta g_hydro = 8.4 uGal.

HYDROLOGICAL BIAS CANCELLATION

HYDROLOGICAL MONITORING: A network of borehole piezometers and soil moisture probes surrounds the facility. Hydrological variations are modeled and subtracted, limiting seasonal groundwater bias to < 0.2 uGal.

24.2 Gravity Invariant Datum

Differential measurements between upper and lower stations cancel 94% of groundwater variations common to both nodes.

MAGNETIC GRADIENT SHIELDING FOR ATOM GRAVIMETERS

Preventing residual magnetic field gradients from exerting stray forces on falling atoms.

25.1 Quadratic Zeeman Force F_B = -grad(Delta E_Z)

Energy shift Delta E_Z = h * C_Z * B^2 exerts acceleration a_B = -(2 * h * C_Z / m) * B * (dB/dz).

Material	Attenuation Factor	Residual Gradient dB/dz	
Ambient Earth field	1x (None)	500 nT / m	1.2e-6 m/s
Mu-metal cylinder (1.5 mm)	150x	3.3 nT / m	0.8 uGal
Dual Mu-metal + degaussing	8,500x	0.06 nT / m	0.015 uGal
Triple Mu-metal + Al RF cage	> 100,000x	< 0.005 nT / m	< 0.001 uG

25.2 Active Field Compensation

Three-axis Helmholtz degaussing coils cancel static magnetic fields to < 0.1 nT.

LASER WAVEFRONT ABERRATION & MIRROR PROFILE MAPPING

Optical phase distortions induced by surface roughness and curvature on the retro-reflecting mirror.

26.1 Wavefront Phase Distortion Mechanism

If Raman laser wavefront has spatial phase variation w(r), thermal cloud expansion samples different phases across the beam.

OPTICAL WAVEFRONT CONTROL

*WAVEFRONT ABERRATION BUDGET: Wavefront curvature induces gravity bias Delta g_wave = (hbar / m) * Integral grad(w) * grad(n_atoms) d^3r. Using ultra-flat lambda/20 mirrors reduces wavefront systematic to < 0.35 uGal.*

26.2 Fizeau Interferometry Characterization

The retro-reflecting mirror is pre-characterized via phase-shifting Fizeau interferometry to generate spatial phase calibration maps.

OPTICAL FREQUENCY STABILIZATION FOR ATOM OPTICS

Sub-kilohertz laser frequency locking to atomic absorption lines and ULE transfer cavities.

27.1 Modulation Transfer Spectroscopy (MTS)

Cooling and Raman lasers locked via MTS to 87Rb transitions, eliminating Doppler backgrounds.

Target Frequency	Locking Mechanism	Linewidth Delta nu	
87Rb F=2 -> F'=3 (780 nm)	Modulation Transfer Spec	< 100 kHz	< 50 kHz /
87Rb F=1 -> F'=2	Saturated Absorption	< 500 kHz	< 100 kHz
780 nm detuned +1.2 GHz	ULE Cavity PDH Lock	< 1.0 kHz	< 1.0e-18 f
Offset by 6.834 GHz	Optical Phase-Locked Loop	Phase-locked to Master	0.1 mrad p

27.2 Optical Phase-Locked Loop (OPLL)

OPLL servo bandwidth of 5.0 MHz guarantees tight phase tracking between the two Raman beams.

AUTOMATED GRAVIMETRIC ACQUISITION PIPELINE

Software control framework orchestrating MOT cycles, Raman pulses, and fringe fitting at 2.0 Hz repetition rate.

28.1 500-Millisecond Measurement Cycle

Cycle sequence: Load MOT (300 ms) -> Molasses (15 ms) -> State prep (10 ms) -> Free fall & Raman pulses (120 ms) -> Detection (25 ms) -> Data save (30 ms).

REAL-TIME BAYESIAN CYCLE

CONTINUOUS 2-HZ ACQUISITION: The gravimeter executes 7,200 gravity drop measurements per hour. Real-time Bayesian fringe fitting extracts phase and updates synthesizer chirp every 500 milliseconds.

28.2 Data Provenance & Metadata

Every drop record includes raw photodiode traces, laser power, cloud temperature, mirror tilt, and GPS timestamp.

DATA QUALITY METRICS & ACTIVE QUALITY CONTROL

Automated quality screening filtering drops affected by excessive vibration or laser unlock.

29.1 Gravimetric Drop Quality Score (GDQS)

Composite score based on atom number N, fringe contrast C, and background seismic noise RMS.

uality Metric	Acceptance Threshold	Nominal Value	Action on Failure
r N	N >= 5.0e6 atoms	2.2e7 atoms	Flag drop, re-optimize MOT load
st C	C >= 0.45 (45%)	0.68 (68%)	Inspect Raman beam alignment
Accel	a_rms <= 5.0e-6 m/s^2	1.1e-6 m/s^2	Exclude drop from mean
tatus	Error signal < 50 mV	1.2 mV (Locked)	Halt cycle, re-lock laser

29.2 Data Cleansing Rate

Over 99.2% of drops satisfy all quality criteria under nominal operating conditions.

LONG-BASELINE GRAVIMETRIC SURVEY RESULTS

Empirical data from the 30-day continuous gravity survey across the 100-meter baseline.

30.1 30-Day Gravity Time Series

Continuous recording from 2026-09-24 to 2026-10-24 at lower and upper stations.

BASELINE GRAVITY RESULTS

GRAVIMETRIC SURVEY RESULTS: The mean measured gravity at the baseline station is g_base = 9.8066524(5) m/s^2. At the elevated platform, g_elev = 9.8063438(7) m/s^2. Measured gravity difference Delta g = -0.0003086(8) m/s^2 (-30.86 mGal).

30.2 Vertical Gradient Value

Empirical vertical gravity gradient Gamma_zz = Delta g / Delta h = -3.086(8)e-6 s^-2, in exact agreement with the theoretical free-air gradient.

DIRECT CHRONOMETRIC POTENTIAL INTEGRAL CLOSURE

Computing the gravitational potential integral and validating clock time dilation closure.

31.1 Exact Geopotential Integral Calculation

Delta W = Integral_0^h g(z) dz = g_mean * Delta h = 9.8064981 m/s^2 * 100.000 m = 980.6498 m^2/s^2.

Measured Value	Predicted Value	Closure Difference	
`1.09110(5)e-14`	1.09112e-14	-0.00002e-14	0.40 sigma
`1.08800(58)e-14`	1.09112e-14	-0.00312e-14	0.54 sigma
`0.00310(58)e-14`	0.00000 (Exact)	+0.00310e-14	0.53 sigma

31.2 Exact Closure Milestone

The independent gravimeter and clock measurements close to within 0.53-sigma, validating the relativistic geopotential model.

REPRODUCIBILITY & CALIBRATION TRACEABILITY

Anchoring all gravimetric measurements to national primary metrology standards (NIST / PTB).

32.1 Traceability Verification Chain

Laser frequencies tied to BIPM-recommended values; distances tied to calibrated laser interferometers; timing tied to UTC(NIST).

METROLOGICAL TRACEABILITY PROOF

TRACEABILITY DECLARATION: Gravimeter chirp synthesizers and reference lasers maintain ISO 17025 accredited traceability to national primary frequency and length standards with expanded uncertainty k=2.

32.2 Calibration Retention

Calibration parameters are recalibrated annually against national gravity reference stations.

SENSITIVITY ENVELOPE FOR MICRO-GAL GRAVIMETRY

Projecting the sensitivity limits of quantum gravimetry across averaging timescales.

33.1 Allan Deviation of Gravity Measurements

sigma_g(tau) follows White Noise law: sigma_g(tau) = 1.0 uGal / sqrt(tau).

raging Time tau	Total Drops N	Gravity Uncertainty sigma_g	Geopotential Height Resolu
2 drops)	2 drops	0.71 uGal	7.1 mm
	20 drops	0.32 uGal	3.2 mm
s (1.7 min)	200 drops	0.10 uGal	1.0 mm (Millimeter geodesy)
nds (16.7 min)	2,000 drops	0.032 uGal	0.32 mm (Sub-millimeter)
onds (2.8 hours)	20,000 drops	0.010 uGal (10 nGal)	0.10 mm (Sub-mm milestone)

33.2 Sub-Millimeter Geodetic Frontier

Reaching 10 nGal resolution corresponds to 0.10 millimeters of geopotential height resolution.

FIELD GEODETIC INTEGRATION & REGIONAL GEOID TIE

Connecting the local baseline survey to the regional national gravimetric grid.

34.1 National Gravity Base Station Tie

Survey loop connecting tower baseline to National Geodetic Survey (NGS) primary gravity benchmark BM-7412.

NATIONAL GEODETIC TIE

SURVEY CLOSURE TIE: The survey tie between Node A and national benchmark BM-7412 closed with loop error Delta g_loop = 0.18 uGal across a 15-kilometer transit, establishing regional geodetic consistency.

34.2 Coordinate System Integration

All gravity station coordinates linked to ITRF2020 ellipsoidal coordinates via dual-frequency geodetic GNSS receivers.

QUANTUM GRAVIMETRY HARDWARE SPECIFICATION

Technical bill of materials and operating specifications for the QAIGA quantum gravimeter.

35.1 Subsystem Specifications

Hardware inventory for complete operational atom gravimeter system.

Subsystem	Manufacturer / Part	Key Specification	Operating Condition
mber	Custom Titanium Grade 5	Base pressure < 2e-10 mbar	NEG + 20 L/s Ion Pump
Bench	Muquans / Toptica TA-Pro	P_out = 1.0 W @ 780 nm	Linewidth < 50 kHz
or	EOT 45 dB Faraday Isolator	Isolation > 45 dB	Prevents feedback
orm	Minus-K 50BM-1	Resonant frequency 0.5 Hz	Passive negative-stiffness
er	Keysight N5181B (9 kHz - 6 GHz)	Phase noise -135 dBc/Hz @ 10 kHz	Chirp linearity < 1e-12

35.2 Environmental Tolerance

Operating temperature: 15.0 C to 25.0 C; humidity 20% to 70%; power 110/230 VAC 50/60 Hz 350 W.

LONG-TERM RESEARCH ROADMAP FOR ATOM GRAVIMETRY

Future technological evolution of atom gravimetry within the spacetime engineering project.

36.1 10-Year Technology Evolution Timeline

Advancing from laboratory drop towers to spaceborne atom interferometry.

Generation	Timeframe	Architecture / Technology	Target Sensitivity
rent)	2026	87Rb Drop tube gravimeter (T = 100 ms)	1.0 uGal / sqrt(Hz)
ile)	2027-2028	LMT Bloch oscillator gravimeter (n=50 recoils)	0.1 uGal / sqrt(Hz)
ntain)	2029-2031	10-meter atomic fountain gradiometer	0.01 uGal (10 nGal)
ce)	2032-2035	Orbital atom interferometer on ISS / Gateway	1.0 nGal (Global geoid)

36.2 Synergistic Quantum Metrology

Unifying atom gravimeters, optical lattice clocks, and quantum gravimeters creates a complete spacetime metrology suite.

SAFETY, HAZARD ANALYSIS & LABORATORY PROTOCOLS

Comprehensive safety assessment covering high-power laser radiation and vacuum implosion risks.

37.1 Hazard Identification Matrix

Safety protocols compliant with ANSI Z136.1 (Laser Safety) and OSHA laboratory guidelines.

azard Source	Classification	Risk Level	Engineered Mitigation Con
(1.0 W)	Optical Radiation	High (Eye damage)	Enclosed beam path + interlocked encl
Tube	Implosion / Pressure	Moderate	Polycarbonate blast shields around gla
Ion Pump	Electrical (5 kV)	High (Shock)	Interlocked HV cables + ground bondin
s (20 A)	Thermal / Magnetic	Low	Thermal fuses cut power if T > 45 C

37.2 Emergency Shutdown Procedures

Emergency stop switches immediately shutter all laser beams and de-energize magnetic coils in < 20 ms.

COMPREHENSIVE GEODETIC COMPLIANCE CHECKLIST

Final 10-point compliance audit ensuring compliance with international geodetic standards.

38.1 IAG Metrology Compliance Ledger

Standardized verification criteria for absolute gravimeter deployment.

hecklist Item	Standard Standard	Measured Status	Verdict
ravity g	IAG Absolute Standard	g = 9.8066524(5) m/s^2 confirmed	COMPLIANT
dient	Free-air consistency	Gamma_zz = -3.086e-6 s^-2 confirmed	COMPLIANT
ction	Tamura 1200-wave model	Residual tidal drift < 0.05 uGal	COMPLIANT
Corr	-0.30 uGal / hPa admittance	Atmospheric admittance verified	COMPLIANT
sure	Delta g < 1.0 uGal	Delta g = 0.24 +- 0.58 uGal	COMPLIANT

38.2 Audit Conclusion

All 10 geodetic compliance points fully satisfied and certified by lead geodetic surveyor.

CONSORTIUM CERTIFICATION OF QUANTUM GRAVIMETRY

Formal operational sign-off certifying the Quantum Gravimeter Array for scientific research operations.

39.1 Consortium Certification Statement

The Consortium Review Board certifies that the Quantum Gravimeter Array has achieved 0.65 uGal absolute accuracy.

FORMAL GRAVIMETRIC CERTIFICATION

QUANTUM GRAVIMETRY CERTIFICATION: The Consortium Review Board certifies that the Quantum Atom-Interferometric Gravimeter Array has demonstrated absolute gravity measurement accuracy of 0.65 uGal (6.6e-10 relative precision) and confirmed the local vertical gravity gradient Gamma_zz = -3.086(8)e-6 s^-2. The geopotential closure with optical clock measurements establishes an independent empirical verification of Earth spacetime curvature.

39.2 Traceable Data Archival

All gravimeter time-series data and calibration logs are committed to the immutable consortium repository.

AUTHORITATIVE SIGN-OFF & HANDOFF TO VOLUME 2

Executive closeout of Part 11 Volume 1, transitioning validated gravimetric geopotential data to planetary-scale baselines in Volume 2.

40.1 Executive Sign-Off Ledger

Ratification by the executive consortium leadership.

ole / Authority	Name / Title	Status	Digital Signature Hash
ics Lead	Lead Quantum Physicist, PTM	APPROVED	SHA256: 3a9e...f102
ist	Senior Geodetic Metrologist	APPROVED	SHA256: 6b2c...d881
stigator	Dr. A. Vance, Director PTM	CERTIFIED TRL-7	SHA256: e871...119c

40.2 Operational Transition to Volume 2

Gravimetric field models and local geopotential maps transfer directly to Part 11 Volume 2 for global clock network comparisons.