

SYLTRA

Smart Living. Seamlessly Connected.

INTEGRATED MANAGEMENT SYSTEM

Integrated Management System Blueprint

ISO 9001:2015 · ISO 14001:2015 · ISO 45001:2018

Quality, Environmental & Occupational Health and Safety

Site safety protocols, audit governance & vendor alliance strategy

1. Integrated Management System (IMS) Framework

SYLTRA operates a single Integrated Management System (IMS) that fuses Quality (ISO 9001:2015), Environmental (ISO 14001:2015), and Occupational Health & Safety (ISO 45001:2018) management into one unified operating model, purpose-built for automation, smart-systems integration, and field maintenance services.

Rather than running three parallel systems, SYLTRA aligns policy, risk assessment, document control, audit cycles, and management review into a shared governance structure — reducing duplication while raising the consistency of evidence collected across every engagement. The IMS follows the Plan-Do-Check-Act (PDCA) cycle at both the corporate and project level.

Standard	Core Focus for SYLTRA	Key Output Records
ISO 9001:2015	Accuracy in PLC/SCADA programming, precision wiring, hardware verification, and zero-defect commissioning.	FAT/SAT records, Customer Satisfaction Surveys, NCRs.
ISO 14001:2015	Safe collection, categorization, and ecological disposal of industrial electronic waste and spent batteries.	E-Waste Log, Disposal Certificates, Environmental Aspect Register.
ISO 45001:2018	Mitigation of live electrical shock hazards, LOTO protocols, and safe installation on cable trays.	Electrical Work Permits, Toolbox Talks Ledger, Incident Register.

1.1 Integration Governance

A single IMS Representative (the Quality & HSE Manager) owns cross-standard coordination, ensuring a change raised under one standard is screened for impact on the procedures it touches. Document control, audit scheduling, and management review run as shared processes rather than three separate calendars.

2. Site Safety & Commissioning Protocols (Toolbox Talks)

Every operational morning, site managers conduct a short briefing with technical personnel before execution begins, logged in the Toolbox Talks Ledger.

Protocol A — Live Electrical Panel Safety & LOTO

- Always use calibrated multimeters to confirm voltage absence before touching contacts.
- Execute Lock-Out Tag-Out (LOTO) on source circuit breakers; only the active technician holds the key.
- Class 00 / Class 0 insulated gloves and insulated safety footwear are strictly mandatory.

Protocol B — Safe Programming & On-Site Testing

- Never push modified logic without saving a local, time-stamped restore point.
- Confirm all mechanical areas are clear of personnel before switching a PLC to Run mode.
- Every commissioning session defines a documented rollback path.

Protocol C — Working at Height & Cable Tray Installation

- Full-body harness with a certified anchor point is mandatory above 1.8m.
- Cable trays and supports are inspected for rated load capacity before routing new runs.

Protocol D — Emergency Response on Site

- CO2 fire extinguishers staged within 10 meters of every active panel work area.
- 100% of field technicians trained in electrical-shock rescue and basic first aid.

3. Annual Internal Audit Schedule

SYLTRA executes a cross-departmental, impartial internal audit scheme with rotated auditors and defined non-conformity closure deadlines.

Department	Targeted Clauses	Audit Focus Points
Engineering & Design	ISO 9001: 8.3	Software revision control, backup logs, design-input validation.
Site Operations	ISO 45001 / 14001	LOTO logs, hazardous e-waste containment, PPE adherence.
Procurement / Stores	ISO 9001: 8.4	Vendor evaluations, calibration validity of testing equipment.
Customer Support	ISO 9001: 9.1	SLA adherence and closure quality of maintenance tickets.
HR & Training	ISO 9001 / 45001	Competency records and safety certification validity.

4. Management Review Agenda

An annual executive meeting verifies the structural health and compliance of SYLTRA's operational framework.

Input Parameters

- Status of actions from previous management reviews.
- Performance and effectiveness of the IMS, including audit results and customer satisfaction.
- Adequacy of resources to sustain operations.

Decision Outputs

- Resource allocations for the following operating period.
- Targeted training pipelines and certification plans for engineering teams.

5. Global Vendor Alliance Strategy (Siemens / Schneider Electric)

The strategic path to achieve official System Integrator status with tier-one automation vendors:

- **Talent Pipeline Certification:** Enroll two engineers in official certification pipelines.
- **Track Record Compilation:** Document three successful automation case studies backed by FAT/SAT evidence.
- **Compliance Sync:** Leverage this IMS documentation to satisfy vendor partner-audit requirements.
- **Formal Application:** Submit the System Integrator package and host the technical review visit.

6. Roles & Responsibilities (RACI Summary)

R=Responsible, A=Accountable, C=Consulted, I=Informed.

Process	Exec. Mgmt	Quality & HSE Mgr	Site Lead	Technicians
Document Control	I	A/R	C	I
Internal Audit	I	A/R	C	I
Toolbox Talks	I	C	A/R	R
NCR & Corrective Action	I	A	R	C
Management Review	A/R	R	I	I

Disclaimer: This system documentation blueprint is compiled for corporate structural development purposes based on ISO guidance and standard engineering practices. All field testing and execution must strictly respect active country laws and engineering safety declarations.