

**SYLTRA**

Smart Living. Seamlessly Connected.

QUALITY MANAGEMENT SYSTEM

# ISO 9001:2015

## Quality Management

---

ISO 9001:2015

Documented processes for precision automation delivery

Quality manual, mandatory procedures, templates & audit checklist

# 1. Organizational Profile & Scope

---

SYLTRA is a technology and engineering company delivering commercial automation, smart-control installation, maintenance, and integration services for facilities and industrial sites.

**Scope of Application:** This Quality Management System covers all processes and departments involved in the supply, design, installation, and maintenance of automation systems, as well as after-sales support and technical assistance at SYLTRA's headquarters and client execution sites.

# 2. Context of the Organization

---

SYLTRA monitors and reviews the internal and external factors affecting its strategic direction and its ability to achieve the intended results of the Quality Management System.

## External Issues

Rapid technological development in automation engineering, evolving legal and regulatory requirements, market competition, and pricing volatility for sensitive supply equipment.

## Internal Issues

Engineering and technical staff competency, stability of the software infrastructure, responsiveness to maintenance reports, and availability of essential spare parts.

## Interested Parties & Their Requirements

- **Customers:** Stable and secure automation systems, precise execution on schedule, and fast preventive/corrective maintenance.
- **Suppliers:** Clear purchase orders, adherence to payment schedules, and transparency on required technical part specifications.
- **Government & Regulatory Bodies:** Compliance with occupational safety standards and commercial/labor law.
- **Employees (Engineers & Technicians):** A safe work environment, continuous training on modern software systems, and fair performance incentives.

# 3. Quality Policy

---

SYLTRA is committed to delivering leading commercial and engineering solutions in automation installation, maintenance, and execution that exceed customer expectations, by focusing on:

- The highest levels of precision and reliability in designing and operating automated systems for complex client needs.
- Full compliance with all applicable local and international laws, regulations, and legislative standards.
- Continuous development and improvement of our processes and Quality Management System in line with ISO 9001:2015.
- Raising the competency and skills of our engineering and technical staff to keep pace with the latest global technologies in automation, control, and artificial intelligence.

*Top management endorses this policy and ensures it is communicated, understood, and applied at every organizational level.*

# 4. The 4 Mandatory Operating Procedures

---

## Procedure 1 — Documented Information Control

**Objective:** Standardize the mechanism for creating, reviewing, approving, amending, and retaining all documents and records related to SYLTRA's quality system.

- The document originator drafts it per the approved template, then submits it to the relevant department manager for review.
- The Quality Management Representative (or Executive Manager) approves the document before official distribution and use.
- Every document receives a unique identifier (code) including revision number and approval date for traceability.
- Paper records are retained in designated storage; electronic copies are stored on protected servers with access controls preventing unauthorized edits.
- Documents are reviewed periodically (at least annually) to confirm they remain aligned with actual working practices.

## Procedure 2 — Internal Audit

**Objective:** Systematically and independently verify that the company's Quality Management System conforms to ISO 9001:2015 and to internally approved procedures.

- Prepare an annual audit plan covering all departments and processes (sales, installation projects, maintenance, HR, procurement).
- Select qualified internal auditors independent of the departments they audit, to ensure complete impartiality.
- Use pre-prepared checklists to gather evidence, observe real conditions, and review inspection and field-installation records.
- Log non-conformities (if any), issue final reports, and deliver them to relevant department managers with corrective deadlines.
- Follow up on the implementation of corrective actions, measure their effectiveness, and formally close reports.

## Procedure 3 — Management Review

**Objective:** Evaluate the suitability, adequacy, and effectiveness of the Quality Management System and its alignment with the company's strategic direction, as assessed by top management.

- Top management holds a management review meeting on a regular cycle (at least every 6–12 months).
- The Quality Representative prepares meeting inputs, including: status of previous actions, context changes, audit results, customer satisfaction, supplier performance, and risk management.
- Inputs are discussed and meeting outputs issued, including decisions and recommendations on improvement opportunities, policy amendments, and resource needs.
- Meeting proceedings are fully documented in a "Management Review Minutes" record, signed by all attendees, and retained as a mandatory quality record.

## Procedure 4 — Non-Conformity & Corrective Action

**Objective:** Address deviations from required specifications during supply, installation, or maintenance, and prevent their recurrence.

- When any defect is detected (e.g. an automation programming error, a faulty supplied part, delayed maintenance response), a Non-Conformity Report (NCR) is opened.
- An immediate containment action is taken to limit the direct impact of the defect and protect the customer's interest (e.g. immediate replacement of a defective part).
- A working team forms to conduct Root Cause Analysis using methods such as the 5 Whys or a fishbone diagram.
- A corrective action plan is set to prevent recurrence of the root cause, with a named owner and timeline.
- After a defined period, effectiveness is verified before the non-conformity report is formally closed.

## 5. Ready-to-Use Operational Templates

### Template A — Risk & Opportunity Matrix for Automation and Installation

| ID   | Process                  | Potential Risk                                           | Expected Impact                                          | P | S | Level    | Preventive Action                                               | Owner           |
|------|--------------------------|----------------------------------------------------------|----------------------------------------------------------|---|---|----------|-----------------------------------------------------------------|-----------------|
| R-01 | Supply & Purchasing      | Delayed arrival of control components (PLCs) from abroad | Delayed delivery of client installation projects         | 3 | 4 | 12 (Med) | Diversify supply sources; hold safety stock for critical parts. | Procurement Mgr |
| R-02 | Execution & Installation | Programming error in on-site control panel               | Disruption to client production line or equipment damage | 2 | 5 | 10 (Med) | Run simulation testing in the workshop before site transfer.    | Project Mgr     |
| R-03 | Maintenance & Support    | No emergency maintenance technician available on call    | Breach of SLA and customer dissatisfaction               | 2 | 4 | 8 (Low)  | Flexible on-call roster; remote technical support system.       | Maintenance Mgr |

### Template B — Supplier Evaluation & Approval Record

Supplier Name: \_\_\_\_\_ Evaluation Date: \_\_/\_\_/\_\_\_\_ Materials/Services Supplied: (sensors, cabling, control panels, software, calibration)

**Scoring criteria (0–10 each):** material quality & conformity to spec; adherence to delivery schedule; flexibility, technical support & after-sales service; price competitiveness & payment terms.

**Decision:** Approved supplier (score > 30) · Trial/monitored supplier (score 20–30) · Rejected supplier (score < 20).

### Template C — Customer Satisfaction Survey

Covers: accuracy and efficiency of delivered automation systems; adherence to installation/delivery schedules; speed of maintenance and technical-support response during emergencies; availability of required spare parts and alternatives. Each item rated Excellent / Very Good / Acceptable / Poor.

### Template D — Non-Conformity Report (NCR) & Corrective Action

Captures: report number and detection date; department; detailed description of the non-conformity; immediate containment action and owner; root-cause analysis; proposed corrective actions with owner and deadline; effectiveness verification and formal closure sign-off by the Quality Manager.

## 6. Internal Audit Checklist (ISO 9001:2015)

Used to review and monitor department and process readiness ahead of the external certification audit.

| Clause   | Audit Requirement                                                                                                           | Conforms? | Evidence / Field Notes                                                       |
|----------|-----------------------------------------------------------------------------------------------------------------------------|-----------|------------------------------------------------------------------------------|
| Clause 4 | Has the company identified the internal/external issues affecting its automation systems and operating context?             |           | Review of the context matrix and organizational scope in the Quality Manual. |
| Clause 5 | Does top management demonstrate commitment, and is the quality policy declared and understood by engineers and technicians? |           | Verify policy sign-off and posting at HQ and affiliated workshops.           |
| Clause 6 | Is there a clear, documented mechanism for identifying supply-delay and programming-error risks and response plans?         |           | Review the approved operational risk & opportunity matrix.                   |

| Clause     | Audit Requirement                                                                                                          | Conforms? | Evidence / Field Notes                                                      |
|------------|----------------------------------------------------------------------------------------------------------------------------|-----------|-----------------------------------------------------------------------------|
| Clause 7   | Are competency, qualification, and training records maintained for installation and maintenance engineers/technicians?     |           | Review training files and qualifications with HR.                           |
| Clause 7.5 | Are quotations, engineering drawings, and supply invoices controlled and coded per the document-control procedure?         |           | Spot-check samples of executed automation drawings and their codes.         |
| Clause 8   | Is there a precise review of customer engineering requirements before design and execution begin?                          |           | Review signed contracts and preliminary technical meeting minutes.          |
| Clause 8.4 | Are suppliers of sensitive components and control panels evaluated periodically to ensure supply-chain integrity?          |           | Inspect completed supplier evaluation records from the last 6 months.       |
| Clause 8.5 | Are field installation and maintenance operations under engineering supervision, with acceptance/testing minutes recorded? |           | Review inspection and commissioning reports signed by the customer on site. |
| Clause 9   | Are customer satisfaction surveys distributed periodically, and has at least one internal audit been conducted this year?  |           | Review survey statistics and internal audit reports.                        |
| Clause 10  | When a software or technical fault occurs post-delivery, are non-conformity and corrective-action procedures activated?    |           | Inspect the NCR log and verify closure and prevention of recurrence.        |