X Construction Sdn Bhd INCIDENT/ACCIDENT INVESTIGATION REPORT

PART A						
Report NO: 161057						
Investigation Team						
1. AnasSHO (Leader)						
2. Amir						
3. Hilmi						
Terms of Reference						
1. Site Of Incident	REF-20240521-BPWIT4					
2. Copy Of HIRARC	REF-20240521-D4URY7					
3. Interview Victims or Witness	\bigcirc					
Category of Incident : Fatal						
When and Where did the Incider	nt Occur?					
The incident occurred on 21-05-2	2025 at 13:12:00. It occurre	ed at Sarawak.				
Description of the incident :						
A fifth-grade student died after b	eing struck by a goalpost v	hile hanging from it.				
Description of property damage	(if any):					
Goalpost has broken.						
How did the incident occur :						
REF-20240521-SUVZVU						
Kid was hanging on a broken and rusty goalpost which eventually broke and cause the fall.						
Findings of the investigation :						
The goalpost is already rusty and	d on the end of being broke	en.				
Reported By :						
\mathcal{A}						
AnasSHO						

X Construction Sdn Bhd HAZARD IDENTIFICATION, RISK ASSESSMENT, AND RISK CONTROLS REGISTER

Project/HQ: X Construction Sdn Bhd	Description of Job : Falsework and Scaffolding Temporary Structure	Prepared By : AnasPM	Hirarc No :
Location: Jayyid	Verified By: AnasSHO	Approved By: AnasPM	Date: 21/05/2024

Hazard Identification			Risk Assessment					Risk Control			
No	Job Sequence	Hazard	Risk	Current Control	L	s	Score	Index	Opportunity	New Control (Suggestions)	Responsibility
1	Material management	Obstruct Material	Tripping by obstruct material	+short briefing before work +use proper PPE	2	3	6	М			Supervisor
2	Erection & and installation of false work/ temporary structure	Pinch point	Minor Injury	+toolbox briefing +use trained workers +short briefing before work +use proper PPE	2	2	4	L			Supervisor
3	Cont	Falling Material	+physical injury +material damage	+toolbox briefing +use trained workers +housekeeping work +any tools need to be secure	3	3	9	M			Supervisor

Rev No:

Issue Date:2024-04-11

X Construction Sdn Bhd HAZARD IDENTIFICATION, RISK ASSESSMENT, AND RISK CONTROLS REGISTER

Project/HQ: X Construction Sdn Bhd	Description of Job : Falsework and Scaffolding Temporary Structure	Prepared By : AnasPM	Hirarc No :
Location: Jayyid	Verified By: AnasSHO	Approved By: AnasPM	Date: 21/05/2024

	Hazard Identification			Risk Assessment					Risk Control			
I	No	Job Sequence	Hazard	Risk	Current Control	L	s	Score	Index	Opportunity	New Control (Suggestions)	Responsibility
,	1	Cont	Falling Material	+physical injury +material damage	+toolbox briefing +use trained workers +housekeeping work +any tools need to be secure		3		М			Supervisor

Rev No:

Issue Date:2024-04-11