PURCHASE DESCRIPTION
AIR COMPRESSOR

1. GENERAL SYSTEM DESCRIPTION

This requirement will require the contractor to supply and install an air compressor to the Rock Island Arsenal-Joint Manufacturing & Technology Center (RIA-JMTC). This will be tied into existing air compressors at RIA-JMTC. The system will include an air compressor, air dryer, oil-water separator and any other components or materials necessary for operation. The system will compress, dry and supply air to multiple buildings at JMTC.

2. STANDARDS AND PUBLICATIONS

2.1 Clarification

Any ambiguities, questions, requests for clarification or discrepancies between sections of this purchase description, drawings, national or industry standards discovered by the contractor in reviewing this purchase description shall be reported by the bidder in writing to the contracting officer BEFORE THE DATE SCHEDULED FOR CLOSE OF BIDDING/receipt of proposal. Submission of a proposal or bid shall be construed as evidence that such examination has been made. Therefore, later claims for labor, material, or equipment required, or for difficulties encountered, which could have been foreseen had such reasonable examination been made, may be denied.

3. DESIGN

3.1 Ownership

3.1.1 This equipment is a standard product of the manufacturer and shall require either no change or minor design changes to meet requirements of these specifications. Therefore, ownership of the design will remain with the manufacturer.

3.2 General Design Standards

3.2.1 <u>DEVIATION FROM PRODUCT</u>: Modifications to the manufacturer's standard design to achieve requirements as specified in this document are only permissible as dictated by good design practice. For example, mounting a 20-hp motor in a power train designed and normally using a 10-hp motor would not be acceptable.

3.2.2 <u>UNITS OF MEASURE</u>: Dimensions and capacities in this purchase description are given in the English-US (in-lb) system. All dials, gauges, and drawings shall be in the English-US system or both the English-US and the metric systems, unless otherwise specified in this document.

3.2.3 <u>ID DATA PLATE</u>: The equipment shall include a main data plate which will include the following data as a minimum requirement (additional information is acceptable): Manufacturer Name, Manufacturer's Dunns and Bradstreet Number, Manufacturer's Model Number, Manufacturer's Serial Number, Year of Manufacture, Contract Number, Machine Weight. This information is necessary for compliance with the government Unique Identification Program (UID).

3.2.4 <u>DATA PLATES</u>: All instruction, data, and identification plates and labels attached to this equipment and its controls shall be manufactured of corrosion and oil-resistant metal or plastic material. All wording shall be in the English language using plain, bold face lettering. Lettering shall be permanent and have a contrasting background.

3.2.5 <u>ITEM UNIQUE IDENTIFICATION (IUID) REGISTRATION</u>: The contractor shall register the equipment in the IUID Registry (as one single system). IUID registration requires the contractor to input Cage Code, Model Number, and Serial Number into a Government Database to allow for asset and inventory tracking. IUID Registry of the equipment shall be performed at http://dodprocurementtoolbox.com/site/uidregistry/. Training for IUID is available in https://wawftraining.eb.mil. IUID registration of this equipment is required prior to final payment in the Wide Area Work Flow (WAWF). The contractor shall also affix a machine readable 2-dimensional (2-D) matrix representing the IUID registry to the machine. The IUID 2-D matrix may be included on the ID Data Plate outlined in paragraph 3.2.4.

3.2.6 UTILITY CONNECTION: Equipment supplied to the Rock Island Arsenal will have single point shut off for each utility supplied to a system. This means that equipment constituting a single system shall be wired to a single main electrical disconnect point, plumbed to a single pneumatic shut-off valve, etc… This will be referred to as the "point of first connection". Each type of power source may have only one point of first connection. E.g. (1) pneumatic shut-off valve, (1) water supply shut-off valve, (1) electrical disconnect, etc… Each point of first connection shall be clearly labeled on the system and shown in the safety lockout portion of the documentation package. These points must be located on a stationary component and positioned such that they will not create a hazard to personnel during normal operation of the system. The first connection points shall be accessible from the shop floor without the use of ladders, steps, or stools. Access cannot be hampered by operation of the system.

3.2.7 UTILITY CONNECTION LABOR: Rock Island Arsenal shall provide only such labor and materials as will be needed to connect facility utilities to each point of first connection of the system. The supplier will be responsible for all connections beyond the point of first connection for each utility.

3.2.8 UTILITIES AVAILABLE: Rock Island Arsenal shall be responsible for providing the following:

3.2.8.1 Connection of 460-V, 60-Hz, 3-Ph AC electrical power to the fused or breaker type disconnect switch required in the ELECTRICAL DISCONNECT paragraph of this purchase description. Connection does not include filters, surge protection, or any peripheral equipment necessary to make the equipment functional.

3.2.8.2 Connection of approximately 80-psi compressed air to a single point for each system, if needed. Connection does not include filters, dryers, or any peripheral equipment necessary to make the equipment functional.

3.2.8.3 Connection of approximately 65-psi water to a single point for each system, if needed. Connection does not include filters or any peripheral equipment necessary to make the equipment functional. If water is required, the contractor shall be responsible for installing a backflow limiting device sufficient to prevent possible contamination of the water system. This is necessary to maintain IEPA compliance.

3.2.8.4 Connection of 1.5-in diameter natural gas pipe with a 5-psi pressure within the plant to a single point for each system, if needed. Connection does not include filters or any peripheral equipment necessary to make the equipment functional.

3.2.8.5 If, due to contractor caused problems, the equipment or components of the equipment must be moved or removed and replaced, by RIA after initial placement, the contractor shall be billed for such work at current RIA labor and overhead rates.

3.2.9 ELECTRICAL DISCONNECT: The equipment shall be equipped with a manual, fused or breaker type disconnect switch, readily accessible to the operator, which will deactivate the entire equipment. It shall be located no more than 6-ft 7-in from the floor to the highest point the control device. It shall be capable of being locked in the de-energized state (OFF) only.

3.2.10 CONDUIT: Flexible conduit is not permitted in exposed areas. All wires, cables, and hoses will be enclosed by rigid, oil-proof protection, except where flexibility is necessary for operation of the equipment. Flexible wires, cables and hoses shall be arranged to prevent draping or tripping hazards.

3.2.11 SERVICE ACCESS: Components subject to periodic adjustment, replacement, or servicing shall be readily accessible. Meaning that experienced personnel can access the part after no more than 30-min of labor. If any special tools or equipment are necessary to access these components, said equipment will be supplied as part of the system and provided with a proper storage location within the system.

3.2.12 DEFLECTION: The system shall recover from distortion and deflection at no load. The machine and its components shall be sufficiently rigid that work piece finish and tolerances are not impaired by machine vibration.

3.2.13 NEW EQUIPMENT: The equipment furnished under this purchase description shall be new and unused.

3.2.14 COMPONENT ENVIRONMENT: Under no circumstances shall a component be used in an application not recommended by the component manufacturer. Components shall not be subjected to conditions of operation beyond the recommendations of the manufacturer, such as excessive heat, lack of lubrication, over-loading.

3.2.15 REPLACEMENT COMPONENTS: All replaceable components shall be manufactured to definite standards for tolerance, clearance, and finish, enabling components to be field installed without further machining.

3.2.16 CASTINGS AND FORGINGS: All castings and forgings shall be free of defects, scale, and mismatching. No process such as welding, peening, plugging, or filling shall be used for reclaiming any defective part for use in this equipment without the prior written consent of the contracting officer.

3.2.17 SURFACE BUILDING AND COATINGS: Welding, brazing, soldering, coating or plating shall be employed only where specified in the original design. These operations may not be employed as a means of reclaiming a defective part.

3.2.18 FASTENING DEVICES: All screws, pins, bolts, and similar parts shall be installed in such a manner as to prevent change in tightness. Those devices subject to removal or adjustment shall not be swaged, peened, staked, or otherwise permanently deformed. They shall not be installed using permanent bonding adhesives.

3.2.19 CLEANING AND DEBURRING: All surfaces of castings, forgings, molded parts, stampings, and welded components shall be cleaned and free from sand, dirt, fins, flash, scale, flux, and other harmful or extraneous materials. All edges shall be either rounded or beveled unless sharpness is required to perform a necessary function. Except as specified herein, the condition and finish of all surfaces shall be commensurate with the manufacturer's commercial practice.

3.2.20 PAINTING: All unfinished surfaces of the equipment shall be painted with a lead free and chromium free commercial grade of metal primer and a minimum of one finish coat. The color shall be in accordance with the manufacturer's standard commercial practice, or as necessary to maintain compliance with OSHA regulations, as applicable.

3.2.21 LUBRICATION: Components specified as requiring lubrication by the original manufacturer shall have an appropriate means of providing said lubrication included in the design of the machine.

3.2.21.1 The lubrication points will be labeled on the lubrication drawing provided as part of the maintenance documentation and will also be labeled on the machine at the lubrication point and on any access panel covering the lubrication point. These labels will include as a minimum standard, the specific type of lubricant, the quantity to be used, the frequency for change, and the maintenance manual reference for detailed instructions. The lettering shall be English and the units shall be English standard (i.e. pints, quarts, and gallons)

3.2.21.2 If an automatic circulation system is used, it shall be complete, including, but not limited to the following: reservoir, valves, nozzles, filters, pumps, sight gages, and other components as necessary to make the system completely functional.

3.2.21.2.1 A system allowing blockages or inadequacies to go undetected is unacceptable. The system shall be interlocked to the machine control, providing an alarm that lubrication failure has occurred. The system shall not initiate immediate shutdown of the affected function during a cutting cycle. It shall allow completion of the cycle and shutdown in an orderly sequence.

3.2.21.2.2 The reservoir shall be sized to allow no less than 80-hrs of machine run time before requiring refill. It shall also have a means provided for draining and cleaning. A means shall be provided to enable the operator to determine the fluid level.

3.2.21.2.3 All filters shall be either cleanable or replaceable.

3.2.21.2.4 All pumps shall be self-priming.

3.2.22 FILTRATION/REGULATION: Equipment requiring filtered or regulated energy sources shall be supplied with the components necessary to perform this function. E.g. the equipment shall be supplied with a Filter, Regulator, Lubricator (FRL) device, if filtered, lubricated, regulated pressurized air is required for the efficient, proper operation of the equipment. These devices shall be located on the equipment side of the lockout devices at the points of first connections.

3.2.22.1 Equipment which requires compressed air shall have a regenerative type desiccant or refrigerated compressed air dryer capable of drying air down to 35°F pressure dew point, minimum, from air entering the equipment at 110°F, and capable of supplying air to the rated standard cubic feet per minute (SCFM) of the equipment. The unit shall purge condensate automatically. In the case of the latter, the refrigerant used shall not be a Class I or Class II, ozone depleting substance. The air dryer shall be connected and/or piped to the equipment by the contractor.

3.2.22.2 Equipment which requires a high quality constant power source shall have proper isolation and/or power conditioning equipment for the power service designated in this description. All electrical equipment shall have a power factor (ratio of real power to apparent power) of no less than 80%, as read at the equipment main disconnect. Equipment with a power factor of less than 80% shall be fitted with suitable power factor correction capacitance, sized on the basis of the equipment inductive AC load.

3.2.23 HYDRAULICS: The machine will be equipped with a hydraulic system and the system shall be complete with, but not limited to, pump, valves, piping, cylinders, pressure controls, filter, and reservoir. All components necessary to make the system completely functional shall be provided.

3.2.23.1 If the duty cycle of the system under maximum usage will cause the hydraulic fluid to exceed 120°F in temperature, a suitable air-cooled heat exchanger shall be provided to maintain fluid temperature at or below that temperature. The exchanger shall be equipped with changeable fiberglass filter(s), unless permanent type filters are supplied.

3.2.23.2 The system shall have adequate capacity to provide sufficient pressure and flow to perform all hydraulic operations under all normal machine operating conditions.

3.2.23.3 Protection shall be provided to prevent damage to components.

3.2.23.4 Safeguards shall be provided to alert the operator of temperatures and pressures above/below design limits. If safe limits (within design limits) are exceeded, the system shall automatically shut down.

3.2.23.5 Anti-surge devices or circuits shall be incorporated to ensure uniformity of motion under varying loads.

3.2.23.6 The hydraulic reservoir shall be provided with means for draining and cleaning.

3.2.23.7 Means shall be provided to enable the operator to determine fluid level.

3.2.23.8 Each hydraulic system shall include a filter, which shall be either cleanable or replaceable.

3.2.23.9 All pumps shall be self-priming.

3.2.24 COOLANT: The machine will be equipped with a coolant system and it shall be equipped with external flood coolant capabilities, as a minimum. Machines using cutting tools shall be equipped with both through the tool and external flood coolant capabilities. Coolant on/off shall be a machine control function.

3.2.24.1 The coolant systems shall include all necessary components necessary to provide completely functional systems, with sufficient capacity to give satisfactory service and provide adequate pressure and flow under normal operating conditions.

3.2.24.2 Coolant troughs and chip screens shall be provided around the machine table base to trap, direct, and return the coolant to the reservoir. An easily removable strainer shall be provided in the return line to the reservoir. "Easily removable" is defined as being removable after no more than 5-min of work by experienced personnel.

3.2.24.3 All machine coolant systems and their components shall provide drip-proof coolant delivery to the coolant point of discharge. In addition, the machine shall be designed and constructed to prevent coolant from escaping the confines of the machine or leaking to the floor when producing work-pieces of a size within the dimensions of the machine table.

3.2.25 MOTORS:

3.2.25.1 All motors shall be rated for continuous duty.

3.2.25.2 Motors shall not operate in an overload condition during normal operation of the equipment and shall be equipped with overload protection.

3.2.25.3 Each motor shall bear an identification plate containing the identity of the manufacturer, model number, serial number, input voltage, amperage, horsepower, phase, frequency, duty cycle, and frame size or mounting identification.

3.2.25.4 Motor starters and controls shall operate at no greater than 120-VAC. It is preferred that they operate at 24-VDC.

3.2.25.5 Motor starters shall provide drop-out protection. This means that, in the event of a loss of power, the equipment shall be re-energized only by the deliberate action of the operator. Manual or mechanical motor starters shall not be deemed acceptable.

3.2.26 DIALS AND GAUGES: All scales, dials, and gauges shall be manufactured of corrosion and oil-resistant material. All wording shall be in the English language using plain, bold face lettering. Lettering shall be permanent and have a contrasting background.

3.2.27 FOUNDATION: The requirement for a separate foundation or floor alteration is not permissible. The system shall be capable of being installed on an existing concrete floor without modification to the system or the floor, except for installation of anchor bolts. The existing floor is 9-inch tall, raised concrete.

3.2.27.1 The equipment location will be in B220 Basement on an existing 15’ X 10’ concrete slab and surrounding concrete. A raised section of the slab remaining from previous use will be leveled by RIA-JMTC to prepare the foundation prior to machine placement. Remaining equipment will sit beside the concrete slab on existing unraised concrete flooring.

3.3 Safety, Security and Environmental

3.3.1 SECURITY: The RIA-JMTC is an Army installation subject to Department of Defense safeguards, various precautions, and plant protection measures. All of the below requirements will be necessary of contractors visiting RIA to satisfy requirements of this purchase description; Additional requirements will be placed on contractors requiring access to the Army Network, or Common Access Card (CAC), as specifically detailed below. At all times during the execution of this work, contractor personnel will maintain adequate plant protection devises to minimize espionage, sabotage, and other malicious destruction and damage. The contractor shall comply with all security requirements of the Rock Island Arsenal. Rock Island Arsenal island-wide Force Protection levels may be adjusted/changed at any time, which may cause possible delays and will directly affect procedures for accessing the island.

3.3.1.1 Access and General Protection/Security Policy and Procedures: The contractor and any associated subcontractor employees shall provide all information required for background checks to meet installation access requirements to be accomplished by the installation Director of Emergency Services. All contractor employees must comply with all personal identity verification requirements (IAW FAR clause 52.204-9) as directed by Department of Defense (DoD), Headquarters Department of the Army (HQDA), and any local policy. If the Force Protection Condition (FPCON) changes, the Government may require changes in contractor installation access, security matters, or security processes.

3.3.1.1.1 Access to RIA: Contractor and all subcontractor employees performing work at RIA shall comply with adjudication standards and procedures using the National Crime Information Center Interstate Identification Index (NCIC-III) and Terrorist Screening Database (TSDB) and any applicable installation, facility access screening and local security policies and procedures. The JMTC Representative/ COR shall provide guidance to complete the Access Control Records Check request Form though the Rock Island Arsenal Directorate of Emergency Services.

3.3.1.1.2 Random Antiterrorist Measures Program (RAMP) participation: Contractor personnel are subject to RAMP security program (i.e. vehicle searches, wearing of ID badges, etc.). Contractor shall comply with any, and all instructions issued by the Rock Island Arsenal Police Department. The RAMP is discussed in the RIA-JMTC Anti-Terrorism Training.

3.3.1.1.3 During FPCONs levels of Charlie or Delta, services may be discontinued/postponed due to a higher National or local security threat. Services will resume when FPCON Level is reduced to Bravo, or lower. FPCON levels are described in Anti-Terrorism Level I Training.

3.3.1.1.4 Contractor personnel shall return all Installation Badges and access passes as soon as possible prior to contract completion. RIA-JMTC electronic keys and access passes are accountable items, shad shall be returned within 24-hours of no longer being needed. Items will be returned to the COR, or paced in a drop box at a RIA-JMTC access point.

3.3.1.2 Security Training: The contractor shall complete the following training:

3.3.1.2.1 Anti-Terrorism, Level I: All contractor employees, including subcontractor employees, requiring access to Army installations, facilities, or controlled access areas shall complete Anti-Terrorism (AT) Level I Awareness training. The COR will be provided a copy of the Rock Island Arsenal –Joint Manufacturing and Technology Center (RIA-JMTC) AT Level I Awareness Training and assure that the training is complete. The contractor shall sign a memorandum of record for each contractor employees and subcontractor employee to the RIA-JMTC Operations Center prior issuing any electronic keys, or access pass being authorized.

3.3.1.2.2 iWatch (See Something, Say Something) Training: The Contractor and all associated subcontractors shall complete iWatch Training. iWatch Training shall be provided during the Anti-Terrorism Training.

3.3.1.3 No CAC cards will be issued for this requirement.

3.3.2 <u>FEDERAL MARIJUANA LAWS REMAIN UNCHANGED</u>: Note: Rock Island Arsenal is under the exclusive federal jurisdiction of the United States. Under federal law, marijuana is still defined as a Schedule I drug, and possession and use of marijuana is still illegal. Any person using or in possession of marijuana on Rock Island Arsenal may be criminally prosecuted in federal district court. In addition, such individuals may be permanently barred from entering Rock Island Arsenal.

3.3.3 <u>REAL ID</u>: Starting 07-May-2025 all personnel entering Rock Island Arsenal will be required to show a Real ID form of identification.

3.3.4 <u>FIRE PREVENTION AND PROTECTION</u>: The contractor shall comply with all fire prevention measures prescribed in the installation Fire Regulations, a copy of which is on file in the office of the Contracting Officer. A written fire permit shall be obtained from the installation Fire Marshall for use of open flame devices, such as torches, portable furnaces, tar kettles, or gas and electric welding and cutting equipment, in, on, or within 15-ft of the building. The contractor shall be liable for any fire loss to the Government properly attributable to negligence on the part of the contractor, including failure to comp1y with fire prevention measure described by the terms of this purchase description.

3.3.5 INDUSTRY AND REGULATIONS: The equipment shall comply with the most current of all local, state, and federal laws and regulations listed in Standards and Publications.

3.3.6 MATERIAL EXCLUSIONS: The equipment shall not contain polychlorinated biphenyl (PCB), ozone depleting substances (Class I or Class II), or asbestos materials.

3.3.7 SAFETY REGULATION COMPLIANCE: The contractor shall comply with standard OSHA and RIA safety standards, including conforming to confined space work requirements when applicable.

3.3.8 LOSS OF PRESSURE: Hydraulic and pneumatic circuits shall be designed such that loss of pressure, or pressure surges, shall not cause a hazard. Means shall be provided to prevent operation of the equipment with insufficient pressure, if such operation could cause a hazard.

3.3.9 TRAPPED ENERGY: Means shall be provided for the controlled release of stored energy. This energy may be in the form of, but not limited to, air and hydraulic pressure accumulators, capacitors, springs, counter balances and flywheels. When appropriate, a label shall be affixed to the stored energy source to identify the hazard.

3.3.10 WORKING RANGE: Hydraulic and pneumatic components shall be selected, which cannot be adjusted outside the safe working range of the circuit and/or equipment.

3.3.11 CONTROL GUARDS: Controls shall be guarded against accidental operation.

3.3.12 OPERATOR REACH: Controls shall be within reach and located such that the operator, when in the normal operating position, is not required to reach past moving parts, which may cause injury.

3.4 Responsibilities

3.4.1 SITE INSPECTION: Any site inspections and/or measurements, which must be taken in order to determine the suitability of the proposed location or to perform the design of the system, are the sole responsibility of the contractor. This may begin prior to completing the bidding process. Rock Island Arsenal will support this function through the POC (point of contact) by guiding personnel, facilitating security registration, and providing general assistance. The contractor will be responsible for providing any and all equipment necessary for this process.

4. COMPONENT SPECIFICATION

Equipment: The supplier shall furnish all equipment normally considered by him to be standard for his machine unless identified in this requirement to be of specific manufacture. The following equipment shall be provided in addition to the equipment specified in other sections of this purchase description, which may not be standard. The inclusion of standard equipment in this paragraph is inadvertent and should not be construed to allow duplication. The supplied equipment shall consist of a rotary screw air compressor, air dryer, oil-water separator and all other necessary components for complete installation and operation of the system as described below.

4.1 Dimensions:

4.1.1 DOOR ACCESS: The equipment shall be shipped either assembled or disassembled to pass through a door 14-ft wide by 12-ft high and shall not exceed 8.5-ft in length.

4.1.2 COMPONENT WEIGHT: The maximum weight of any one piece shall not exceed 20,000-lbs.

4.1.3 INSTALLED FLOORSPACE: When installed completely, the equipment shall be contained in an area 10-ft long and 15-ft long. Maximum height shall not exceed 10-ft.

4.2 Air Compressor:

4.2.1 The air compressor shall be an Ingersoll Rand model RS220IE-A125

4.2.1.1 The compressor shall be a minimum of 300 HP

4.2.1.2 The compressor's capacity shall be a minimum of 1582 cfm

4.2.1.3 The compressor's rated pressure shall be a minimum of 115 psig

4.2.1.4 The system shall be equipped with a NEMA Premium efficiency motor or equivalent

4.2.1.5 The system shall contain an XS-Series or equivalent remote intelligent control, delivering control functionality through user interface and remote access

4.2.1.6 The system shall be a leak-free design and be completely integrated. It shall feature steel braided oil hoses and O-rings face seals

4.2.1.7 Using progressive adaptive control, the system shall continually adapt to prevent downtime

4.2.1.8 An on-board IoT platform shall offer real-time monitoring to maximize uptime

4.3 Air Dryer

4.3.1 The air dryer shall be an Ingersoll Rand model DA3000JNVCA40G000

4.3.1.1 The dryer shall be a minimum of 6.8 HP

4.3.1.2 The system shall have a minimum capacity of 1800 cfm

4.3.1.3 The dryer shall use centrifugal separation to remove moisture from the chilled air though the use of a float-type or timed electric solenoid drain

4.3.1.4 The dryer shall operate only when required by load in order to save energy

4.3.1.5 A cold well of propylene glycol-water which provides ISO Class 4 quality air shall be maintained via full insulation of the thermal mass and high efficiency evaporator

4.3.1.6 The system shall be equipped with automatic controls to reduce energy draw

4.4 Oil-Water Separator

4.4.1 An Ingersoll Rand model AS180 PolySep Oil Water Separator shall be provided

4.4.1.1 The separator shall have a minimum capacity of 1800 cfm

4.4.1.2 The separator shall be able to withdraw and absorb any lubricant permanently

4.4.1.3 The system shall be capable of handling up to 380 liters/hr (100 gal/hr)

4.5 Machine Models

4.5.1 The contractor shall provide models of the machine to be used for cad drawing and programming purposes.

5. INFORMATION TECHNOLOGY SYSTEMS AND SUPPORT

5.1 Installation IT Support:

5.1.1 PERSONNEL: RIA-JMTC will not provide the technician credentials to access the workstation. Access to the workstation will be provided by the RIA-JMTC IT Support Staff escort. Removable Media e.g., CD/DVD/USB/SD/External hard drive will be scanned prior to use. Programs and software must be ran from RIA-JMTC approved/provided media or CD/DVD(s). Contractor Devices will not be allowed to connect to the RIA-JMTC network nor will they be allowed to connect to RIA-JMTC equipment other than to scan and transfer media.

5.1.2 An internet connection or connection to the RIA network shall not be required for use.

5.2 INSPECTION/FINAL ACCEPTANCE:

5.3 Media/ Devices

5.3.1 CONTRACTOR DEVICES: Contractor Devices will not be allowed to connect to the RIA-JMTC network and they will not be allowed to connect to RIA-JMTC equipment other than to scan and transfer media.

5.3.2 NON-GOVERNMENT OWNED SYSTEMS OR DEVICES: The contractor shall comply with AR 25-1 and AR 25-2. The contractor shall not install or connect non-Government-owned computing systems or devices to Government networks without the COR's coordination and obtaining the proper authorization from the appropriate Information System Security Manager (ISSM), ensuring that all software has a Government Assess Only Authorization. The non-Government-owned computing systems or devices include, but are not limited to, personal or Contractor-owned thumb drives e.g., memory sticks, flash drives, Universal Serial Bus (USB) drives, jump drives, pen drives, removable or external hard drives, Personal Digital Assistants (PDA), PC Cards/Express Cards, MP3 players, cell phones, digital media, floppy disks, compact disc (CD)/digital video disk (DVD) burners, optical recordings, photo flash cards, laptops, or any devices that can store data.

5.3 INFORMATION ASSURANCE AND ACCREDITATION:

5.3.1 Non-Government-Owned computing systems or devices: The Contractor shall comply with AR 25-1 and AR 25-2. The Contractor shall not install or connect non-Government-owned computing systems or devices to Government networks without a government representative coordinating and obtaining proper authorization from the appropriate Information System Security Manager (ISSM), ensuring that all software has a Government Assess Only Authorization. The non-Government-owned computing systems or devices include, but are not limited to, personal or Contractor-owned thumb drives e.g., memory sticks, flash drives, Universal Serial Bus (USB) drives, jump drives, pen drives, removable or external hard drives, Personal Digital Assistants (PDA), PC Cards/Express Cards, MP3 players, cell phones, digital media, floppy disks, compact disc (CD)/digital video disk (DVD) burners, optical recordings, photo flash cards, laptops, or any devices that can store data.COMPONENT SPECIFICATION

5.3.2 System Accreditation and Re-Accreditation: The Contractor shall assist in providing system accreditation documentation such as required artifacts and shall answer technical questions required for registration for accreditation. All documents shall be IAW Chapter 5, and Appendices D and E, AR 25-2, Information Systems Security (dated 3 August 2007) and DOD Instruction 8510.01, Risk Management Framework (RMF) Program or future DOD regulation that supersedes these regulations. The Contractor shall assist in performing yearly reviews of the accreditation, or whenever changes/additions are made to the system. The Contractor will assist in preparing risk assessments, as required.

6. APPROVAL/SHIPPING

6.1 Shipping

6.1.1 RESPONSIBILITY: The contractor is responsible for delivery of the equipment to the Rock Island Arsenal. Adequate preserving of equipment surfaces, packing, marking, and skidding of materials for shipment shall be the responsibility of the contractor. If special lifting devices, such as hooks or eyes, are required for ease of handling, they shall be supplied with the equipment. Any special devices shall be returned to the contractor upon request only if they will not be required for future movement of the equipment, and at the contractor's expense.

6.1.2 SHIPPING SCHEDULE: Be aware, the Rock Island Arsenal will only off-load equipment arriving between 6:00 am and 12:00 am (noon), local time on Mondays through Thursdays except holidays. For information concerning holidays, the contractor should consult the contracting officer. There is no place to stage transporting vehicles awaiting the arrival of contractors. All equipment shall be delivered at the same time, meaning the same day (multiple trucks are acceptable) unless pre-authorized to deliver on multiple days by the RIA-JMTC contracting officer.

6.1.3 RECEIVER: All shipments to Rock Island Arsenal including installation tools and/or replacement parts, as well as the original shipment of the equipment, shall be marked "ATTN: Mr. Robert Mcclure TARA-LGC". Items not correctly marked are subject to being returned at the vendor's expense.

6.1.4 ARRIVAL INSPECTION: Upon receipt of equipment at Rock Island Arsenal, a preliminary inspection shall be performed to determine condition and/or count. This inspection shall be performed by Rock Island Arsenal personnel.

6.2 Installation

6.2.1 SITE PREPARATION REQUIREMENTS: The contractor shall be solely responsible for any necessary site inspections required for determining the specifications of work that must be completed prior to final system installation. The contractor will then provide detailed information of any preparation work that the vendor must perform prior to system installation to Rock Island Arsenal.

6.2.2 SITE PREPARATION EXECUTION: The contractor will be solely responsible for site preparation except as specifically excluded in this document. This includes but is not limited to excavation, foundation work, and surface preparation. This work may be performed through the use of a sub-contractor, but the specification, supervision, and certification of the work remains the responsibility of the primary contractor.

6.2.2.1 RIA-JMTC will prepare the surface of the existing foundation. See section 3.2.29 for more information. It is expected that the air compressor will be placed on an existing raised concrete slab while the air dryer will be placed beside it on existing unraised concrete.

6.2.3 PREPARATION EXECUTION SUPPORT: Rock Island Arsenal will support the preparation portion of the installation by providing utilities to the points of first connection.

6.2.4 LABOR AND MATERIAL: The supplier is solely responsible for providing all labor, materials, hardware, tools, and equipment necessary for complete installation/start-up of this system except as specifically listed in this document as being provided by the Rock Island Arsenal.

6.2.4.1 Any lubricants, coolants, oils etc. required for initial start-up and operation shall be the responsibility of the contractor to provide.

6.2.4.2 Any anchoring mechanisms/materials shall be the responsibility of the contractor to provide. If RIA-JMTC is installation the foundation, JMTC will be responsible for the installation of the contractor provided anchoring mechanisms in preparation for machine placement.

6.2.4.3 Any decking, stairs, rail systems, or other specialized operator/machine interfaces shall be provided by the contractor for use at the install location

6.2.5 SUPERVISION: Supervision of the installation process will be the responsibility of the contractor. Rock Island Arsenal shall retain the right to periodic inspection and evaluation of the process, as it deems necessary.

6.2.6 OFF-LOADING/PLACEMENT: Off-loading of the equipment from the delivery vehicle, and placement of the equipment in position for the installation is the responsibility of the contractor. The contractor shall not be allowed to use government equipment to accomplish this work.

6.2.6.1 The components will enter the building through an overhead door. The end location of the equipment is the basement of building 220, meaning the door sits below ground. A forklift and/or other equipment will be needed to lower the equipment to the door below. The height needed to lower the equipment is 6.5-ft. RIA-JMTC personnel will assist in this process.

6.2.7 OFF-LOADING/PLACEMENT OPTION: At the request of the contractor, Rock Island Arsenal will perform the off-loading and placement of the equipment.

6.2.7.1 Any special requirements or precautions to be observed shall be the responsibility of the contractor to provide.

6.2.7.2 The contractor or his representative may be present during this process; however, such person will be responsible for being present upon arrival of the equipment at Rock Island Arsenal. Off-loading and placement shall not be delayed to allow arrival of the contractor or his representative.

6.2.7.3 If, due to contractor caused difficulties, the equipment or components of the equipment must be moved, removed or replaced by Rock Island Arsenal after initial placement, the contractor shall be billed for such work at current Rock Island Arsenal labor and overhead rates.

6.2.8 LIABILITY: In any case, the equipment remains the property of the contractor, and the contractor shall assume all responsibility and liability for the equipment and the work performed upon it. The government shall be held harmless for any damage done to the equipment at any time up until final acceptance of the equipment by Rock Island Arsenal, except in the case of intentional damage and/or gross negligence on the part of Rock Island Arsenal personnel.

6.2.9 SET-UP: The contractor shall be responsible for set-up and connection of the equipment beyond connections of the utilities to the points of first connection.

6.2.10 SECURITY: The RIA-JMTC is an Army installation subject to Department of Defense safe guards, various precautions, and plant protection measures. At all times during the execution of this SOW, the contractor will maintain adequate plant protection devises to minimize espionage, sabotage, and other malicious destruction and damage. The contractor shall comply with all security requirements of the Rock Island Arsenal. Rock Island Arsenal Island-wide Force Protection levels may be adjusted/changed at any time, which may cause possible delays and will directly affect procedures for accessing the Island.

Delivery Hours or Service Hours: Service calls, equipment installation, training, and equipment delivery (where the contractor offloads) will only be allowed from 0600 – 1530, Monday through Thursday, except for Government Holidays. Deliveries of items where the contractor has opted for Government "off-loading option", must be received before 1200 hours. These hours are subject to change, however, the Government will notify the contractor of such changes. The vendor will contact the designated Performance Certifier/ COR to obtain an electronic key for their representative (i.e. delivery driver) in order to have access to the facility. Deliveries and service calls outside the normal hours stated above will be coordinated with the Performance Certifier/ COR to address any emergency situations."

6.3 Completion

6.3.1 Final acceptance of the equipment shall occur after the following:

6.3.1.1 Set-up completion by the contractor.

6.3.1.2 Successful completion of performance testing at Rock Island Arsenal.

6.3.1.3 Final inspection approval by the government representative or inspector. This is to verify full compliance with this description to include amendments and modifications to the final contract. The government representative shall perform any and all tests he deems necessary to ensure compliance with this description and industry standards to include, but not limited to ease of control, convenience of operation, safe operation, and adequacy of lubrication devices.

6.3.1.4 All required training is complete.

6.3.1.5 Complete documentation packages are delivered.

7. TRAINING

The contractor shall provide instruction in proper operation and maintenance of the equipment without additional cost to the government. Training shall be of sufficient duration that the recipients are able to demonstrate a reasonable level of competence as determined by the equipment installer and/or the inspector. Acceptance may be delayed as a result of inadequate training.

7.1 Schedule

Training shall training shall be coordinated with the Rock Island Arsenal. Daily training shall begin no later than 6:30 a.m. CST and shall continue until at least 2:15 p.m. CST. This is required to get full coverage of the 1st shift of operation at RIA-JMTC. If training does not begin until after the stated time, RIA-JMTC may at its option require additional training at a different time to compensate for the loss of training caused by the late start. This may include more time than what is represented by the delay (e.g. a 1-hr delay may require 2-hrs later to impart the knowledge lost).

7.2 Location

All training shall be performed at the Rock Island Arsenal. It shall be performed using the equipment purchased in this description.

7.3 Type

Each type of training shall be given independently. Rock Island Arsenal shall coordinate with the contractor to provide the proper personnel for each type of training. The following types of training shall be provided by the contractor.

7.3.1 MAINTENANCE: Mechanical and electrical control and diagnostic maintenance training shall be provided by the contractor. This shall include information on troubleshooting and preventive maintenance procedures. This shall be provided for (2) personnel.