

TABLE 1 FOR SECTION 07 60 00  
FLASHING AND SHEETMETAL  
PART 3 EXECUTION  
PARAGRAPH 3.5.1 PROCEDURE

| TABLE I. SHEET METAL WEIGHTS, THICKNESSES, AND GAGES |                                     |                           |                       |                                    |                         |
|------------------------------------------------------|-------------------------------------|---------------------------|-----------------------|------------------------------------|-------------------------|
| Sheet Metal Items                                    | [Copper kilograms per square meter] | [Aluminum, mm]            | [Stainless Steel, mm] | [Terne-Coated Stainless Steel, mm] | [Zinc-Coated Steel, mm] |
| [Building Expansion Joints]                          |                                     |                           |                       |                                    |                         |
| [Cover]                                              | 4.9                                 | 0.81                      | 0.38                  | 0.38                               | 0.6                     |
| [Waterstop-bellows or flanged, U-type.]              | 4.9                                 | -                         | 0.38                  | 0.38                               | -                       |
| [Covering on minor flat, pitched or curved surfaces] | 6.125                               | 1.02                      | 0.46                  | 0.46                               | -                       |
| [Downspouts and leaders]                             | 4.9                                 | 0.81                      | 0.38                  | 0.38                               | 0.6                     |
| [Downspout clips and anchors]                        | -                                   | 1.02 clip<br>3.175 anchor | -                     | -                                  | -                       |
| [Downspout straps, 50 mm]                            | 14.7 (a)                            | 1.52                      | 1.27                  | -                                  | -                       |
| [Conductor heads]                                    | 4.9                                 | 0.81                      | 0.38                  | 0.38                               | -                       |
| [Scupper lining]                                     | 6.125                               | 0.81                      | 0.38                  | 0.38                               | -                       |
| [Strainers, wire diameter or gage]                   | 4.0 gage                            | 3.66 diameter             | 2.77 diameter         | -                                  | -                       |
| [Flashings:]                                         |                                     |                           |                       |                                    |                         |
| [Base]                                               | 6.125                               | 1.02                      | 0.46                  | 0.46                               | 0.6                     |
| [Cap (Counter-flashing)]                             | 4.9                                 | 0.81                      | 0.38                  | 0.38                               | 0.5                     |
| [Eave]                                               | 4.9                                 | -                         | 0.38                  | 0.38                               | 0.6                     |

TABLE I. SHEET METAL WEIGHTS, THICKNESSES, AND GAGES

| Sheet Metal Items                                         | [Copper kilograms per square meter] | [Aluminum, mm]    | [Stainless Steel, mm] | [Terne-Coated Stainless Steel, mm] | [Zinc-Coated Steel, mm] |
|-----------------------------------------------------------|-------------------------------------|-------------------|-----------------------|------------------------------------|-------------------------|
| [Spandrel beam]                                           | 3.1                                 | -                 | 0.25                  | 0.25                               | -                       |
| [Bond barrier]                                            | 4.9                                 | -                 | 0.38                  | 0.38                               | -                       |
| [Stepped]                                                 | 4.9                                 | 0.81              | 0.38                  | 0.38                               | -                       |
| [Valley]                                                  | 4.9                                 | 0.81              | 0.38                  | 0.38                               | -                       |
| [Roof drain]                                              | 4.9 (b)                             |                   |                       |                                    |                         |
| [Pipe vent sleeve (d)]                                    |                                     |                   |                       |                                    |                         |
| [Coping]                                                  | 4.9                                 | -                 | -                     | -                                  | -                       |
| [Gravel stops and fascias:]                               |                                     |                   |                       |                                    |                         |
| [Extrusions]                                              | -                                   | 1.91              | -                     | -                                  | -                       |
| [Sheets, corrugated]                                      | 4.9                                 | 0.81              | 0.38                  | 0.38                               | -                       |
| [Sheets, smooth]                                          | 6.125                               | 1.27              | 0.46                  | 0.46                               | 0.6                     |
| [Edge strip]                                              | 7.35                                | 1.27              | 0.635                 | -                                  | -                       |
| [Gutters:]                                                |                                     |                   |                       |                                    |                         |
| [Gutter section]                                          | 4.9                                 | 0.81              | 0.38                  | 0.38                               | 0.6                     |
| [Continuous cleat]                                        | 4.9                                 | 0.81              | 0.38                  | 0.38                               | 0.6                     |
| [Hangers, dimensions]                                     | 25 mm by 3 mm (a)                   | 25 mm by 2 mm (c) | 25 mm by 1 mm         | -                                  | -                       |
| [Joint Cover plates (See Table II)]                       | 4.9                                 | 0.81              | 0.38                  | 0.38                               | 0.6                     |
| [Reglets (c)]                                             | 3.1                                 | -                 | 0.25                  | 0.25                               | -                       |
| [Splash pans]                                             | 4.9                                 | 1.02              | 0.46                  | 0.46                               | -                       |
| (a) Brass.                                                |                                     |                   |                       |                                    |                         |
| (b) May be lead weighing 19.6 kilograms per square meter. |                                     |                   |                       |                                    |                         |

| TABLE I. SHEET METAL WEIGHTS, THICKNESSES, AND GAGES                                                                                                                |                                     |                |                       |                                    |                         |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------|----------------|-----------------------|------------------------------------|-------------------------|
| Sheet Metal Items                                                                                                                                                   | [Copper kilograms per square meter] | [Aluminum, mm] | [Stainless Steel, mm] | [Terne-Coated Stainless Steel, mm] | [Zinc-Coated Steel, mm] |
| (c) May be polyvinyl chloride.                                                                                                                                      |                                     |                |                       |                                    |                         |
| (d) 12.25 kilogram minimum lead sleeve with 100 mm flange. Where lead sleeve is impractical, refer to paragraph entitled "Single Pipe Vents" for optional material. |                                     |                |                       |                                    |                         |

| TABLE I. SHEET METAL WEIGHTS, THICKNESSES, AND GAGES |                                    |                          |                         |                                      |                                     |
|------------------------------------------------------|------------------------------------|--------------------------|-------------------------|--------------------------------------|-------------------------------------|
| Sheet Metal Items                                    | [Copper kilograms per square foot] | [Aluminum, inch]         | [Stainless Steel, inch] | [Terne-Coated Stainless Steel, inch] | [Zinc-Coated Steel, U.S. Std. Gage] |
| [Building Expansion Joints]                          |                                    |                          |                         |                                      |                                     |
| [Cover]                                              | 16                                 | .032                     | .015                    | .015                                 | 24                                  |
| [Waterstop-bellows or flanged, U-type.]              | 16                                 | -                        | .015                    | .015                                 | -                                   |
| [Covering on minor flat, pitched or curved surfaces] | 20                                 | .040                     | .018                    | .018                                 | -                                   |
| [Downspouts and leaders]                             | 16                                 | .032                     | .015                    | .015                                 | 24                                  |
| [Downspout clips and anchors]                        | -                                  | .040 clip<br>.125 anchor | -                       | -                                    | -                                   |
| [Downspout straps, 2-inch]                           | 48 (a)                             | .060                     | .050                    | -                                    | -                                   |
| [Conductor heads]                                    | 16                                 | .032                     | .015                    | .015                                 | -                                   |
| [Scupper lining]                                     | 20                                 | .032                     | .015                    | .015                                 | -                                   |

TABLE I. SHEET METAL WEIGHTS, THICKNESSES, AND GAGES

| Sheet Metal Items                  | [Copper kilograms per square foot] | [Aluminum, inch] | [Stainless Steel, inch] | [Terne-Coated Stainless Steel, inch] | [Zinc-Coated Steel, U.S. Std. Gage] |
|------------------------------------|------------------------------------|------------------|-------------------------|--------------------------------------|-------------------------------------|
| [Strainers, wire diameter or gage] | No. 9 gage                         | .144 diameter    | .109 diameter           | -                                    |                                     |
| [Flashings:]                       |                                    |                  |                         |                                      |                                     |
| [Base]                             | 20                                 | .040             | .018                    | .018                                 | 24                                  |
| [Cap (Counter-flashing)]           | 16                                 | .032             | .015                    | .015                                 | 26                                  |
| [Eave]                             | 16                                 | -                | .015                    | .015                                 | 24                                  |
| [Spandrel beam]                    | 10                                 | -                | .010                    | .010                                 | -                                   |
| [Bond barrier]                     | 16                                 | -                | .015                    | .015                                 | -                                   |
| [Stepped]                          | 16                                 | .032             | .015                    | .015                                 | -                                   |
| [Valley]                           | 16                                 | .032             | .015                    | .015                                 | -                                   |
| [Roof drain]                       | 16 (b)                             |                  |                         |                                      |                                     |
| [Pipe vent sleeve (d)]             |                                    |                  |                         |                                      |                                     |
| [Coping]                           | 16                                 | -                | -                       | -                                    | -                                   |
| [Gravel stops and fascias:]        |                                    |                  |                         |                                      |                                     |
| [Extrusions]                       | -                                  | .075             | -                       | -                                    | -                                   |
| [Sheets, corrugated]               | 16                                 | .032             | .015                    | .015                                 | -                                   |
| [Sheets, smooth]                   | 20                                 | .050             | .018                    | .018                                 | 24                                  |
| [Edge strip]                       | 24                                 | .050             | .025                    | -                                    | -                                   |
| [Gutters:]                         |                                    |                  |                         |                                      |                                     |
| [Gutter section]                   | 16                                 | .032             | .015                    | .015                                 | 24                                  |
| [Continuous cleat]                 | 16                                 | .032             | .015                    | .015                                 | 24                                  |

| TABLE I. SHEET METAL WEIGHTS, THICKNESSES, AND GAGES                                                                                                           |                                    |                         |                         |                                      |                                     |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------|-------------------------|-------------------------|--------------------------------------|-------------------------------------|
| Sheet Metal Items                                                                                                                                              | [Copper kilograms per square foot] | [Aluminum, inch]        | [Stainless Steel, inch] | [Terne-Coated Stainless Steel, inch] | [Zinc-Coated Steel, U.S. Std. Gage] |
| [Hangers, dimensions]                                                                                                                                          | 1 inch by 1/8 inch (a)             | 1 inch by .080 inch (c) | 1 inch by .037 inch     | -                                    | -                                   |
| [Joint Cover plates (See Table II)]                                                                                                                            | 16                                 | .032                    | .015                    | .015                                 | 24                                  |
| [Reglets (c)]                                                                                                                                                  | 10                                 | -                       | .010                    | .010                                 | -                                   |
| [Splash pans]                                                                                                                                                  | 16                                 | .040                    | .018                    | .018                                 | -                                   |
| (a) Brass.                                                                                                                                                     |                                    |                         |                         |                                      |                                     |
| (b) May be lead weighing 4 pounds per square foot.                                                                                                             |                                    |                         |                         |                                      |                                     |
| (c) May be polyvinyl chloride.                                                                                                                                 |                                    |                         |                         |                                      |                                     |
| (d) 2.5 pound minimum lead sleeve with 4 inch flange. Where lead sleeve is impractical, refer to paragraph entitled "Single Pipe Vents" for optional material. |                                    |                         |                         |                                      |                                     |

| TABLE II. SHEET METAL JOINTS                                 |                                                                             |                             |         |
|--------------------------------------------------------------|-----------------------------------------------------------------------------|-----------------------------|---------|
| TYPE OF JOINT                                                |                                                                             |                             |         |
| Item Designation                                             | Copper, Terne-Coated Stainless Steel, Zinc-Coated Steel and Stainless Steel | Aluminum                    | Remarks |
| Joint cap for building expansion seam, cleated joint at roof | 30 mm single lock, standing seam, cleated                                   | 30 mm single lock, standing | --      |
| Flashings                                                    |                                                                             |                             |         |

TABLE II. SHEET METAL JOINTS

| TYPE OF JOINT    |                                                                                           |                                                                                                  |                                                                                                                                                                         |
|------------------|-------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Item Designation | Copper, Terne-Coated<br>Stainless Steel,<br>Zinc-Coated Steel and<br>Stainless Steel      | Aluminum                                                                                         | Remarks                                                                                                                                                                 |
| Base             | 25 mm<br>75 mm lap for expansion<br>joint                                                 | 25 mm flat locked,<br>soldered; sealed; 75 mm<br>lap for expansion joint                         | Aluminum producer's<br>recommended hard setting<br>sealant for locked<br>aluminum joints. Fill each<br>metal expansion joint with<br>a joint sealing compound compound. |
| Cap-in reglet    | 75 mm lap                                                                                 | 75 mm lap                                                                                        | Seal groove with joint<br>sealing compound.                                                                                                                             |
| Reglets          | Butt joint                                                                                | --                                                                                               | Seal reglet groove with<br>joint sealing compound.                                                                                                                      |
| Eave             | 25 mm flat locked,<br>cleated. 25 mm loose<br>locked, sealed expansion<br>joint, cleated. | 25 mm flat locked,<br>locked, cleated 25 mm<br>loose locked, sealed<br>expansion joints, cleated | Same as base flashing.                                                                                                                                                  |
| Stepped          | 75 mm lap                                                                                 | 75 mm lap                                                                                        | --                                                                                                                                                                      |
| Valley           | 150 mm lap cleated                                                                        | 150 mm lap cleated                                                                               | --                                                                                                                                                                      |
| Edge strip       | Butt                                                                                      | Butt                                                                                             | --                                                                                                                                                                      |
| Gravel stops:    |                                                                                           |                                                                                                  |                                                                                                                                                                         |
| Extrusions       | --                                                                                        | Butt with 13 mm space                                                                            | Use sheet flashing beneath<br>and a cover plate                                                                                                                         |
| Sheet, smooth    | Butt with 6 mm space                                                                      | Butt with 6 mm space                                                                             | Use sheet flashing backup<br>plate.                                                                                                                                     |

| TABLE II. SHEET METAL JOINTS                                                          |                                                                                      |                                         |                                                                                          |
|---------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------|-----------------------------------------|------------------------------------------------------------------------------------------|
| TYPE OF JOINT                                                                         |                                                                                      |                                         |                                                                                          |
| Item Designation                                                                      | Copper, Terne-Coated<br>Stainless Steel,<br>Zinc-Coated Steel and<br>Stainless Steel | Aluminum                                | Remarks                                                                                  |
| Sheet, corrugated                                                                     | Butt with 6 mm space                                                                 | Butt with 6 mm space                    | Use sheet flashing beneath<br>and a cover plate or a<br>combination unit                 |
| Gutters                                                                               | 40 mm lap, riveted and<br>soldered                                                   | 25 mm flat locked<br>riveted and sealed | Aluminum producers<br>recommended hard setting<br>sealant for locked<br>aluminum joints. |
| (a) Provide a 75 mm lap elastomeric flashing with manufacturer's recommended sealant. |                                                                                      |                                         |                                                                                          |
| (b) Seal Polyvinyl chloride reglet with manufacturer's recommended sealant.           |                                                                                      |                                         |                                                                                          |

| TABLE II. SHEET METAL JOINTS                                       |                                                                                      |                                    |         |
|--------------------------------------------------------------------|--------------------------------------------------------------------------------------|------------------------------------|---------|
| TYPE OF JOINT                                                      |                                                                                      |                                    |         |
| Item Designation                                                   | Copper, Terne-Coated<br>Stainless Steel,<br>Zinc-Coated Steel and<br>Stainless Steel | Aluminum                           | Remarks |
| Joint cap for building<br>expansion seam,<br>cleated joint at roof | 1.25 inch single lock,<br>standing seam, cleated                                     | 1.25 inch single lock,<br>standing | --      |
| Flashings                                                          |                                                                                      |                                    |         |

TABLE II. SHEET METAL JOINTS

| TYPE OF JOINT    |                                                                                                 |                                                                                                        |                                                                                                                                                                            |
|------------------|-------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Item Designation | Copper, Terne-Coated<br>Stainless Steel,<br>Zinc-Coated Steel and<br>Stainless Steel            | Aluminum                                                                                               | Remarks                                                                                                                                                                    |
| Base             | One inch<br>3 inch lap for expansion<br>joint                                                   | One inch flat locked,<br>soldered; sealed; 3 inch<br>lap for expansion joint                           | Aluminum producer's<br>recommended hard setting<br>sealant for locked aluminum<br>joints. Fill each metal<br>expansion joint with a<br>joint sealing compound<br>compound. |
| Cap-in reglet    | 3 inch lap                                                                                      | 3 inch lap                                                                                             | Seal groove with joint<br>sealing compound.                                                                                                                                |
| Reglets          | Butt joint                                                                                      | --                                                                                                     | Seal reglet groove with<br>joint sealing compound.                                                                                                                         |
| Eave             | One inch flat locked,<br>cleated. One inch loose<br>locked, sealed expansion<br>joint, cleated. | One inch flat locked,<br>locked, cleated one inch<br>loose locked, sealed<br>expansion joints, cleated | Same as base flashing.                                                                                                                                                     |
| Stepped          | 3 inch lap                                                                                      | 3 inch lap                                                                                             | --                                                                                                                                                                         |
| Valley           | 6 inch lap cleated                                                                              | 6 inch lap cleated                                                                                     | --                                                                                                                                                                         |
| Edge strip       | Butt                                                                                            | Butt                                                                                                   | --                                                                                                                                                                         |
| Gravel stops:    |                                                                                                 |                                                                                                        |                                                                                                                                                                            |
| Extrusions       | --                                                                                              | Butt with 1/2 inch space                                                                               | Use sheet flashing beneath<br>and a cover plate                                                                                                                            |
| Sheet, smooth    | Butt with 1/4 inch space                                                                        | Butt with 1/4 inch space                                                                               | Use sheet flashing backup<br>plate.                                                                                                                                        |

TABLE II. SHEET METAL JOINTS

| TYPE OF JOINT                                                                          |                                                                                      |                                            |                                                                                          |
|----------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------|--------------------------------------------|------------------------------------------------------------------------------------------|
| Item Designation                                                                       | Copper, Terne-Coated<br>Stainless Steel,<br>Zinc-Coated Steel and<br>Stainless Steel | Aluminum                                   | Remarks                                                                                  |
| Sheet, corrugated                                                                      | Butt with 1/4 inch space                                                             | Butt with 1/4 inch space                   | Use sheet flashing beneath<br>and a cover plate or a<br>combination unit                 |
| Gutters                                                                                | 1.5 inch lap, riveted and<br>soldered                                                | One inch flat locked<br>riveted and sealed | Aluminum producers<br>recommended hard setting<br>sealant for locked aluminum<br>joints. |
| (a) Provide a 3 inch lap elastomeric flashing with manufacturer's recommended sealant. |                                                                                      |                                            |                                                                                          |
| (b) Seal Polyvinyl chloride reglet with manufacturer's recommended sealant.            |                                                                                      |                                            |                                                                                          |

] -- End of Section --