

1. PRE-PROPOSAL INQUIRY RESPONSES:

Question #	Reference			Question	Government Response
	Page	Section	Paragraph		
1	Attachment B	Base Option	A0134	Can you provide clarification- Perform Roof Survey / Assessment up to 50,000 SF in accordance with Attachment B- this is the same attachment where it is being price and there is not additional information	See revised ELINs provided via Amendment 0005
2	Attachment B	Base Option	A0135	Can you provide clarification- Perform Roof Survey / Assessment over 50,000 SF and up to 100,000 SF in accordance with Attachment B. this is the same attachment where it is being price and there is not additional information	See revised ELINs provided via Amendment 0005
3	Attachment B	Base Option	A0136	Can you provide clarification-Perform Roof Survey / Assessment over 100,000 SF in accordance with Attachment B.- this is the same attachment where it is being price and there is not additional information	See revised ELINs provided via Amendment 0005
4	Attachment B	Base Option	A0134	Perform Roof Survey / Assessment up to 50,000 SF in accordance with Attachment B- the amount is 1,000 SF but the line item calls out 50,000 SF does this mean 1000 Units or the total divided by 50?	See revised ELINs provided via Amendment 0005
5	Attachment B	Base Option	A0135	Perform Roof Survey / Assessment over 50,000 SF and up to 100,000 SF in accordance with Attachment B.- the amount is 1,000 SF but the line item calls out 50,000 SF does this mean 1000 Units or the total divided by 50?	See revised ELINs provided via Amendment 0005
6	Attachment B	Base Option	A0136	Perform Roof Survey / Assessment over 100,000 SF in accordance with Attachment B.- the amount is 1,000 SF but the line item calls out 50,000 SF does this mean 1000 Units or the total divided by 50?	See revised ELINs provided via Amendment 0005
7	Attachment B	Base Option	A0131	Provide all materials and equipment to perform Unit Priced Labor work per the scope and delivery schedule specified in the order. Material costs shall BE NEGOTIATED BY KO - What does this line item mean as far as pricing?	This is for all materials not covered in specific ELIN
8	Attachment B	Base Option	A0131	Provide all materials and equipment to perform Unit Priced Labor work per the scope and delivery schedule specified in the order. Material costs shall BE NEGOTIATED BY KO - Is this a coefficient for materials?	See Response to PPI#7.

9	Attachment B	Base Option	A0132	Provide labor to perform all Unit Priced Labor work per the scope and delivery schedule specified in the order. MUST BE NEGOTIATED BY KO - Does this mean for hours outside of these line items?	Confirmed.
10	Attachment B	Base Option	A006-A007	What is the difference between these line items? They both state removing and replacing tarped insulation.	A0006 provides for the removal and replacement of polyisocyanurate tapered insulation panels, A0007 provides for the removal and replacement of tapered roof insulation
11	Attachment B	Base Option	A006-A007	What is the attachment method we should assume- mechanical or low-rise insulation adhesive	Contractors' means and methods should adhere to the EM385 state and local bldg. codes.
12	Attachment B	Base Option	A006-A007	This line item is in SQs. If there are multiple layers of insulation, are they included or would they each be able to be added? For example, 100 SQs of two layers of 2.6 inch insulation would that be 200 SQs or 100 SQs. If it is only 100 SQs what should we assume is the thickness of insulation that would be added to the roof systems. Or could this become a BF price?	See revised ELINs provided via Amendment 0005
13	Attachment B	Base Option	A006-A007	Are cover boards- HD iso/ Densdeck included in this cost- or if they are apart of the system an additional SQ amount can be added to the total?	PENDING RESPONSE
14	Attachment B	Base Option	A0039-A0049	Do the line items here cover insulation removal and replacement or is that covered by the A006-A007 and this is only for the EPDM or TPA and the accessories for the membrane systems	Roof System would mean all together
15	Attachment B	Base Option	A0039-A0049	What is the warranty to be assumed for these systems?	1 year
16	Attachment B	Base Option	A0039-A0049	What is the mil to be assumed for these systems?	1 year
17	Attachment B	Base Option	A0132	Provide labor to perform all Unit Priced Labor work per the scope and delivery schedule specified in the order. MUST BE NEGOTIATED BY KO.- What does this line item mean? Do none of the other line items include labor?	This Line item is for any labor not captured in the other ELINs.
18	Attachment B	Base Option	A0023	Coat roofing with aluminum pigmented slate shingles (All or Partial) slate shingles (All or Partial)	PENDING RESPONSE

				fiberglass bitumen roof coating- What does it mean by coating roofing with aluminum slate shingles? Is this a typo and the line item is for coating aluminum slate and slate shingles with fiberglass coating?	
19	Attachment B	Base Option	A0105-A0109	Strainers - the same two types are strainers are called out twice- why aren't the line items combined?	A0105 is for Remove existing metal scupper lining and replace with new metal scupper lining and A0109 Install new metal splash pans
20	Attachment B	Base Option	A0046-0049	Remove existing roof system and replace with new Thermoplastic alloy roof system (TPA) - There are no specs in the IDIQ specifications book for TPA- there is for PVC, can this line item be changed to PVC and if not can a TPA section be added - and basis of design manufacturer?	PENDING RESPONSE
21	Attachment B	Base Option	A0036-A0038	E.P.D.M. (RUBBER ROOF SYSTEM) (Install new E.P.D.M. Roof System over Existing Built-up Roof)- Is this for an overlay system? If so does this price include a cover board?	PENDING RESPONSE
22	Attachment B	Base Option	A0036-A0038	E.P.D.M. (RUBBER ROOF SYSTEM) (Install new E.P.D.M. Roof System over Existing Built-up Roof)- What is the mil to be assumed?	PENDING RESPONSE
23	Attachment B	Base Option	A0036-A0038	E.P.D.M. (RUBBER ROOF SYSTEM) (Install new E.P.D.M. Roof System over Existing Built-up Roof)- What is the warranty to be assumed?	PENDING RESPONSE
24	Attachment B	Base Option	A0028-0029	Remove existing roof system and replace with new single ply reinforced modified bitumen sheet roofing system- Can you provide a basis of design for this system?	PENDING RESPONSE
25	Attachment B	Base Option	A0028-0029	Remove existing roof system and replace with new single ply reinforced modified bitumen sheet roofing system- What is the warranty assumed for this system?	1 year
26	Attachment B	Base Option	A0028-0029	Remove existing roof system and replace with new single ply reinforced modified bitumen sheet roofing system- Please let me know if our interpretation is correct- These line items do not include wall flashing, coping, pipes, walk pads, insulation removal and install, etc. and is the cost to remove the membrane system and to install the new membrane system- this would be used in conjunction with other line items to get full price?	PENDING RESPONSE

27	Att. B - Roofing IDIQ ELINs	ELIN A0027	System Gas	Please provide additional detail on the scope of work required	PENDING RESPONSE
28	Att. B - Roofing IDIQ ELINs	ELIN A0104	Power washing	The "unit" calls for LF. Should this be measured and priced in SF vs. LF?	PENDING RESPONSE
29	Att. B - Roofing IDIQ ELINs	ELIN A0131	Unit Priced Labor	Please provide additional clarification for this CLIN. Is this to only represent the hourly rate for Overhead when labor is paid at a fixed rate (Unit Priced Labor) and direct materials are negotiated per specific work order?	PENDING RESPONSE
30	Att. B - Roofing IDIQ ELINs	ELIN A0132	Labor Category	Please provide additional clarification as to which labor category from the prevailing wage category this CLIN should be quoted. Projects typically have multiple applicable prevailing wages (roofer, equipment operator, general laborer...). Each project has a blended rate depending on the specific work required. In order to fairly assess, a specific prevailing wage category should be used for comparison purpose.	PENDING RESPONSE
31	Att. B - Roofing IDIQ ELINs	ELIN 0133	Perform Service Call	Please clarify. Service calls have a material and labor cap of \$2,500. Is this CLIN to include the \$2,500 cap or only capture the cost to dispatch a crew for a service call.	PENDING RESPONSE
32	"Page No.: 03 of 04"	Attachment "B" ELIN List	A0109	ELIN No.: A0109 Remove existing metal scupper lining and replace with new metal scupper lining (Copper) mentions a quantity of 300 EA. In past experience the scupper repairs are usually 1 to 4 at a time for a task order not the 300 EA at one time. Can the quantities be adjusted to reflect more accurate past performance requirements. Example if you did 300 at one time there would be a cost savings VS doing 4 at one time. There is most likely not 300 scuppers being replaced at one time. Can we adjust the quantity to a more realistic number like 30?	See revised ELINs provided via Amendment 0005
33	Page No.: 07 of 39	RFP	1.2	General Overview of Contract mentions the work site to be NSA-Philadelphia PA. / PNY-Philadelphia PA. / NSA-Mechanicsburg PA. The prevailing wage rates for Philadelphia (PNY & NSA) are about 25% HIGHER than NSA Mechanicsburg, PA. With that being said there is only ONE (1) ELIN sheet for all three	See revised ELINs provided via Amendment 0005

				bases. Will NAVY consider giving a separate ELIN sheet for NSA Mechanicsburg, PA. since the rates are much lower at that base. The rates for both Philadelphia Bases can go on the current ELIN summary since the rates are the same in Philadelphia, PA. This impacts ALL ELINS and also specifically ELIN No.: A0132. Provide Labor to perform all Unit Priced Labor work per the scope and delivery schedule specified in the order. MUST BE NEGOTIATED WITH KO.	
34	Page No.: 04 of 04	Attachment "B" ELIN List	A0131	ELIN No.: A0131 Provide all materials and equipment to perform Unit Priced Labor work per the scope and delivery schedule specified in the order. Material costs shall BE NEGOTIATED BY KO. Since there could be a few equipment needs for different roofs would the government considering adding some equipment as listed below that have been used on previous NAVY roofs from past experience. This will help create a fair balanced bid with the primes. Example: A0131.01: Hydraulic Crane 60 TON (120 FT) A0131.02: Hydraulic Crane 80 TON (180 FT) A0131.03: Hydraulic Crane 120 TON (250 FT) A0131.04: Boom Lift Articulating 60' A0131.05: Boom Lift Articulating 80' A0131.06: Boom Lift Articulating 120' A0131.07: Forklift Telescopic 5K (35') A0131.08: Forklift Telescopic 8K (50') A0131.09: Forklift Telescopic 10K (65')	No equipment list. No maintenance.
35	Page No.: 01 of 39	RFP	13	Will Bid Date be Extended?	Bid due date has been extended to 10 March 2026 NLT 2:00 PM EDT via Amendment 0004.
36	Page No.: 06 of 39	RFP	52.226-27 Site Visit	Since access to roof could not be given at the 1st site visit due to snow and weather will there be a 2nd site visit scheduled.	There will not be another site visit held.

37	Attachment "C" NSW PNYA Roofs and Attachment "B" ELINS	RFP	"C" & "B"	Attachment "C" List Thirty Three (33) Roof that get cleaning and inspections. These Roofs on Attachment "C" are NOT Listed on Attachment "B" ELINS. Will these roofs be added to the ELIN list for PNYA.	This is not part of the scope. Attachment C revised with Amendment 0005.
38	Attachment "B" ELINS	RFP	All Pages	Should Labor be included in each unit cost? The amount of labor required for each unit cost will be significantly different.	Include labor to perform the work described in the ELINS. Additional labor will be captured in the ELIN 0132.
39	Attachment "B" ELINS	RFP	AO132	AO132 states to provide labor cost to perform all unit cost work. Will this per hour cost be assigned to all work that is performed. Then applied to the amount of hours it takes to do the work.	PENDING RESPONSE
40	Attachment "B" ELINS	RFP	A0006	What should we use for the average thickness of tapered insulation or should this be changed to brdft. Price. Tapered insulation is priced based off the thickness of the insulation. A brdft foot is define as 1"x12"x12".	PENDING RESPONSE
41	Attachment "B" ELINS	RFP	A0006 and A0007	Looks like A006 and A007 are the exact same price but worded differently is this correct.	A006 and A007 are for different material
42	Attachment "B" ELINS	RFP	Various ELINS	Should there be a line item for disposal under non-pre-priced labor, material or should that be carried in the unit cost.	PENDING RESPONSE
43	Attachment "B" ELINS	RFP	Various ELINS	Will there be line items added for Safety, mobilization, and travel time.	PENDING RESPONSE
44	Attachment "D" PNYA CNIC Roof	RFP	Various ELINS	This shows one Roof Area B44 states Granite Shingles. Should this be Slate? Also please confirm SF of roof area.	See revised Attachment D with Amendment 0005.
45	Attachment "D" PNYA CNIC Roof	RFP	Various ELINS	This shows one Roof Area B44 states Granite Shingles. Should this be Slate? Also please confirm SF of roof area.	See response to PPI#47.
46	013000 Page No.: 03 / 014500 Page No.: 09 / 013526 Page No.: 10.	Specificati on Section No.: 013000 Administrative Requirements, 014500 Quality	013000 Paragraph No.: 1.4.1 / 014500 Paragraph No.: 1.6.2.2 / 013526	Confirm that the field manager can be (1) one manager Tripple Hat as long as the one individual meets all the qualification requirements. Field Superintendent 10 years experience, CQC Manager 10 Years experience QC Certificate and SSHO Level Two per US Army Corps of Engineers EM-385 Safety and Health Manual based	No, the SSHO has to be separate. Reference the EM385

		Control and 013526 Governmental Safety Requirements	Paragraph No.: 1.8.	on 2024 version with required safety and health certificates.	
47	013526 Page No.: 13.	Specification Section No.: 013526 Governmental Safety Requirements	013526 Paragraph No.: 1.09	The Governmental Safety & Health Requirements specification requires the Accident Prevention Plan (APP) be prepared per the EM-385 1-1 (2024). The EM-385 1-1 requires a Competent Person in Fall Protection Training which requires 24 HRS of EM-385 1-1 and ANSI training both hands on and classroom. Please confirm this training is required for this RFP.	Confirmed.
48	Attachment "B" ELINS	RFP	Various ELINS	Please confirm if all the following cost should be included in each ELIN. Labor, Material, CQC, SSHO, Field Superintendent, Trailers, Fall Protection, Equipment, Other General Conditions, Field Overhead, Office Overhead, Project Management and Profit. If any of these should be included in separate ELIN's please confirm which ones.	Confirmed.
49				Please confirm if a single, duly qualified individual may "triple hat" and serve as the project superintendent, QC Manager, and SSHO.	No, the SSHO has to be separate. Reference the EM385
50				Is US Citizen mandatory at Job site?	Yes
51				Please share the photos of site visit.	There were no photos taken of the site visit.
52				Please provide the incumbent roofing contractors, company name, POC information (Name, email, Phone).	PENDING RESPONSE
53				Please provide the incumbent roofing contractors, company name, POC information (Name, email, Phone).	PENDING RESPONSE
54	8	Section 00 21 13 - Instructions to Bidders	3.2 Bid Submission Instructions	Is this project a Small Business or VOSB/SDVOSB set aside? The SF 1442 states it is a Total Small Business Set-Aside, however the Bid Submission Instructions require "Confirmation of filing of Veterans' Employment and Training (VETS) VETS-4212 for the 2024/2025 filing cycle."	This is a Total Small Business Set-Aside. VETS 4212 for 2024/2025 is a requirement.

55	8	Section 00 21 13 - Instructions to Bidders	Responsi bility Determin ation Informati on	The required information for the responsibility determination will not be evaluated as part of the sealed bid evaluation and instead used to form the basis of responsibility. Will this evaluation be conducted on a pass/fail basis for the information provided? How is this requirement a price only, not a LPTA evaluation if past performances and technical capabilities of the low bidder will be evaluated for acceptability?	"The Responsibility Determination is performed after the bid opening and required in accordance with FAR 9.104-1 as stated in the IFB. The IFB states: Although required to be submitted with the bid package, this information will not be evaluated as part of the sealed bid evaluation. This information forms the basis of your firm's responsibility determination should your firm be the apparent low bidder. This IDIQ is being awarded under FAR Part 14."
56	8	Section 00 21 13 - Instructions to Bidders	Responsi bility Determin ation Informati on	It is requested that prior contracts for similar work of similar magnitude and POC information for the issuing organizations be provided for reference, how many past performances are required/preferred? Is there a time period of how recent the contracts should be? Using what criteria will these contracts be evaluated to determine firm's responsibility?	PENDING RESPONSE
57	8	Section 00 21 13 - Instructions to Bidders	Responsi bility Determin ation Informati on	Please clarify how you would like us to provide a schedule for performing required services. Should the schedule assume the utilization of every ELIN service? How will this schedule be evaluated to determine responsibility?	PENDING RESPONSE
58	8	3.2		Please clarify providing a technical schedule with the proposal?	A work schedule will be requested with proposal of each task order. To provide estimated days on site. In addition, when work starts an actual schedule is requested at the pre-con meeting.
59	31	252.204- 7021		Please advise if this contract will require CMMC Level 2 Requirements.	This will be evaluated on a per task order basis.
60	5	1000		Please confirm the CLIN price includes all other requirements other than the ELIN price. (i.e., overhead, bonding, QC, PM, etc.)	PENDING RESPONSE
61		3.2		Does the government expect offeror's to submit pricing based on the average task orders in the previous 5 years?	Submit pricing per current rates.

62	10	01-35-26	1.8.2	Please confirm on dual roles between the supervisor, QC, and SSHO. Is this negotiable (i.e. based on the magnitude of the project)?	No, the SSHO has to be separate. Reference the EM385
63	10	01-35-26	1.8.2	What are the expectations for the SSHO in regard to being onsite each day/week during Task order work (i.e. does this include QC inspections)?	Reference the EM385.
64	10	01-35-26	1.8.2	If EM 385 Training is required-is the 40, 24 or 16 hour training needed for qualification?	PENDING RESPONSE
65	5	01-35-26		Is Type 2 PPE hard hats required?	PENDING RESPONSE
66	5	01-35-26		What clearances are required for site access? TWIC? FBI? 5512?	PENDING RESPONSE
67	1	Attachment B		Please confirm both ELIN Lines A0006 and A0007 is the same scope of work? If not, please provide the clarification.	PENDING RESPONSE
68	1	Attachment B		ELIN 0008 Please specify what type of vapor barrier.	PENDING RESPONSE
69	1	Attachment B		ELIN 0023 Please specify clarification on work- coating of slate shingles?	PENDING RESPONSE
70	1	Attachment B		ELIN 0026,27,28,29- Please advise on manufacturing requirements.	PENDING RESPONSE
71	1	Attachment B		ELIN A0100 Please clarify the details of roof drain cleaning (i.e. only roof level)?	PENDING RESPONSE
72				There are modified bitumen line items in the ELINs but no specifications in Attachment A.	PENDING RESPONSE
73				There are TPA line items in the ELINs but no specifications in Attachment A.	See revised ELINs provided via Amendment 0005
74				Please provide a site map for NSA Mechanicsburg.	Provided as Attachment with Amendment 0005.

75				Please provide a roof history for NSA Mechanicsburg and NSA Philadelphia similar to Attachment C NSWC PNYA Roofs.	Documentation to be provided per task order.
76				The ELINs do not include items for the 6 times per year roof/gutter/drain cleaning as per Attachment C or the biannual work referenced in Attachment D. Is this work required for this contract?	Revised Attachment provided. No cleanings are required for this contract. However, this work could be requested through a task order.
77				What type of wood species is expected for the T&G treated wood decking?	The Navy follows the minimum requirements under the em385 and all city and state regulations and codes unless specified.
78				This contract includes Davis Bacon wages for two counties that are significantly different. Which should be used for pricing?	See revised ELINs provided via Amendment 0005
79				Are there any specific criteria or certification requirements for the individual(s) conducting roof surveys?	The Navy follows the minimum requirements under the em385 and all city and state regulations and codes unless specified.
80				How are weather-related delays handled for the task orders?	An ECD extension request is submitted.
81		Wind Uplift Requirements		Provide wind speeds for all roof systems per the specification sections "Wind Uplift Resistance."	The Navy follows the minimum requirements under the em385 and all city and state regulations and codes unless specified.
82	12	07 53 23	2.1.1	For Type II EPDM reinforced, is a thickness of 75 mils acceptable?	The Navy follows the minimum requirements under the em385 and all city and state regulations and codes unless specified.
83	12	07 53 23	2.1.1	For ballasted EPDM roofs, provide minimum mil thickness.	The Navy follows the minimum requirements under the em385 and all city and state regulations and codes unless specified.
84				For line item A0131, what type of work is meant to be addressed? Is this to be priced for evaluation?	PENDING RESPONSE
85				For line item A0132, what type of work is expected for the unit labor work? Is this to be priced for evaluation?	PENDING RESPONSE

86				What are the onsite staffing requirements?	See Attachment General Specifications.
87				Line items A0006 and A0007 are both tapered insulations. Is one of them meant to be for field/flat boards?	PENDING RESPONSE
88				Can the insulation be priced by various thicknesses for different R-values that might be required?	The Navy follows the minimum requirements under the em385 and all city and state regulations and codes unless specified.
89				Can the tapered insulation be priced by board foot rather than by the square?	See revised ELINs provided via Amendment 0005. Prices shall be provided by unit indicated in each Line Item.
90				Please allow for a time extension on the proposal due date to allow for the responses to the questions to be reflected in the proposals.	See response to PPI# 35.
91				Is the bid guarantee to be based on 20% of the base year total price?	The bid guarantee shall be 20% of the bid price for the total contract including base plus all four option years, or \$3M, whichever is less.
92	12	07 60 00	2.2.20	According to the Copings paragraph, copings shall be copper unless otherwise indicated. If allowed, what thicknesses are required for aluminum and stainless steel? No thicknesses are provided for aluminum or stainless steel on Table I for copings other than copper.	The Navy follows the em385 and all city and state regulations and codes.
93		ELIN		We will have different pricing based on the wage rates for each county. Can the ELINs be separated to include the actual costs for each site?	See revised ELINs provided via Amendment 0005.
94		ATTCH C&D		Please provide clarification on inspections at each location.	No inspections are required under this contract. Inspection/Surveys may be requested however, this will be done through a task order in which all information will be provided at that time.
95				Can the bid date be extended by 1 week?	See response to PPI# 35.

96				Will the costs associated the required for the full time QC manager, SSHO and Superintendent be added to the total cost of each Task Order after the scope of work and the duration of the individual Task Order is established?	Yes, we will provide a Service Repair Order (SRO) for you to fill in which includes ELINs we used pertaining to the work. For any labor and materials not covered in a specific ELIN you will use
97				Please provide Wage Rates for Mechanicsburg location. If they differ from the Phila. wage rates there should be a different pricing schedule for that location.	Wage Rates for Mechanicsburg are provided by the IFB.
98	8	3.2	2	We are a Joint Venture with a Mentor Protégé in place. Are we required to submit financials for both parties or will just the mentor's suffice?	Both are required. Refer to page 8 of the IFB and bid per IFB.
99				Will the following FAR Clauses be incorporated into this contract? DFARS Clause 252.204-7021 Contractor Compliance with Cybersecurity Model Certification Level Requirements DFARS Provision 252.204-7025 Notice of Cybersecurity Maturity Model Certification Level Requirements	Both are already included in the IFB.
100	ELIN's			Philadelphia and Mechanicsburg have significant differences in their wage rates. Also, the travel costs will vary significantly depending on the location of each task order. Two separate ELIN's should be provided for each location for accurate pricing. Please advise if this is possible.	A revision to the ELINs was made to separate Philadelphia and Mechanicsburg. See Amendment 0005.
101				How many contractors do you anticipate will be selected/awarded this contract for advantageous & competitive pricing that best serves the United States government?	One contractor will be selected for this award.
102				Per the site meeting, could you please advise when photos documenting the general conditions of the roofs will be made available?	Photos will not be provided as the condition of each roof is not necessary as this is an IDIQ contract. Each task order will have its own individual site visit.
103				Additionally, can we expect an extension to the proposal due date to allow time for responses to submitted questions?	See response to PPI#35.
104	27	3	52.228-1	The Surety Company is asking what dollar amount are we using, since there is not a seed project. Ie. 20% of X? _____. The Specs say 3,000,000. We want to be accurate.	See response to PPI#91.

ATTACHMENTS:

1. Amendment 0005 – Attachment A – General Specification Revisions
2. Amendment 0005 – Attachment B – Roof Survey Check List
3. Amendment 0005 – Attachment C - NSW PNYA Roofs (Revised)
4. Amendment 0005 – Attachment D - PNYA CNIC Bldg. 44 Roof (Revised)
5. Amendment 0005 – Attachment ELINS – ELINS Roofing IDIQ Revised
6. Amendment 0005 – Attachment P – NSA-M Base Map

(End Summary of Changes)