

LEBANON VAMC STERILE STORAGE IMPROVEMENTS

PROJECT #595-23-104
1700 S LINCOLN AVENUE
LEBANON, PA 17042

OWNER:
LEBANON VA MEDICAL CENTER
1700 S LINCOLN AVENUE
LEBANON PA 17042
(717) 272-6621

ARCHITECT/ENGINEER:
AE WORKS, LTD
418 BEAVER STREET
SEWICKLEY, PA 15143

CONTACT: STEPHEN SIMONDS

CONTACT: DAWN CINDRIC

SHEET INDEX

GENERAL	
G001	COVER SHEET
G100	ICRA NOTES AND PLANS
G101	ICRA PLANS
G102	ICRA PLANS
G103	ICRA PLANS
G104	ICRA PLANS

ARCHITECTURAL	
A101	BUILDING 1 - THIRD FLOOR ARCHITECTURAL PLAN
A102	BUILDING 102 - FIRST FLOOR ARCHITECTURAL PLAN

MECHANICAL	
M-001	MECHANICAL SYMBOLS, ABBREVIATIONS, AND GENERAL NOTES
001-MD-100	BUILDING 1 - BASEMENT FLOOR HVAC DEMOLITION PLAN
001-MD-101	BUILDING 1 - FIRST FLOOR HVAC DEMOLITION PLAN
001-MD-102	BUILDING 1 - SECOND FLOOR HVAC DEMOLITION PLAN
001-MD-103	BUILDING 1 - THIRD FLOOR HVAC DEMOLITION PLAN
001-MD-104	BUILDING 1 - FOURTH FLOOR HVAC DEMOLITION PLAN
001-MD-105	BUILDING 1 - FIFTH FLOOR HVAC DEMOLITION PLAN
004-MD-101	BUILDING 4 - FIRST FLOOR HVAC DEMOLITION PLAN
017-MD-101	BUILDING 17 - FIRST FLOOR HVAC DEMOLITION PLAN
017-MD-102	BUILDING 17 - SECOND FLOOR HVAC DEMOLITION PLAN
017-MD-103	BUILDING 17 - THIRD FLOOR HVAC DEMOLITION PLAN
017-MD-104	BUILDING 17 - FOURTH FLOOR HVAC DEMOLITION PLAN
017-MD-105	BUILDING 17 - FIFTH FLOOR HVAC DEMOLITION PLAN
018-MD-104	BUILDING 18 - FOURTH FLOOR HVAC DEMOLITION PLAN
018-MD-105	BUILDING 18 - FIFTH FLOOR HVAC DEMOLITION PLAN
022-MD-101	BUILDING 22 - FIRST FLOOR HVAC DEMOLITION PLAN
022-MD-102	BUILDING 22 - SECOND FLOOR HVAC DEMOLITION PLAN
037-MD-101	BUILDING 37 - FIRST FLOOR HVAC DEMOLITION PLAN
101-MD-101	BUILDING 101 - FIRST FLOOR HVAC DEMOLITION PLAN
102-MD-101	BUILDING 102 - FIRST FLOOR HVAC DEMOLITION PLAN
104-MD-101	BUILDING 104 - FIRST FLOOR HVAC DEMOLITION PLAN
104-MD-103	BUILDING 104 - THIRD FLOOR HVAC DEMOLITION PLAN
001-M-100	BUILDING 1 - BASEMENT FLOOR HVAC PLAN
001-M-101	BUILDING 1 - FIRST FLOOR HVAC PLAN
001-M-102	BUILDING 1 - SECOND FLOOR HVAC PLAN
001-M-103	BUILDING 1 - THIRD FLOOR HVAC PLAN
001-M-104	BUILDING 1 - FOURTH FLOOR HVAC PLAN
001-M-105	BUILDING 1 - FIFTH FLOOR HVAC PLAN
004-M-101	BUILDING 4 - FIRST FLOOR HVAC PLAN
017-M-101	BUILDING 17 - FIRST FLOOR HVAC PLAN
017-M-102	BUILDING 17 - SECOND FLOOR HVAC PLAN
017-M-103	BUILDING 17 - THIRD FLOOR HVAC PLAN
017-M-104	BUILDING 17 - FOURTH FLOOR HVAC PLAN
017-M-105	BUILDING 17 - FIFTH FLOOR HVAC PLAN
018-M-104	BUILDING 18 - FOURTH FLOOR HVAC PLAN
018-M-105	BUILDING 18 - FIFTH FLOOR HVAC PLAN
022-M-101	BUILDING 22 - FIRST FLOOR HVAC PLAN
022-M-102	BUILDING 22 - SECOND FLOOR HVAC PLAN
037-M-101	BUILDING 37 - FIRST FLOOR HVAC PLAN
101-M-101	BUILDING 101 - FIRST FLOOR HVAC PLAN
102-M-101	BUILDING 102 - FIRST FLOOR HVAC PLAN
104-M-101	BUILDING 104 - FIRST FLOOR HVAC PLAN
104-M-103	BUILDING 104 - THIRD FLOOR HVAC PLAN

001-MP-100	BUILDING 1 - BASEMENT FLOOR PIPING PLAN
001-MP-101	BUILDING 1 - FIRST FLOOR PIPING PLAN
001-MP-102	BUILDING 1 - SECOND FLOOR PIPING PLAN
001-MP-103	BUILDING 1 - THIRD FLOOR PIPING PLAN
001-MP-104	BUILDING 1 - FOURTH FLOOR PIPING PLAN
001-MP-105	BUILDING 1 - FIFTH FLOOR PIPING PLAN
004-MP-101	BUILDING 4 - FIRST FLOOR PIPING PLAN
017-MP-101	BUILDING 17 - FIRST FLOOR PIPING PLAN
017-MP-102	BUILDING 17 - SECOND FLOOR PIPING PLAN
017-MP-103	BUILDING 17 - THIRD FLOOR PIPING PLAN
017-MP-104	BUILDING 17 - FOURTH FLOOR PIPING PLAN
017-MP-105	BUILDING 17 - FIFTH FLOOR PIPING PLAN
018-MP-104	BUILDING 18 - FOURTH FLOOR PIPING PLAN
018-MP-105	BUILDING 18 - FIFTH FLOOR PIPING PLAN
022-MP-101	BUILDING 22 - FIRST FLOOR PIPING PLAN
022-MP-102	BUILDING 22 - SECOND FLOOR PIPING PLAN
037-MP-101	BUILDING 37 - FIRST FLOOR PIPING PLAN
101-MP-101	BUILDING 101 - FIRST FLOOR PIPING PLAN
102-MP-101	BUILDING 102 - FIRST FLOOR PIPING PLAN
104-MP-101	BUILDING 104 - FIRST FLOOR PIPING PLAN
104-MP-103	BUILDING 104 - THIRD FLOOR PIPING PLAN
M501	HVAC DETAILS 1
M502	HVAC DETAILS 2
M503	HVAC DETAILS 3
M-701	HVAC SCHEDULES
M-702	VENTILATION INDEX
M800	CONTROL DIAGRAMS - LEGEND
M801	CONTROL DIAGRAMS 1
M802	CONTROL DIAGRAMS 2

ELECTRICAL	
E000	ELECTRICAL SYMBOLS AND ABBREVIATIONS
001-ED-104	BUILDING 1 - FOURTH FLOOR ELECTRICAL DEMOLITION PLAN
001-ED-105	BUILDING 1 - FIFTH FLOOR ELECTRICAL DEMOLITION PLAN
004-ED-101	BUILDING 4 - FIRST FLOOR ELECTRICAL DEMOLITION PLAN
017-ED-104	BUILDING 17 - FOURTH FLOOR ELECTRICAL DEMOLITION PLAN
017-ED-105	BUILDING 17 - FIFTH FLOOR ELECTRICAL DEMOLITION PLAN
001-E-100	BUILDING 1 - GROUND FLOOR ELECTRICAL PLAN
001-E-101	BUILDING 1 - FIRST FLOOR ELECTRICAL PLAN
001-E-102	BUILDING 1 - SECOND FLOOR ELECTRICAL PLAN
001-E-103	BUILDING 1 - THIRD FLOOR ELECTRICAL PLAN
001-E-104	BUILDING 1 - FOURTH FLOOR ELECTRICAL PLAN
001-E-105	BUILDING 1 - FIFTH FLOOR ELECTRICAL PLAN
004-E-101	BUILDING 4 - FIRST FLOOR ELECTRICAL PLAN
017-E-101	BUILDING 17 - FIRST FLOOR ELECTRICAL PLAN
017-E-102	BUILDING 17 - SECOND FLOOR ELECTRICAL PLAN
017-E-103	BUILDING 17 - THIRD FLOOR ELECTRICAL PLAN
017-E-104	BUILDING 17 - FOURTH FLOOR ELECTRICAL PLAN
017-E-105	BUILDING 17 - FIFTH FLOOR ELECTRICAL PLAN
018-E-104	BUILDING 18 - FOURTH FLOOR ELECTRICAL PLAN
018-E-105	BUILDING 18 - FIFTH FLOOR ELECTRICAL PLAN
022-E-101	BUILDING 22 - FIRST FLOOR ELECTRICAL PLAN
022-E-102	BUILDING 22 - SECOND FLOOR ELECTRICAL PLAN
037-E-101	BUILDING 37 - FIRST FLOOR ELECTRICAL PLAN
101-E-101	BUILDING 101 - FIRST FLOOR ELECTRICAL PLAN
102-E-101	BUILDING 102 - FIRST FLOOR ELECTRICAL PLAN
104-E-101	BUILDING 104 - FIRST FLOOR ELECTRICAL PLAN
104-E-103	BUILDING 104 - THIRD FLOOR ELECTRICAL PLAN
E700	ELECTRICAL SCHEDULES
E701	ELECTRICAL SCHEDULES
E702	ELECTRICAL SCHEDULES

VICINITY MAP



SITE

LOCATION MAP



SITE

		Consultant		Architect/Engineer of Record		Stamp		OFFICE OF CONSTRUCTION AND FACILITIES MANAGEMENT		Drawing Title COVER SHEET		Phase BID DOCUMENTS		Project Title STERILE STORAGE IMPROVEMENTS		Project Number 595-23-104	
																Building Number -	
														Location 1700 S LINCOLN AVE, LEBANON, PA 17042		Drawing Number	
														Issue Date 11.17.25		Checked DC	
																Drawn SB	
																G001 1 of 110	

INFECTION CONTROL RISK ASSESSMENT FOR CONSTRUCTION
(TO BE COMPLETED BY CONTRACTOR AND SIGNED BY INFECTION CONTROL NURSE)

STEP #1: SELECT ACTIVITY TYPE BELOW:
CONSTRUCTION ACTIVITY TYPES:

TYPE A - INSPECTION AND NON-INVASIVE ACTIVITIES
INCLUDES, BUT NOT LIMITED TO:
• REMOVAL OF CEILING TILES FOR VISUAL INSPECTION LIMITED TO 1 TILE PER 50 SQUARE FEET
• PAINTING (BUT NOT SANDING)
• WALL COVERING
• ELECTRICAL TRIM WORK
• MINOR PLUMBING
• ACTIVITIES WHICH DO NOT GENERATE DUST OR REQUIRE CUTTING OF WALLS OR ACCESS TO CEILINGS OTHER THAN FOR VISUAL INSPECTION

TYPE B - SMALL SCALE, SHORT DURATION (less than 1 day) ACTIVITIES WHICH CREATE MINIMAL DUST
INCLUDES, BUT NOT LIMITED TO:
• INSTALLATION OF TELEPHONE AND COMPUTER CABLEING
• ACCESS TO CHASE SPACES
• CUTTING OF WALLS OR CEILING WHERE DUST MIGRATION CAN BE CONTROLLED

TYPE C - WORK THAT GENERATES A MODERATE TO HIGH LEVEL OF DUST OR REQUIRES DEMOLITION OR REMOVAL OF ANY FIXED BUILDING COMPONENTS OR ASSEMBLIES
INCLUDES, BUT NOT LIMITED TO:
• SANDING OF WALLS FOR PAINTING OR WALL COVERING
• REMOVAL OF FLOOR COVERING, CEILING TILES AND CASEWORK
• NEW WALL CONSTRUCTION
• MINOR DUCT WORK OR ELECTRICAL WORK ABOVE CEILINGS
• MAJOR CABLEING ACTIVITIES
• ANY ACTIVITY WHICH CANNOT BE COMPLETED WITHIN A SINGLE WORK SHIFT

TYPE D - MAJOR DEMOLITION AND CONSTRUCTION PROJECTS
INCLUDES, BUT NOT LIMITED TO:
• ACTIVITIES THAT REQUIRE CONSECUTIVE WORK SHIFTS
• REQUIRES HEAVY DEMOLITION OR REMOVAL OF A COMPLETE CABLEING SYSTEM
• NEW CONSTRUCTION

IS IT LIKELY THE CONTRACTOR'S STAFF WILL BE PLACED AT RISK FOR INFECTION WITH TUBERCULOSIS? YES / NO
IS IT LIKELY THERE WILL BE PHYSICAL DISRUPTION OF THE WATER SYSTEMS DURING ACTIVITY? YES / NO

STEP #4: COMPLETE THE INFECTION CONTROL CONSTRUCTION PERMIT:

CLASS I - DURING CONSTRUCTION PROJECT
1. EXECUTE WORK BY METHOD TO MINIMIZE RAISING DUST FROM CONSTRUCTION OPERATIONS
2. IMMEDIATELY REPLACE A CEILING TILE DISPLACED FOR VISUAL INSPECTION

CLASS II - DURING CONSTRUCTION PROJECT
1. PROVIDE ACTIVE MEANS TO PREVENT AIRBORNE DUST FROM DISPERSING INTO ATMOSPHERE
2. WATER MIST WORK SURFACES TO CONTROL DUST WHILE CUTTING
3. SEAL UNUSED DOORS WITH DUCT TAPE
4. BLOCK OFF AND SEAL AIR VENTS
5. PLACE DUST MAT AT ENTRANCE AND EXIT OF WORK AREA
6. REMOVE OR ISOLATE HVAC SYSTEM IN AREAS WHERE WORK IS BEING PERFORMED

CLASS III - DURING CONSTRUCTION PROJECT
1. REMOVE OR ISOLATE HVAC SYSTEM IN AREA WHERE WORK IS BEING DONE TO PREVENT CONTAMINATION OF DUCT SYSTEM
2. COMPLETE ALL CRITICAL BARRIERS, I.E. SHEETROCK, PLYWOOD, PLASTIC, TO SEAL AREA FROM NON-WORK AREA OR IMPLEMENT CONTROL CUBE METHOD (GART WITH PLASTIC COVERING & SEALED CONNECTION TO WORK SITE WITH HEPA VACUUM FOR VACUUMING PRIOR TO EXIT) BEFORE CONSTRUCTION BEGINS
3. MAINTAIN NEGATIVE AIR PRESSURE WITHIN WORKSITE UTILIZING HEPA-EQUIPPED AIR FILTRATION UNITS
4. CONTAIN CONSTRUCTION WASTE BEFORE TRANSPORTATION IN TIGHTLY COVERED CONTAINERS
5. COVER TRANSPORT RECEPTACLES OR CARTS. TAPE COVERING UNLESS SOLID LID IS USED

CLASS IV - DURING CONSTRUCTION PROJECT
1. ISOLATE HVAC SYSTEM IN AREA WHERE WORK IS BEING DONE TO PREVENT CONTAMINATION OF DUCT SYSTEM
2. COMPLETE ALL CRITICAL BARRIERS, I.E. SHEETROCK, PLYWOOD, PLASTIC, TO SEAL AREA FROM NON-WORK AREA OR IMPLEMENT CONTROL CUBE METHOD (GART WITH PLASTIC COVERING & SEALED CONNECTION TO WORK SITE WITH HEPA VACUUM FOR VACUUMING PRIOR TO EXIT) BEFORE CONSTRUCTION BEGINS
3. MAINTAIN NEGATIVE AIR PRESSURE WITHIN WORKSITE UTILIZING HEPA-EQUIPPED AIR FILTRATION UNITS
4. SEAL HOLES, PIPES, CONDUITS AND PUNCTURES APPROPRIATELY
5. CONSTRUCT ANTEROOM AND REQUIRE ALL PERSONNEL TO PASS THROUGH THIS ROOM SO THEY CAN BE VACUUMED USING A HEPA VACUUM CLEANER BEFORE LEAVING WORK SITE, OR THE CAN WEAR CLOTH OR PAPER COVERALLS THAT ARE REMOVED EACH TIME THEY LEAVE THE WORK SITE
6. ALL PERSONNEL ENTERING THE WORK SITE ARE REQUIRED TO WEAR SHOE COVERS. SHOE COVERS MUST BE CHANGED EACH TIME THE WORKER EXITS THE WORK AREA
7. DO NOT REMOVE BARRIERS FROM WORK AREA UNTIL COMPLETED PROJECT IS INSPECTED BY SAFETY MANAGEMENT & INFECTION CONTROL, & THOROUGHLY CLEANED BY ENVIRONMENTAL MANAGEMENT

CLASS I - UPON COMPLETION OF PROJECTS

1. CLEAN WORK UPON COMPLETION OF TASK

CLASS II - UPON COMPLETION OF PROJECTS

1. WIPE WORK SURFACES WITH DISINFECTANT
2. CONTAIN CONSTRUCTION WASTE BEFORE TRANSPORT IN TIGHTLY COVERED CONTAINERS
3. REMOVE ISOLATION OF HVAC SYSTEM IN AREA WHERE WORK IS BEING PERFORMED

CLASS III - UPON COMPLETION OF PROJECTS
1. DO NOT REMOVE BARRIERS FROM WORK AREA UNTIL COMPLETED PROJECT IS INSPECTED BY SAFETY MANAGEMENT & INFECTION CONTROL, & THOROUGHLY CLEANED BY ENVIRONMENTAL MANAGEMENT
2. REMOVE BARRIER MATERIALS CAREFULLY TO MINIMIZE SPREADING OF DIRT & DEBRIS ASSOCIATED WITH CONSTRUCTION
3. VACUUM WORK AREA WITH HEPA-FILTERED VACUUMS
4. WET MOP WITH DISINFECTANT
5. REMOVE ISOLATION OF HVAC SYSTEM IN AREAS WHERE WORK IS BEING PERFORMED

CLASS IV - UPON COMPLETION OF PROJECTS
1. REMOVE BARRIER MATERIALS CAREFULLY TO MINIMIZE SPREADING OF DIRT & DEBRIS ASSOCIATED WITH CONSTRUCTION
2. CONTAIN CONSTRUCTION WASTE BEFORE TRANSPORT IN TIGHTLY COVERED CONTAINERS
3. COVER TRANSPORT RECEPTACLES OR CARTS. TAPE COVERING UNLESS SOLID LID
4. VACUUM WORK AREA WITH HEPA-FILTERED VACUUMS
5. WET MOP WITH DISINFECTANT
6. REMOVE ISOLATION OF HVAC SYSTEM IN AREAS WHERE WORK IS BEING PERFORMED

CONTRACTOR'S SIGNATURE AND DATE

INFECTION CONTROL NURSE'S SIGNATURE AND DATE

STEP #2: SELECT RISK GROUP BELOW AND MARK BOTTOM OF COLUMN

A) INFECTION CONTROL RISK GROUPS

GROUP 1 - LOW: OFFICE AREAS:

GROUP 2 - MEDIUM: CARIOLOGY, ECHOCARDIOGRAPHY, ENDOSCOPY, NUCLEAR MEDICINE, PHYSICAL THERAPY, RADIOLOGY/MRI, RESPIRATORY THERAPY

GROUP 3 - HIGH RISK: COLI, EMERGENCY ROOM, LABORATORIES, OUTPATIENT SURGERY, PHARMACY, POST ANESTHESIA CARE UNIT, SURGICAL UNITS

GROUP 4 - HIGHEST RISK: ANY AREA CARING FOR IMMUNOCOMPROMISED PATIENTS, CARDIAC CATH LAB, CENTRAL SUPPLY, INTENSIVE CARE UNIT, MEDICAL UNITS, NEGATIVE AIRFLOW ROOMS, ONCOLOGY, OPERATING ROOMS

STEP #3: DETERMINE CLASS OF PRECAUTIONS USING MATRIX BELOW:

CONSTRUCTION ACTIVITY INFECTION CONTROL MATRIX TO DETERMINE CLASS
* ION MUST BE CONSULTED WHEN THE ASSESSMENT INDICATES THAT CLASS II, III, IV PRECAUTIONS ARE REQUIRED

RISK LEVEL	TYPE 'A'	TYPE 'B'	TYPE 'C'	TYPE 'D'
GROUP 1	I	II	III / IV	IV
GROUP 2	I	II	III / IV	IV
GROUP 3	I	II	III / IV	IV
GROUP 4	II	III / IV	III / IV	IV
CONSTRUCTION TYPE: RISK GROUP:	D			RISK ASSESSMENT: IV

PROJECTED UTILITY OUTAGES IMPACTING INFECTION CONTROL	ELECTRICAL	POTABLE WATER	HVAC	MEDICAL VACUUM	SEWER
YES	YES	YES	YES	YES	YES


DUST CONTROL PLAN NOTES / DUST CONTROL PLAN HAZARD ASSESSMENT

PRIOR TO INITIATING WORK, CONTRACTOR WILL ASSESS THE SCOPE OF THE CONSTRUCTION ACTIVITIES AND DETERMINE THE POTENTIAL RISK GROUPS INVOLVED BASED ON THE LOCATION OF ACTIVITIES AND EXTENT AND DURATION OF THE WORK. LOW RISK GROUPS ARE CONSIDERED OFFICE WORKERS; MEDIUM RISK GROUPS ARE CONSIDERED INPATIENT AND OUTPATIENT AREAS NOT IN THE HIGH RISK GROUP. HIGH RISK GROUP DESIGNATION INCLUDES INPATIENT AREAS SUCH AS PEDIATRIC AND ADULT OPERATING/DELIVERY ROOMS, CATH LABS, IMMOBILIZATION UNITS, ICU, ANALYSIS, NURSING AS WELL AS CLINIC AREAS/CLINICS ASSOCIATED WITH HEMATOLOGY, ONCOLOGY, PEDIATRIC INFECTION DISEASE, OR TRANSPLANT SERVICES) AND SERVICE AREAS (CENTRAL PROCESSING, STERILE PROCESSING, FOOD PREP, ASEPTIC AREA AND PHARMACY). THE VAMC INFECTION CONTROL GROUP WILL CONFIRM AND APPROVE THE DESIGNATION PROVIDED IN THIS SUBMITTED DUST CONTROL PLAN. VAMC IS ALSO RESPONSIBLE FOR ANY AND ALL INFECTION CONTROL MEASURES DETERMINED AND ESTABLISHED BY VAMC POLICY, SUCH AS THE RELOCATION OF HIGH RISK PATIENTS, APPROVING ALTERNATE TRAFFIC PATHS FOR CONSTRUCTION WORKERS OR ESTABLISH ALTERNATE TRAFFIC PATTERNS FOR STAFF, PATIENTS AND VISITORS. THE PLAN SHOULD BE REVISED ACCORDING TO SPECIFIC VAMC POLICIES OR CHANGING CONDITIONS AT THE SITE AS THEY MAY OCCUR.

RENOVATION
FOR THE PURPOSE OF THIS RENOVATION, THE CONSTRUCTION WORK IS CONSIDERED ADJACENT TO MEDIUM RISK. AND COMPRISED WORK WHICH COULD GENERATE MODERATE TO HIGH LEVELS OF DUST NOT WITHIN THE CONFINES OF A SUITE OR OFFICE AND INCLUDES EXTENSIVE CONSTRUCTION WORK (DEMOLITION) IN BUILDING 6 THROUGHOUT THE FIRST, SECOND FLOOR CEILING AND BASEMENT. THE DUST CONTROL PLAN SHALL BE DISTRIBUTED AND REVIEWED BY ALL CONTRACTORS PERFORMING WORK ON THIS CONSTRUCTION PROJECT.

A. EXTERNAL DEMOLITION AND CONSTRUCTION ACTIVITIES
• DETERMINE IF THE IMPACTED AREA OF THE FACILITY CAN OPERATE TEMPORARILY ON RECIRCULATED AIR, IF FEASIBLE SEAL OFF ADJACENT AIR INTAKES
• IF THIS IS NOT POSSIBLE OR PRACTICAL, CHECK THE LOW-EFFICIENCY FILTER BANKS FREQUENTLY AND REPLACE AS NEEDED TO AVOID BUILDUP OF PARTICULATE
• SEAL WINDOWS AND REDUCE WHEREVER POSSIBLE OTHER SOURCES OF OUTSIDE AIR INTRUSION (OPEN DOORS IN STAIRWELLS AND CORRIDORS) ESPECIALLY IN PROTECTIVE ENVIRONMENT (PE) AREAS.


B. INTERNAL DEMOLITION AND CONSTRUCTION ACTIVITIES DUST AND DEBRIS CONTROL
• BARRIER SYSTEMS: THE AREA SHOULD BE ISOLATED, AS THE PROJECT REQUIRES. SMALL, SHORT DURATION PROJECTS GENERATING MINIMAL DUST MAY USE FIRE-RATED PLASTIC SHEETING, BUT SHOULD BE SEALED AT FULL CEILING HEIGHT WITH AT LEAST 2-FOOT OVERLAPPING FLAPS FOR ACCESS TO ENTRY. PROJECTS THAT PRODUCE MODERATE TO HIGH LEVELS OF DUST REQUIRE RIGID, DUST-PROOF, AND FIRE-RATED BARRIER WALLS (E.G., DRYWALL) WITH CAULKED SEAMS FOR A TIGHT SEAL EXTENDING FLOOR TO CEILING. SEAL OFF AND BLOCK RETURN AIR VENTS IF RIGID BARRIERS ARE USED FOR CONTAINMENT. LARGE DUST PROJECTS NEED AN ENTRY VESTIBULE FOR CLOTHING CHANGES AND TOOL STORAGE, AND TIGHT SEALS SHOULD BE MAINTAINED AT THE FULL PERIMETER OF WALLS AND WALL PENETRATIONS. AN INTERIM PLASTIC DUST BARRIER (MINIMUM 4 MIL) MAY BE REQUIRED TO PROTECT THE AREA WHILE THE RIGID IMPERVIOUS BARRIER IS BEING CONSTRUCTED. ANY DUST SHALL BE IMMEDIATELY CLEANED IF TRACKED OUTSIDE OF THE CONSTRUCTION BARRIER. UPON COMPLETION OF THE CONSTRUCTION PROJECT DUST BARRIERS SHALL BE REMOVED CAREFULLY TO MINIMIZE SPREADING OF DUST AND THE CONTRACTOR SHALL HAVE TEMPORARY DUST PROTECTION IN PLACE BEFORE REMOVAL OF A PERMANENT BARRIER. CONTRACTOR PERSONNEL SHALL MONITOR AND PERFORM BARRIER MAINTENANCE, AND BE EDUCATED TO NOTICE SIMPLE CUES SUCH AS ACCUMULATIONS OF VISIBLE DUST EVIDENCED BY FOOTPRINTS, OPENED DOORS/WINDOWS EVIDENCED BY PRESENCE OF INSECTS AND FLIES, WET CEILING TILE, ETC.
• TRAFFIC CONTROL: DESIGNATED ENTRY AND EXIT PROCEDURES SHALL BE DEFINED. EGRESS PATHS SHOULD BE FREE OF DEBRIS. DESIGNATED ELEVATORS SHOULD BE USED DURING SCHEDULED TIMES, AND ONLY AUTHORIZED PERSONNEL SHOULD BE ALLOWED TO ENTER THE CONSTRUCTION ZONE. SIGNAGE SHOULD DIRECT PEDESTRIAN TRAFFIC AWAY FROM THE CONSTRUCTION AREA AND MATERIALS.
• DEMOLITION DEBRIS: DEBRIS SHOULD BE REMOVED IN CARTS WITH TIGHTLY FITTED COVERS, USING DESIGNATED TRAFFIC ROUTES. EFFORTS SHOULD BE MADE TO MINIMIZE USE OF ELEVATORS WITH AN EMPHASIS ON TRANSPORT DURING THE LOWEST PERIOD OF ACTIVITY. DEBRIS SHOULD BE REMOVED DAILY AND AT TIMES SPECIFIED BY THE VAMC. IF CHUTES ARE USED TO DIRECT DEBRIS OUTSIDE, HIGH EFFICIENCY PARTICULATE HEPA/FILTERED NEGATIVE AIR MACHINES SHOULD BE USED, AND THE CHUTE OPENING SHOULD BE SEALED WHEN NOT IN USE. FILTERS SHOULD BE BAGGED AND SEALED BEFORE BEING TRANSPORTED OUT OF THE CONSTRUCTION AREA. THE CONTRACTOR SHALL NOT HALL DEBRIS THROUGH PATIENT-CARE AREAS WITH PRIOR APPROVAL OF THE VAMC.
• EXTERIOR WINDOWS: WINDOWS SHOULD BE SEALED TO MINIMIZE INFILTRATION FROM ANY ADJACENT EXCAVATION DEBRIS.
• CEILINGS THAT ARE REMOVED/MOVED TO ALLOW CONSTRUCTION OF ICRA BARRIERS SHOULD BE REINSTALLED TO PRE-CONSTRUCTION CONDITIONS.




TEMPORARY ICRA PARTITION

NOTE:

- FOR EXISTING PARTITIONS USED AS ICRA BARRIERS, THE CONTRACTOR SHALL COMPLETE THE FOLLOWING:
 - MODIFY EXISTING PARTITION TO A ONE-HOUR RATED ICRA BARRIER
 - EXTEND PARTITION TO FLOOR DECK WITH 58" G.W.B. ON EACH SIDE
 - FINISH WALL PARTITION AS DIRECTED BY UL RATING REQUIREMENTS
 - INFILL EXISTING OPENINGS WITH 58" G.W.B ON EACH SIDE
 - PROVIDE FIRESTOPPING AT ALL EXISTING PENETRATIONS
- PROVIDE 45 MINUTE RATED DOOR TO ACCESS CONSTRUCTION AREA AT ALL NEW AND EXISTING ICRA BARRIERS.
- THE CONTRACTOR SHALL NOT BLOCK SPRINKLER PROTECTION ON THE VA-OCCUPIED SIDE OF THE ICRA BARRIER.



1 Bldg 01-00 BASEMENT FLOOR - RM 51 - ICRA
1/4" = 1'-0"




2 Bldg 01-00 BASEMENT FLOOR - RM 16 - ICRA
1/4" = 1'-0"


ICRA KEYNOTES	
1	ANTICIPATED LOCATION OF TEMPORARY ICRA PARTITION. COORDINATE FINAL LOCATION WITH VA PRIOR TO INSTALLATION.
2	PROVIDE STICKY MATS AT ENTRANCE TO ANY ROOM WITH WORK BEING DONE.
3	SUPPLY AND INSTALL 6 MIL HEAVY DUTY, REINFORCED, FIRE-RETARDANT POLY SHEETING (VULQUEEN). PLASTIC SHEET SHALL BE FULLY SEALED AT PERIMETER. PROVIDE ZIPPER OPENINGS FOR AREAS AFFECTED BY WORK.

GENERAL ICRA NOTES


- ICRA BARRIERS AND POLY SHEETING SHOWN ON THE ICRA PLANS ARE GENERAL LOCATIONS OF WHAT IS ANTICIPATED BEING NEEDED. THE CONTRACTOR IS RESPONSIBLE FOR COMPLETING AN ICRA PLAN FOR EVERY AREA OF CONSTRUCTION AND FURNISHING ONTO THE VA COR FOR APPROVAL BEFORE STARTING ANY TYPE OF CONSTRUCTION.
- A MINIMUM OF 42" EGRESS IS REQUIRED IN EGRESS CORRIDORS AT ALL TIMES.





3 Bldg 01-00 BASEMENT FLOOR - G036 - ICRA
1/4" = 1'-0"




5 Bldg 01-01 FIRST FLOOR - 116A - ICRA
1/4" = 1'-0"




4 Bldg 01-01 FIRST FLOOR - 111 - ICRA
1/4" = 1'-0"



6 Bldg 01-02 SECOND FLOOR - 216 - ICRA
1/4" = 1'-0"




7 Bldg 01-02 SECOND FLOOR - 257-ICRA
1/4" = 1'-0"




8 Bldg 01-02 SECOND FLOOR - 293 - ICRA
1/4" = 1'-0"

		Consultant	Architect/Engineer of Record		Stamp	OFFICE OF CONSTRUCTION AND FACILITIES MANAGEMENT		Drawing Title ICRA NOTES AND PLANS	Phase BID DOCUMENTS	Project Title STERILE STORAGE IMPROVEMENTS		Project Number 595-23-104	
			AE WORKS			VA U.S. Department of Veterans Affairs		Approved:	Sprinkler Status FULLY SPRINKLERED	Location 1700 S LINCOLN AVE, LEBANON, PA 17042		Building Number -	
										Issue Date 11.17.25		Checked DC	Drawn SB
										G100		2 of 110	


ICRA KEYNOTES		
1	ANTICIPATED LOCATION OF TEMPORARY ICRA PARTITION. COORDINATE FINAL LOCATION WITH VA PRIOR TO INSTALLATION.	
2	PROVIDE STICKY MATS AT ENTRANCE TO ANY ROOM WITH WORK BEING DONE.	
3	SUPPLY AND INSTALL 6 MIL HEAVY DUTY, REINFORCED, FIRE-RETARDANT POLY SHEETING (VISCQUEEN). PLASTIC SHEET SHALL BE FULLY SEALED AT PERIMETER. PROVIDE ZIPPER OPENING FOR AREAS AFFECTED BY WORK.	




1 Bldg 01-03 THIRD FLOOR - 346 & 346A - ICRA
1/4" = 1'-0"




2 Bldg 01-03 THIRD FLOOR - 307 - ICRA
1/4" = 1'-0"




3 Bldg 01-03 THIRD FLOOR - 370 - ICRA
1/4" = 1'-0"




4 Bldg 01-04 FOURTH FLOOR - 406 - ICRA
1/4" = 1'-0"




5 Bldg 01-04 FOURTH FLOOR - 472 - ICRA
1/4" = 1'-0"




6 Bldg 01-05 FIFTH FLOOR - 572 - ICRA
1/4" = 1'-0"




7 Bldg 04-01 FIRST FLOOR - 105 - ICRA
1/4" = 1'-0"



8 Bldg 17-01-FIRST FLOOR - 123M - ICRA
1/4" = 1'-0"



BID DEDUCT 1-
Bldg 17-02-SECOND FLOOR - 209 - ICRA
1/4" = 1'-0"




BID DEDUCT 1-
Bldg 17-02-SECOND FLOOR - 264 - ICRA
1/4" = 1'-0"


11/17/2025 7:06:06 AM
Autodesk Docs\\VLEB-016 Sterile Storage Improvements\\VLEB-016-ARCH-24.rvt

			Consultant		Architect/Engineer of Record		Stamp	OFFICE OF CONSTRUCTION AND FACILITIES MANAGEMENT		Drawing Title ICRA PLANS		Phase BID DOCUMENTS		Project Title STERILE STORAGE IMPROVEMENTS		Project Number 595-23-104			
					 AE WORKS AE Works, LTD. 418 Beaver Street Sewickley, PA 15143 Phone: 412-287-7333 www.ae-works.com		 11/17/2025	VA U.S. Department of Veterans Affairs										Building Number -	
1	BID DEDUCT #1		03/02/2026									Sprinkler Status FULLY SPRINKLERED		Location 1700 S LINCOLN AVE, LEBANON, PA 17042		Drawing Number G101 3 of 110			
#	Revisions		Date											Issue Date 11.17.25		Checked DC		Drawn SB	

[illegible]

Autodesk Docs://VLEB-016 Sterile Storage Improvements/VLEB-016-ARCH 24 INT 11/17/2025 7:06:12 AM






BUILDING 1 - THIRD FLOOR - OVERALL PLAN

GENERAL PROJECT NOTES


- 1 THE CONSTRUCTION WORK TO CONFORM WITH THE APPLICABLE CODES AND ORDINANCES OF THE LOCAL JURISDICTION, THE COMMONWEALTH OF PENNSYLVANIA, AND THE CURRENT APPLICABLE VERSION OF THE INTERNATIONAL BUILDING CODE FAMILY. THE CONTRACTOR TO POST NOTICES AND COMPLY WITH THE GOVERNING LAWS OF THE JURISDICTION.
- 2 INSTALLATIONS PERFORMED IN CONNECTION WITH THESE DRAWINGS TO COMPLY WITH THE MOST RECENT NFPA EDITION.
- 3 MAINTAIN ADEQUATE PROTECTION TO SAFEGUARD THE PUBLIC AND ALL PERSONS ENGAGED IN THE PERFORMANCE OF THE WORK.
- 4 THE DRAWINGS REFLECT CONDITIONS AS CAN BE INFERRED FROM VISIBLE CONDITIONS, OR FROM DRAWINGS AND INFORMATION FURNISHED BY THE OWNER, BUT CANNOT BE GUARANTEED. VERIFY ALL GRADES, LINE LEVELS AND DIMENSIONS INDICATED ON THE DRAWINGS AND REPORT ALL INCONSISTENCIES TO THE ARCHITECT PRIOR TO THE EXECUTION OF THE WORK. RECHECK ALL DIMENSIONS PRIOR TO ORDERING MANUFACTURED AND/OR FABRICATED ITEMS.
- 5 PLAN DIMENSIONS, UNLESS NOTED OTHERWISE, ARE TO THE FACE OF THE WALL FINISH OR CENTERLINE OF COLUMN.
- 6 ASSUME FULL RESPONSIBILITY FOR PROTECTION AND SAFEKEEPING OF PRODUCTS PURCHASED FOR THIS PRODUCT AND STORED ON THE PROJECT SITE. COORDINATE WITH THE OWNER ON DEFERRED LOGISTICS FOR REMOVAL OF EXCESS MATERIALS ON THE PROJECT SITE, IF ALLOWED AS PART OF THE REQUIREMENTS OF THIS PROJECT.
- 7 MAINTAIN AREAS UNDER THE CONTRACTOR'S CONTROL, TO BE FREE OF WASTE MATERIALS, DEBRIS, AND RUBBISH. CONTAINERS FOR DEPOSIT OF DEBRIS AND RUBBISH WILL BE PROVIDED BY THE CONTRACTOR. COORDINATE LOCATION OF CONTAINERS WITH THE OWNERS REPRESENTATIVE PRIOR TO APPLICATION. REMOVE AND SPECIFY DEPOSITION MATERIAL OFF SITE IN ACCORDANCE WITH APPLICABLE CODES AND/OR SPECIFICATIONS.
- 8 EXTRANEOUS MATERIALS TO BE PERIODICALLY REMOVED, AND AT THE CONCLUSION OF THE PROJECT.
- 9 PROVIDE AND INSTALL ALL FIRE-RESISTING / FIRESTOPPING MATERIALS AT ALL THROUGH-WALL AND THROUGH-CEILING PENETRATIONS AS REQUIRED FOR THE CONSTRUCTION WORK AND TO FURNISH RATING OF FLOORS AND WALLS. MATERIALS AND INSTALLATION DETAILS TO CONFORM TO UNDERWRITER LABORATORIES LISTING FOR RATED ASSEMBLIES.
- 10 ALL WOOD FRAMING AND SHEATHING TO BE FIRE RETARDANT TREATED AS REQUIRED BY THE BUILDING CODE CLASSIFICATION OF NONCOMBUSTIBLE.
- 11 DO NOT SCALE DRAWINGS. FIELD VERIFY ALL DIMENSIONS AND CONDITIONS PRIOR TO CONSTRUCTION. NOTIFY THE ARCHITECT IF ANY DEVIATIONS OR DISCREPANCIES FOUND AND RECEIVE DIRECTION BEFORE PROCEEDING.
- 12 DURING CONSTRUCTION THE CONTRACTOR WILL WORK ADJACENT TO CURRENT OCCUPIED FLOOR AREAS. CERTAIN ACTIVITIES ARE NOT TO ADVERSELY IMPACT THESE AREAS. CONSTRUCTION RELATED ACTIVITIES THAT MIGHT AFFECT THESE AREAS MUST BE COORDINATED WITH AND APPROVED BY THE VA PRIOR TO OCCURRENCE.
- 13 PROVIDE TEMPORARY DUST ENCLOSURES DURING ALL DEMOLITION AND CONSTRUCTION ACTIVITIES. CONTRACTOR TO COORDINATE LOCATIONS WITH CONTRACTING OFFICER. IF EXISTING WALLS ARE USED, PENETRATIONS MUST BE SEALED TO CREATE A DUST PROOF ENCLOSURE.
- 14 MODIFICATIONS TO THE EXISTING MEP SYSTEMS WILL IMPACT ADJACENT SPACES OUTSIDE THE GENERAL SCOPE OF WORK. ANY DISTURBANCE OF EXISTING CONDITIONS AND FINISHES MUST BE REPAIRED TO MATCH THE CONDITIONS PRIOR TO CONSTRUCTION IMPACTS.
- 15 THE FACILITY IS OPERATIONAL. CONTRACTOR TO MAKE PROVISIONS FOR OWNER AND PUBLIC USE OF THE BUILDING AROUND THE CONSTRUCTION AREA. DELIVERIES, STAGING, STORAGE OF MATERIALS AND OTHER CONSTRUCTION RELATED ACTIVITIES TO BE COORDINATED WITH THE CONTRACTING OFFICER SO AS TO NOT ADVERSELY AFFECT THE WORKING OPERATIONS.
- 16 ASBESTOS AND LEAD ARE NOT ANTICIPATED TO EXIST IN THE BUILDING AREA. HOWEVER, IF ASBESTOS-CONTAINING MATERIAL IS DISCOVERED OR SUSPECTED, STOP WORKING IN THE AREA IMMEDIATELY AND CONTACT THE CONTRACTING OFFICER.
- 17 ALL REVISIONS TO THE DRAWINGS MUST PROCEED THROUGH THE ARCHITECT. OWNER / CONTRACTOR REVISIONS MAY BE CONSIDERED INVALID.
- 18 COMPARE AND COORDINATE ALL DRAWINGS FOR PROPER FIT AND ATTACHMENT OF ALL PARTS. DETAILS NOT SHOWN OR DESCRIBED IN THESE NOTES ARE TO BE CONSTRUCTED TO SAME SIZE AND CHARACTER AS FOR SIMILAR CONDITIONS WHEN SHOWN, SPECIFIED, OR COMMONLY CONSTRUCTED IN THE INDUSTRY.
- 19 NO STRUCTURAL MEMBER TO BE OMITTED, NOTCHED, CUT, BLOCKED OUT, OR RELOCATED WITHOUT PRIOR APPROVAL BY THE ARCHITECT OR ENGINEER.
- 20 PROTECTIVE MEASURES TO BE TAKEN BY THE CONTRACTOR TO PROTECT ADJACENT PROPERTY AT ALL TIMES DURING CONSTRUCTION.
- 21 ALL TEMPORARY BRACING AND SHORING TO BE DESIGNED TO SUSTAIN ALL CONSTRUCTION LOADS, SOIL PRESSURE, LATERAL AND OTHER LOADS TO WHICH THE STRUCTURE MAY BE SUBJECTED.
- 22 COORDINATE LOCATIONS OF LIGHT FIXTURES, SPRINKLER HEADS, REGISTERS, ETC. WITH THE REFLECTED CEILING PLAN LAYOUT.
- 23 ALL SPRINKLER HEADS, DIFFUSERS AND REGISTERS TO BE CENTERED WITH SUSPENDED ACoustICAL PANELS, UNLESS NOTED OTHERWISE ON DRAWINGS.
- 24 ALL VOIDS IN MASONRY, CONCRETE AND OTHER ASSEMBLIES CREATED AROUND PENETRATIONS TO BE FILLED / PATCHED WITH CONSTRUCTION TO MATCH SURROUNDING CONDITIONS.
- 25 CONTRACTOR IS RESPONSIBLE FOR REMOVING AND REPLACING EXISTING CEILINGS IN AREAS OF CONSTRUCTION.
- 26 ALL EXISTING SPRINKLERS AND FIRE ALARM SYSTEMS ARE TO REMAIN ACTIVE THROUGHOUT CONSTRUCTION.
- 27 CONTRACTOR TO COORDINATE ANY BUILDING SYSTEM SHUTDOWNS WITH VA OR PRIOR TO SHUTTING DOWN ANY SYSTEM.

KEYNOTES

- INFILL EXISTING OPENING WITH NEW WALL. PAINT AND ADD WALL BASE TO MATCH ADJACENT WALLS.
- ADD NEW PARTITION AND DOOR TO CREATE A NEW STORAGE ROOM. MODIFY EXISTING ACT CEILING AS REQUIRED TO INSTALL NEW PARTITION.




BUILDING 102 - FIRST FLOOR ENLARGED PLAN
1/4" = 1'-0"



BUILDING 102 - FIRST FLOOR ARCHITECTURAL OVERALL PLAN
1/16" = 1'-0"

DOOR SCHEDULE

DOOR NUMBER	WIDTH	DOOR			FRAME		HARDWARE SET	FIRE RATING	CARD ACCESS	COMMENTS
		HEIGHT	TYPE	MATERIAL	TYPE	MATERIAL				
110C	3'-0"	7'-0"	FLUSH	WOOD	F1	HOLLOW METAL		-		



DOOR DETAILS

3" = 1'-0"

TYPE A - FULL HEIGHT GWB PARTITION

TYPE	OVERALL WIDTH	FRAMING WIDTH	FIRE TEST	FIRE RATING	STC RATING	SOUND INSUL.	COMMENTS
A1	4 7/8"	3 5/8"	-	0 hr	49	Yes	CONTRACTOR TO VERIFY WALL SIZE IN FIELD AND MATCH EXISTING
A2	6"	3 5/8"	-	0 hr	49	Yes	

PARTITION TYPE

3/4" = 1'-0"

		Consultant	Architect/Engineer of Record	Stamp	Office of Construction and Facilities Management	Drawing Title	Phase	Project Title	Project Number
						BUILDING 102 - FIRST FLOOR ARCHITECTURAL PLAN	BID DOCUMENTS	STERILE STORAGE IMPROVEMENTS	595-23-104
						Approved:	Sprinkler Status	Location	Building Number
							FULLY SPRINKLERED	1700 S LINCOLN AVE, LEBANON, PA 17042	-
								Issue Date	Drawing Number
								11.17.25	A102
								Checked	8 of 110
								DC	
								Drawn	
								SB	

HVAC GENERAL NOTES

1. NOT ALL SYMBOLS ARE NECESSARILY USED.

2. COORDINATE FINAL LOCATIONS OF DIFFUSERS AND GRILLES WITH ARCHITECTURAL REFLECTED CEILING PLANS.

3. DRAWINGS ARE DIAGNOSTIC. CONTRACTOR TO FIELD VERIFY DUCT AND PIPE ROUTING AND COORDINATE INTERFERENCE BETWEEN TRADES PRIOR TO INSTALLATION.

4. ROOF OPENINGS, FLASHING, AND COUNTER FLASHING BY GENERAL CONTRACTOR. LOCATION OF OPENINGS BY HEATING CONTRACTOR.

5. DUCTWORK TO BE INSTALLED TIGHT TO UNDERSIDE OF STRUCTURE ABOVE UNLESS NOTED OTHERWISE.

6. PROVIDE ALL MATERIALS, EQUIPMENT AND PERFORM ALL LABOR REQUIRED TO INSTALL, COMPLETE AND OPERABLE MECHANICAL SYSTEMS AS INDICATED ON THE DRAWINGS, AS NOTED AND REQUIRED BY THE SPECIFICATIONS.

7. CONTRACT DOCUMENT DRAWINGS FOR MECHANICAL WORK ARE DIAGRAMMATIC AND ARE INTENDED TO CONVEY SCOPE AND GENERAL ARRANGEMENT ONLY. CONTRACTOR WILL BE RESPONSIBLE FOR FIELD VERIFYING ALL CONDITIONS AND COORDINATE ACTUAL AS NOTED AS PART OF SCOPE OF WORK AT NO COST TO OWNER.

1. STATE AND LOCAL CODES, SEISMIC REQUIREMENTS, ENERGY CODES AND INSURANCE UNDERWRITER REQUIREMENTS.

2. COORDINATE ALL WORK OF ALL MECHANICAL WORK WITH ARCHITECTURAL, STRUCTURAL, CIVIL AND ELECTRICAL WORK, ETC. SHOW ON OTHER CONTRACT DOCUMENT DRAWINGS.

3. MAINTAIN MINIMUM OF 6" FT. BAY CLEARANCE TO UNDERSIDE OF PIPES, DUCTS, CONDUITS, SUSPENDED EQUIPMENT, SUPPORTS, ETC., THROUGHOUT ACCESS ROUTES IN MECHANICAL ROOMS.

4. LOCATE ALL TEMPERATURE, PRESSURE AND FLOW MEASURING DEVICES IN ACCESSIBLE LOCATIONS WITH SECTION OF PIPE OR DUCT UPSTREAM AND DOWNSTREAM, AS RECOMMENDED BY THE MANUFACTURER FOR ACCURACY. ALL SPACE TEMPERATURE, HUMIDITY, AND VIBRATION MEASURING DEVICES TO BE INSTALLED IN ACCORDANCE WITH TESTING AGENCIES COUNCIL (ABC) TAG AGENCY MUST BE A MEMBER OF THE ASSOCIATED AIR BALANCING COUNCIL (AABC) OR THE NATIONAL ENVIRONMENTAL BALANCING BOARD (NEBB). TAG FIRM MUST HAVE A MINIMUM OF 5 YEARS EXPERIENCE ON SIMILAR PROJECTS. TAG FIRM IN ACCORDANCE WITH THE REQUIREMENTS OF AN OVERLAP THE TAB FIRM'S STANDARD RECOMMENDED BY THE TAB TRADE ASSOCIATION TO APPROVE THE TAB FIRM'S INSTALLATION.

5. WHERE TWO OR MORE ITEMS OF THE SAME TYPE ARE REQUIRED, THE PRODUCTS OF A SINGLE MANUFACTURER MUST BE USED.

6. COORDINATE ALL FINAL EQUIPMENT CONNECTIONS WITH THE MANUFACTURERS' CERTIFIED INSTALLATION, MAINTENANCE AND PIPING TRANSLATIONS REQUIRED FOR FINAL EQUIPMENT CONNECTIONS TO FURNISHED EQUIPMENT. FIELD VERIFY AND COORDINATE ALL DUCTWORK AND PIPING DIMENSIONS BEFORE FABRICATION.

7. CONTROL WIRE AND CABLE TRAYS TO BE INSTALLED IN ACCORDANCE WITH DIVISION 26 OF THE SPECIFICATIONS, ALL LOCAL CODES, AND OWNER'S INSURANCE UNDERWRITER REQUIREMENTS.

8. LOCATIONS AND SIZES OF ITEMS SHOWN ON THE DRAWINGS OR CALLED FOR IN THE SPECIFICATIONS THAT ARE DEFINITELY FIXED BY DIMENSIONS ARE APPROXIMATE ONLY. THE EXACT LOCATIONS AND SIZES NECESSARY TO SECURE THE BEST CONDITIONS AND MINIMIZE THE DETERMINED DIMENSIONS MUST BE DETERMINED BY THE ENGINEER. THE APPROVAL OF THE ENGINEER BEFORE BEING INSTALLED. DO NOT SCALE DRAWINGS.

9. PLAN DRAWINGS AND SECTIONS CUTS WHICH SPECIFICALLY IDENTIFY SERVICE ROUTE OFFSPRINGS, ELEVATION CHANGES, OBSTRUCTIONS, ACCESS DOORS, BALANCING DEVICES, ETC. PROVIDE FOR CLEAR CARRY THROUGH FOR ALL PIPING, DUCTWORK, AND PIPING RINGS WITH ALL ACCESS DOORS. ACCESS DOORS TO BE PROVIDED FOR ALL PIPING, DUCTWORK, AND PIPING RINGS AS EXCLUSION FROM CONTRACTORS SCOPE OF WORK. CONTRACTOR MUST BE RESPONSIBLE FOR ACTUAL SITE CONDITIONS AND MUST INCLUDE SUCH CONDITIONS IN SCOPE OF WORK AT CONTRACTOR'S COST TO THE OWNER.

10. ALL MISCELLANEOUS SILENT REQUIRED TO INSURE PROPER INSTALLATION AND SUPPORT OF MECHANICAL WORK AS SHOWN IN DETAILS FOR PIPING, DUCTWORK AND EQUIPMENT UNLESS OTHERWISE NOTED MUST BE FURNISHED AND INSTALLED BY THE MECHANICAL CONTRACTOR AT CONTRACTOR'S COST TO THE OWNER.

11. ALL EQUIPMENT, PIPING, DUCTWORK, ETC. MUST BE SUPPORTED AS DETAIL, SPECIFIED AND AS REQUIRED TO PROVIDE A VIBRATION FREE INSTALLATION.

12. PREVENTS IN FIRE RATING AND SHOCK RESISTANCE DUE TO DUCTWORK, PIPING, CONDUIT, ETC. MUST BE FIRE STOPPED WITH APPROVED FIRESTOPPING MATERIALS.

13. REFER TO TYPICAL DETAILS FOR DUCTWORK, PIPING AND EQUIPMENT INSTALLATION UNLESS OTHERWISE SHOWN. LOCATE ALL ROOM THERMOSTATS.

14. COORDINATE ALL WORK WITH THE MECHANICAL WORK WITH TOP AT 48" OR ABOVE FINISHED FLOOR IN ACCORDANCE WITH ADA REQUIREMENTS. NOTIFY THE ENGINEER OF ANY ROOMS WHERE THE ABOVE LOCATION CAN NOT BE MAINTAINED OR WHERE THERE IS A QUESTION ON LOCATIONS. COORDINATE FINAL LOCATIONS WITH OWNER.

15. BALANCING VALVES AND ISOLATION VALVES USED TO ADJUST FLOW RATES MUST BE PROVIDED WITH POSITIONS INDICATORS AND MAXIMUM ADJUSTABLE STOPS (MEMORY STOPS).

16. ALL ISOLATION VALVES (EXCEPT CONTROL VALVES), STRAINERS, AND PIPING SPECIALTIES MUST BE FULL LINE SIZE BEFORE REDUCING SIZE TO MAKE CONNECTIONS TO EQUIPMENT AND CONTROLS. PROVIDE ISOLATION VALVES BOTH UPSTREAM AND DOWNSTREAM. ALL CONTROL VALVES FOR SERVICE.

17. MECHANICAL JOINTS SUCH AS FLANGES, OR THREADED JOINTS MUST BE INSTALLED TO MATCH EQUIPMENT AND TO PROVIDE PROTECTION FROM PENETRATIONS, AT CONTROL DEVICES, AND IN LONG LINE PIPES (100 FEET OR MORE) TO PREVENT DISASSEMBLY FOR ALTERATION AND REPAIRS.

18. MEASURE, CUT AND INSTALL LINE LENGTH ACCURATELY TO MINIMIZE MISALIGNMENT. INSTALL ALL PIPING WITHOUT FORCING OR SPRINGING.

19. PROVIDE FLEXIBLE CONNECTIONS IN ALL PIPING SYSTEMS CONNECTED TO PUMPS AND OTHER EQUIPMENT WHICH ARE NOT SUPPOSED TO BE RIGID WATER CLOSURES. FLEXIBLE CONNECTIONS MUST BE PROVIDED AS CLOSE TO THE EQUIPMENT AS POSSIBLE OR AS INDICATED ON THE DRAWINGS.

20. PREVENT VIBRATION FROM ALL MECHANICAL EQUIPMENT TO PREVENT VIBRATION TRANSMISSION TO BUILDING STRUCTURE.

21. CONCRETE HOUSEKEEPING PADS MUST BE FURNISHED AND INSTALLED BY THE GENERAL CONTRACTOR. MECHANICAL CONTRACTOR MUST PROVIDE EQUIPMENT WEIGHTS, SIZES AND LOCATION TO GENERAL CONTRACTOR FOR CONCRETE PADS TO BE CAST IN ACCORDANCE WITH STRUCTURAL DETAILS. PAD MUST EXTEND BEYOND THE EQUIPMENT FOOTPRINT A MINIMUM OF 6" INCHES ON EACH SIDE.

22. MECHANICAL EQUIPMENT MUST BE SUPPORTED TO STRUCTURAL MEMBERS. DO NOT DISASSEMBLY. SUPPORTS MUST ATTACH TO STRUCTURAL MEMBERS. COORDINATE WITH STRUCTURAL DRAWINGS.

23. PROVIDE MANUFACTURER'S MATCHING ROOF CURBS FOR ALL ROOF MOUNTING EQUIPMENT. COORDINATE ACTUAL ROOF PITCH AND CONNECTION DETAILS WITH GENERAL CONTRACTOR. PROVIDE SLOPED CURBS PER MANUFACTURERS RECOMMENDATIONS.

24. GENERAL CONTRACTOR TO PROVIDE FLASHING AND FLASHING PER ROOFING MANUFACTURERS INSTALLATION REQUIREMENTS.

25. PROVIDE MANUAL VOLUME DAMPERS IN ALL RUN-OUTS TO DIFFUSERS, BRANCH TAKE-OFFS, AND MAIN SUPPLY TAKE-OFFS, AND IN ALL OTHER AREAS REQUIRED TO PROVIDE PROPER SYSTEM AIRFLOW BALANCING.

26. PROVIDE CHAINHOLE OPERATORS FOR ALL EXPOSED VALVES MOUNTED GREATER THAN 7' ABOVE FINISHED FLOOR LEVEL. CHAIN MUST EXTEND UNOBSTRUCTED TO 0.75" ABOVE FLOOR LEVEL.

27. ALL PIPING AND DUCTWORK MUST CLEAR DOORS, WINDOWS, EQUIPMENT CLEARANCES, MAINTENANCE REQUIREMENTS, CODE SETBACKS, ETC. TO ASSURE PROPER OPERATION, ACCESS AND MAINTENANCE.

28. ALL VALVES MUST BE ADJUSTED FOR SMOOTH AND EASY OPERATION.

29. PROVIDE ALL 90 DEGREE SQUARE ELBOWS WITH DOUBLE RADII TURNING VIEWS UNLESS OTHERWISE INDICATED OR SPECIFIED. PROVIDE ACCESS DOORS UPSTREAM OF ALL ELBOWS CONTAINING TURNING VIEWS.

30. ALL DUCTS MUST BE BONDED ACROSS FLEXIBLE CONNECTIONS WITH FLEXIBLE COPPER OR ALUMINUM BONDING STRAPS MUST BE BOLTED OR SOLDERED TO BOTH THE EQUIPMENT AND THE DUCT.

31. EQUIPMENT SUBMITTALS & SHOP DRAWINGS REQUIRED BY THE SPECIFICATIONS MUST BE APPROVED BY THE ENGINEER PRIOR TO PURCHASE, FABRICATION AND INSTALLATION.

32. ALLATING DEVICES MUST BE PROTECTED BY THE MECHANICAL CONTRACTOR. IF ACCESS OR COME IN CONTACT WITH OWNER PERSONNEL MUST BE PROTECTED, INSULATED, OR CONTROLLED TO REMAIN BELOW 120" F.

33. DISCONNECTS MUST BE PROVIDED BY THE MECHANICAL CONTRACTOR AND INSTALLED BY THE ELECTRICAL CONTRACTOR.

The diagram illustrates six types of fire dampers, each with a unique symbol and a letter code:

- FIRE DAMPER (F):** Represented by a triangle pointing right with a vertical line through its center.
- SMOKE DAMPER (S):** Represented by a triangle pointing right with a vertical line through its center and a horizontal line across the middle.
- MOTORIZED DAMPER (M):** Represented by a triangle pointing right with a vertical line through its center and a horizontal line across the middle, with a small circle at the bottom.
- MANUAL BALANCING DAMPER (B):** Represented by a triangle pointing left with a vertical line through its center.
- BACKDRAFT DAMPER (D):** Represented by a triangle pointing left with a vertical line through its center and a horizontal line across the middle.
- COMBINATION FIRE/SMOKE (C):** Represented by a triangle pointing left with a vertical line through its center and a horizontal line across the middle, with a small circle at the bottom.

Autodesk Docs: \VLEB-016 Sterile Storage Improvements\VLEB-016-MEP 24.M

Architect/Engineer of Record



AE WORKS.

AE Works, LTD.
418 Beaver Street
Sewickley, PA 15143
Phone: 412-287-7333
www.ae-works.com

OFFICE OF
CONSTRUCTION
AND FACILITIES
MANAGEMENT

VA | U.S. Department
of Veterans Affairs

Phase BID DOCUMENTS
Sprinkler Status FULLY SPRINKLERED

Project Number
VLEB-016


Building Number

Drawing Number
M-001




1 EXISTING UNIT TO REMAIN. INSPECT UNIT FOR CORRECT OPERATION, CLEAN COILS, REPLACE FILTERS, AND SERVICE ALL NECESSARY COMPONENTS.


- 1 EXISTING UNIT TO REMAIN. INSPECT UNIT FOR CORRECT OPERATION, CLEAN COILS, REPLACE FILTERS, AND SERVICE ALL NECESSARY COMPONENTS.



**Bldg 01-01 FIRST FLOOR HVAC
DEMOLITION PLAN - ROOM 116A**



**Bldg 01-01 FIRST FLOOR HVAC
DEMOLITION PLAN - ROOM 111**



1 Bldg 01-01 FIRST FLOOR HVAC DEMOLITION PLAN
1/16" = 1'-0"

[illegible]

2

3

4



1

HVAC GENERAL DEMOLITION NOTES

- 1 REFER TO FACILITY'S INFECTION CONTROL AND RISK ASSESSMENT (ICRA) AND SPECIFICATION SECTION 01 35 26 (SAFETY REQUIREMENTS) FOR ADDITIONAL INFORMATION.
- 2 ALL WORK MUST BE SCHEDULED AND COORDINATED JOINTLY WITH THE VA. A DETAILED JOB TIMELINE MUST BE ESTABLISHED AND SUBMITTED FOR REVIEW AND APPROVAL.
- 3 HVAC EQUIPMENT, DIFFUSERS, DUCTS, PIPING, & PENETRATIONS THROUGH CEILINGS, PARTITIONS AND GLASS ARE SHOWN IN THEIR APPROXIMATE LOCATIONS. FIELD-VERRY EXACT LOCATIONS AND COORDINATE FINAL LOCATIONS WITH NEW WORK PLANS.
- 4 FOR EXISTING CONDITIONS TO REMAIN, PROVIDE UL LISTED ASSEMBLIES CORRESPONDING TO WALL AND FLOOR RATINGS FOR ALL HVAC & PIPING PENETRATIONS THROUGH RATED PARTITIONS WHERE MISSING OR DAMAGED. SEAL ALL HVAC & PIPING PENETRATIONS THROUGH NON-RATED FULL HEIGHT PARTITIONS WITH ACOUSTICAL SEALANT, TYPICAL BOTH SIDES OF PARTITION, WHERE MISSING OR DAMAGED.
- 5 REFER TO ARCHITECTURAL SHEETS FOR ADDITIONAL REQUIREMENTS.
- 6 CAP, SEAL, AND INSULATE ALL UNUSED DUCT OPENINGS AND OPEN-END DUCTS RESULTING FROM DEMOLITION WORK AND DISCONNECTED DUCTWORK.
- 7 CONTRACTOR RESPONSIBLE TO REMOVE EXISTING CEILING, REUSE AND REINSTALL TO GREATEST EXTENT POSSIBLE FOR PLAY IN CEILINGS. GYP CEILINGS TO BE CUT AND PATCHED TO MATCH EXISTING. ALL SYSTEMS IN EXISTING CEILING TO REMAIN IN WORKING ORDER. ALL SPRINKLERS AND FIRE ALARMS IN AREA OF WORK TO REMAIN ACTIVE AT ALL TIMES.


KEYNOTES

- 1 DISCONNECT AND REMOVE EXISTING AIR DEVICE AND ASSOCIATED DUCTWORK, DAMPERS, HANGERS, BRACKETS AND ACCESSORIES TO THE EXTENT SHOWN. CAP AND SEAL RESULTING OPEN-ENDED DUCTWORK TO REMAIN.
- 2 RELOCATE EXISTING THERMOSTAT PER NEW WORK PLANS.
- 3 EXISTING UNIT TO REMAIN. INSPECT UNIT FOR CORRECT OPERATION, CLEAN COILS, REPLACE FILTERS, AND SERVICE ALL NECESSARY COMPONENTS.
- 4 DISCONNECT AND REMOVE EXHAUST WALL GRILLE. CAP AND SEAL REMAINING DUCT IN CHASE.
- 5 EXISTING HYDRONIC REHEAT COIL TO REMAIN. INSPECT FOR CORRECT OPERATION, CLEAN COIL, AND SERVICE ALL NECESSARY COMPONENTS.
- 6 DISCONNECT AND REMOVE EXISTING FAN COIL UNIT, AND CAP AND PREPARE REMAINING PIPING, DUCTWORK AND ACCESSORIES TO CONNECT TO NEW REPLACEMENT FAN COIL UNIT.




2 Bldg 01-03 THIRD FLOOR HVAC DEMOLITION PLAN - ROOM 307
1/4" = 1'-0"

3 Bldg 01-03 THIRD FLOOR HVAC DEMOLITION PLAN - ROOM 346 & 346A
1/4" = 1'-0"



4 Bldg 01-03 THIRD FLOOR HVAC DEMOLITION PLAN - ROOM 370
1/4" = 1'-0"



1 Bldg 01-03 THIRD FLOOR HVAC DEMOLITION PLAN
1/16" = 1'-0"

2/23/2024 11:29:36 AM
Autodesk Docs\\VLEB-016 Sterile Storage Improvements\\VLEB-016-MEP_24.rvt


		Consultant	Architect/Engineer of Record	Stamp	OFFICE OF CONSTRUCTION AND FACILITIES MANAGEMENT VA U.S. Department of Veterans Affairs	Drawing Title BUILDING 1 - THIRD FLOOR HVAC DEMOLITION PLAN Approved:	Phase BID DOCUMENTS Sprinkler Status FULLY SPRINKLERED	Project Title STERILE STORAGE IMPROVEMENTS Location 1700 S LINCOLN AVE, LEBANON, PA 17042 Issue Date 11.17.25	Project Number VLEB-016 Building Number	Drawing Number 001-MD-103
#	Revisions									
								Checked TS	Drawn AC	

1	2	3	4	5	6	7	8	9	10
---	---	---	---	---	---	---	---	---	----

- ## KEYNOTES
1. EXISTING UNIT TO REMAIN. INSPECT UNIT FOR CORRECT OPERATION, CLEAN COILS, REPLACE FILTERS, AND SERVICE ALL NECESSARY COMPONENTS.
 2. DISCONNECT AND REMOVE EXISTING FAN COIL UNIT, AND CAP AND PREPARE REMAINING PIPING, DUCTWORK AND ACCESSORIES TO CONNECT TO NEW REPLACEMENT FAN COIL UNIT.
 3. DISCONNECT AND REMOVE EXISTING AIR DEVICE AND ASSOCIATED DUCTWORK, DAMPERS, HANGERS, BRACKETS AND ACCESSORIES TO THE EXTENT SHOWN.



- 1 DISCONNECT AND REMOVE EXISTING AIR DEVICE AND ASSOCIATED DUCTWORK, DAMPERS, HANGERS, BRACKETS AND ACCESSORIES TO THE EXTENT SHOWN.
- 2 DISCONNECT AND REMOVE EXISTING FAN COIL UNIT, AND PREPARE REMAINING PIPING, DUCTWORK AND ACCESSORIES TO CONNECT TO NEW REPLACEMENT FAN COIL UNIT.

[illegible]

A

B

C

D

E

F

2/23/2024 11:30:04 AM

Autodesk Docs\\VLEB-016 Sterile Storage Improvements\\VLEB-016-MEP_24.rvt

A

B

C

D

E


F

HVAC GENERAL DEMOLITION NOTES

- 1
- REFER TO FACILITY'S INFECTION CONTROL AND RISK ASSESSMENT (ICRA) AND SPECIFICATION SECTION 01 35 26 (SAFETY REQUIREMENTS) FOR ADDITIONAL INFORMATION.
- 2
- ALL WORK MUST BE SCHEDULED AND COORDINATED JOINTLY WITH THE VA. A DETAILED JOB TIMELINE MUST BE ESTABLISHED AND SUBMITTED FOR REVIEW AND APPROVAL.
- 3
- HVAC EQUIPMENT, DIFFUSERS, DUCTS, PIPING, & PENETRATIONS THROUGH CEILINGS, PARTITIONS AND SLABS ARE SHOWN IN THEIR APPROXIMATE LOCATIONS. FIELD-VERIFY EXACT LOCATIONS AND COORDINATE FINAL LOCATIONS WITH NEW WORK PLANS.
- 4
- FOR EXISTING CONDITIONS TO REMAIN, PROVIDE UL LISTED ASSEMBLIES CORRESPONDING TO WALL AND FLOOR RATINGS FOR ALL HVAC & PIPING PENETRATIONS THROUGH RATED PARTITIONS WHERE MISSING OR DAMAGED. SEAL ALL HVAC & PIPING PENETRATIONS THROUGH NON-RATED FULL HEIGHT PARTITIONS WITH ACOUSTICAL SEALANT, TYPICAL BOTH SIDES OF PARTITION, WHERE MISSING OR DAMAGED.
- 5
- REFER TO ARCHITECTURAL SHEETS FOR ADDITIONAL REQUIREMENTS.
- 6
- CAP, SEAL, AND INSULATE ALL UNUSED DUCT OPENINGS AND OPEN-END DUCTS RESULTING FROM DEMOLITION WORK AND DISCONNECTED DUCTWORK.
- 7
- CONTRACTOR RESPONSIBLE TO REMOVE EXISTING CEILING, REUSE AND REINSTALL TO GREATEST EXTENT POSSIBLE FOR LAY IN CEILINGS. GYP CEILINGS TO BE CUT AND PATCHED TO MATCH EXISTING. ALL SYSTEMS IN EXISTING CEILING TO REMAIN IN WORKING ORDER, ALL SPRINKLERS AND FIRE ALARMS IN AREA OF WORK TO REMAIN ACTIVE AT ALL TIMES.

KEYNOTES


- 1
- DISCONNECT AND REMOVE EXISTING DUCTLESS SPLIT SYSTEM INDOOR AND OUTDOOR UNITS, AND ASSOCIATED REFRIGERANT PIPING, WIRING, HANGERS, BRACKETS, AND ACCESSORIES.




1

Bldg 04-01 FIRST FLOOR HVAC DEMOLITION PLAN - ROOM 105

1/4" = 1'-0"



--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--




1 EXISTING UNIT TO REMAIN. INSPECT UNIT FOR CORRECT OPERATION, CLEAN
COILS, REPLACE FILTERS, AND SERVICE ALL NECESSARY COMPONENTS.
2 ASSOCIATED THERMOSTAT TO BE RELOCATED - SEE NEW WORK DRAWING.
3 CONFIRM THAT CONNECTED DUCTWORK AND DIFFUSERS MATCH DRAWINGS.
NOTIFY ARCHITECT OF ANY DISCREPANCIES.

HVAC GENERAL DEMOLITION NOTES

- 1 REFER TO FACILITY'S INFECTION CONTROL AND RISK ASSESSMENT (ICRA) AND SPECIFICATION SECTION 01 35 26 (SAFETY REQUIREMENTS) FOR ADDITIONAL INFORMATION.
- 2 ALL WORK MUST BE SCHEDULED AND COORDINATED JOINTLY WITH THE VA. A DETAILED JOB TIMELINE MUST BE ESTABLISHED AND SUBMITTED FOR REVIEW AND APPROVAL.
- 3 HVAC EQUIPMENT, DIFFUSERS, DUCTS, PIPING, & PENETRATIONS THROUGH CEILINGS, PARTITIONS AND SLABS ARE SHOWN IN THEIR APPROXIMATE LOCATIONS. FIELD-VERIFY EXACT LOCATIONS AND COORDINATE FINAL LOCATIONS WITH NEW WORK PLANS.
- 4 FOR EXISTING CONDITIONS TO REMAIN, PROVIDE UL LISTED ASSEMBLIES CORRESPONDING TO WALL AND FLOOR RATINGS FOR ALL HVAC & PIPING PENETRATIONS THROUGH RATED PARTITIONS WHERE MISSING OR DAMAGED. SEAL ALL HVAC & PIPING PENETRATIONS THROUGH NON-RATED FULL HEIGHT PARTITIONS WITH ACOUSTICAL SEALANT, TYPICAL BOTH SIDES OF PARTITION, WHERE MISSING OR DAMAGED.
- 5 REFER TO ARCHITECTURAL SHEETS FOR ADDITIONAL REQUIREMENTS.
- 6 CAP, SEAL, AND INSULATE ALL UNUSED DUCT OPENINGS AND OPEN-END DUCTS RESULTING FROM DEMOLITION WORK AND DISCONNECTED DUCTWORK.
- 7 CONTRACTOR RESPONSIBLE TO REMOVE EXISTING CEILING, REUSE AND REINSTALL TO GREATEST EXTENT POSSIBLE FOR LAY IN CEILINGS. GYP CEILINGS TO BE CUT AND PATCHED TO MATCH EXISTING. ALL SYSTEMS IN EXISTING CEILING TO REMAIN IN WORKING ORDER. ALL SPRINKLERS AND FIRE ALARMS IN AREA OF WORK TO REMAIN ACTIVE AT ALL TIMES.


KEYNOTES

- 1 EXISTING UNIT TO REMAIN. INSPECT UNIT FOR CORRECT OPERATION. CLEAN COILS, REPLACE FILTERS, AND SERVICE ALL NECESSARY COMPONENTS.
- 2 RELOCATE EXISTING THERMOSTAT PER NEW WORK PLANS.
- 3 CONFIRM THAT CONNECTED DUCTWORK AND DIFFUSERS MATCH DRAWINGS. NOTIFY ARCHITECT OF ANY DISCREPANCIES.




BID DEDUCT 1 - Bldg
17-02-SECOND FLOOR HVAC
DEMOLITION PLAN - ROOM 209

2
1/4" = 1'-0"



BID DEDUCT 1 - Bldg
17-02-SECOND FLOOR HVAC
DEMOLITION PLAN - ROOM 264



3
1/4" = 1'-0"



1 BID DEDUCT 1 - Bldg 17-02-SECOND FLOOR HVAC DEMOLITION PLAN

1/16" = 1'-0"

		Consultant	Architect/Engineer of Record		Stamp	Drawing Title	Phase	Project Title		Project Number	
						BUILDING 17 - SECOND FLOOR HVAC DEMOLITION PLAN	BID DOCUMENTS	STERILE STORAGE IMPROVEMENTS		VLEB-016	
						Approved:	Sprinkler Status	Location		Building Number	
							FULLY SPRINKLERED	1700 S LINCOLN AVE, LEBANON, PA 17042			
								Issue Date	Checked	Drawn	Drawing Number
								11.17.25	TS	AC	017-MD-102



- 1 DISCONNECT AND REMOVE EXISTING AIR DEVICE AND ASSOCIATED DUCTWORK, DAMPERS, HANGERS, BRACKETS AND ACCESSORIES TO THE EXTENT SHOWN. CAP AND SEAL RESULTING OPEN-ENDED DUCTWORK TO REMAIN.
- 2 CONFIRM EXISTING DUCT AND DIFFUSER ARE MINIMUM 6" DIAMETER. IF SMALLER, REMOVE AND REPLACE WITH NEW 6" SUPPLY DUCT AND DIFFUSER.
- 3 EXISTING UNIT TO REMAIN. INSPECT UNIT FOR CORRECT OPERATION, CLEAN COILS, REPLACE FILTERS, AND SERVICE ALL NECESSARY COMPONENTS.
- 4 DISCONNECT AND REMOVE EXISTING AIR DEVICE AND ASSOCIATED DUCTWORK, DAMPERS, HANGERS, BRACKETS AND ACCESSORIES TO THE EXTENT SHOWN. CAP AND SEAL RESULTING OPEN-ENDED DUCTWORK TO REMAIN.


VA FORM 08-6231									
1	2	3	4	5	6	7	8	9	10

HVAC GENERAL DEMOLITION NOTES

- 1 REFER TO FACILITY'S INFECTION CONTROL AND RISK ASSESSMENT (ICRA) AND SPECIFICATION SECTION 01 35 26 (SAFETY REQUIREMENTS) FOR ADDITIONAL INFORMATION.
- 2 ALL WORK MUST BE SCHEDULED AND COORDINATED JOINTLY WITH THE VA. A DETAILED JOB TIMELINE MUST BE ESTABLISHED AND SUBMITTED FOR REVIEW AND APPROVAL.
- 3 HVAC EQUIPMENT, DIFFUSERS, DUCTS, PIPING, & PENETRATIONS THROUGH CEILINGS, PARTITIONS AND SLABS ARE SHOWN IN THEIR APPROXIMATE LOCATIONS. FIELD-VERIFY EXACT LOCATIONS AND COORDINATE FINAL LOCATIONS WITH NEW WORK PLANS.
- 4 FOR EXISTING CONDITIONS TO REMAIN, PROVIDE UL LISTED ASSEMBLIES CORRESPONDING TO WALL AND FLOOR RATINGS FOR ALL HVAC & PIPING PENETRATIONS THROUGH RATED PARTITIONS WHERE MISSING OR DAMAGED. SEAL ALL HVAC & PIPING PENETRATIONS THROUGH NON-RATED FULL HEIGHT PARTITIONS WITH ACOUSTICAL SEALANT, TYPICAL BOTH SIDES OF PARTITION, WHERE MISSING OR DAMAGED.
- 5 REFER TO ARCHITECTURAL SHEETS FOR ADDITIONAL REQUIREMENTS.
- 6 CAP, SEAL, AND INSULATE ALL UNUSED DUCT OPENINGS AND OPEN-END DUCTS RESULTING FROM DEMOLITION WORK AND DISCONNECTED DUCTWORK.
- 7 CONTRACTOR RESPONSIBLE TO REMOVE EXISTING CEILING, REUSE AND REINSTALL TO GREATEST EXTENT POSSIBLE FOR LAY IN CEILINGS. GYP CEILINGS TO BE CUT AND PATCHED TO MATCH EXISTING. ALL SYSTEMS IN EXISTING CEILING TO REMAIN IN WORKING ORDER. ALL SPRINKLERS AND FIRE ALARMS IN AREA OF WORK TO REMAIN ACTIVE AT ALL TIMES.


KEYNOTES

- 1 DISCONNECT AND REMOVE EXISTING AIR DEVICE AND ASSOCIATED DUCTWORK, DAMPERS, HANGERS, BRACKETS AND ACCESSORIES TO THE EXTENT SHOWN. CAP AND SEAL RESULTING OPEN-ENDED DUCTWORK TO REMAIN.
- 2 DISCONNECT AND REMOVE EXISTING FAN COIL UNIT, AND CAP AND PREPARE REMAINING PIPING, DUCTWORK AND ACCESSORIES TO CONNECT TO NEW REPLACEMENT FAN COIL UNIT.




BID DEDUCT 1 - Bldg 17-04 FOURTH FLOOR HVAC DEMOLITION PLAN - ROOM 460

1/4" = 1'-0"




BID DEDUCT 1 - Bldg 17-04 FOURTH FLOOR HVAC DEMOLITION PLAN - ROOM 426

1/4" = 1'-0"



BID DEDUCT 1 - Bldg 17-04 FOURTH FLOOR HVAC DEMOLITION PLAN - ROOM 472

1/4" = 1'-0"



BID DEDUCT 1 - Bldg 17-04 FOURTH FLOOR HVAC PLAN DEMOLITION PLAN

1/16" = 1'-0"









1 BID DEDUCT #1 03/02/2026		Consultant		Architect/Engineer of Record		Stamp		Drawing Title		Phase		Project Title		Project Number	
# Revisions		Date		AE WORKS		ANDREJ CERNI		BUILDING 17 - FOURTH FLOOR HVAC DEMOLITION PLAN		BID DOCUMENTS		STERILE STORAGE IMPROVEMENTS		VLEB-016	
				418 Beaver Street		11-17-25		OFFICE OF CONSTRUCTION AND FACILITIES MANAGEMENT		FULLY SPRINKLERED		1700 S LINCOLN AVE, LEBANON, PA 17042		Building Number	
				Sewickley, PA 15143		PROFESSIONAL ENGINEER		U.S. Department of Veterans Affairs				Issue Date		Drawing Number	
				www.ae-works.com								11.17.25		017-MD-104	
												Checked		Drawn	
												TS		AC	

A
B
C
D
E
F

2/23/2024 11:30:23 AM
Autosaved Docs\\VLEB-016 Sterile Storage Improvements\\VLEB-016-MEP_24.rvt


- HVAC GENERAL DEMOLITION NOTES**
- 1 REFER TO FACILITY'S INFECTION CONTROL AND RISK ASSESSMENT (ICRA) AND SPECIFICATION SECTION 01 35 26 (SAFETY REQUIREMENTS) FOR ADDITIONAL INFORMATION.
 - 2 ALL WORK MUST BE SCHEDULED AND COORDINATED JOINTLY WITH THE VA. A DETAILED JOB TIMELINE MUST BE ESTABLISHED AND SUBMITTED FOR REVIEW AND APPROVAL.
 - 3 HVAC EQUIPMENT, DIFFUSERS, DUCTS, PIPING, & PENETRATIONS THROUGH CEILINGS, PARTITIONS AND SLABS ARE SHOWN IN THEIR APPROXIMATE LOCATIONS. FIELD-VERIFY EXACT LOCATIONS AND COORDINATE FINAL LOCATIONS WITH NEW WORK PLANS.
 - 4 FOR EXISTING CONDITIONS TO REMAIN, PROVIDE UL LISTED ASSEMBLIES CORRESPONDING TO WALL AND FLOOR RATINGS FOR ALL HVAC & PIPING PENETRATIONS THROUGH RATED PARTITIONS WHERE MISSING OR DAMAGED. SEAL ALL HVAC & PIPING PENETRATIONS THROUGH NON-RATED FULL HEIGHT PARTITIONS WITH ACOUSTICAL SEALANT, TYPICAL BOTH SIDES OF PARTITION, WHERE MISSING OR DAMAGED.
 - 5 REFER TO ARCHITECTURAL SHEETS FOR ADDITIONAL REQUIREMENTS.
 - 6 CAP, SEAL, AND INSULATE ALL UNUSED DUCT OPENINGS AND OPEN-END DUCTS RESULTING FROM DEMOLITION WORK AND DISCONNECTED DUCTWORK.
 - 7 CONTRACTOR RESPONSIBLE TO REMOVE EXISTING CEILING, REUSE AND REINSTALL TO GREATEST EXTENT POSSIBLE FOR LAY IN CEILINGS. GYP CEILINGS TO BE CUT AND PATCHED TO MATCH EXISTING. ALL SYSTEMS IN EXISTING CEILING TO REMAIN IN WORKING ORDER. ALL SPRINKLERS AND FIRE ALARMS IN AREA OF WORK TO REMAIN ACTIVE AT ALL TIMES.

- # KEYNOTES**
- 1 DISCONNECT AND REMOVE EXISTING FAN COIL UNIT, AND CAP AND PREPARE REMAINING PIPING, DUCTWORK AND ACCESSORIES TO CONNECT TO NEW REPLACEMENT FAN COIL UNIT.
 - 2 EXISTING UNIT TO REMAIN. INSPECT UNIT FOR CORRECT OPERATION, CLEAN COILS, REPLACE FILTERS, AND SERVICE ALL NECESSARY COMPONENTS.



		Consultant	Architect/Engineer of Record	Stamp	OFFICE OF CONSTRUCTION AND FACILITIES MANAGEMENT	Drawing Title BUILDING 17 - FIFTH FLOOR HVAC DEMOLITION PLAN	Phase BID DOCUMENTS	Project Title STERILE STORAGE IMPROVEMENTS	Project Number VLEB-016
									Building Number
						Approved:	Sprinkler Status FULLY SPRINKLERED	Location 1700 S LINCOLN AVE, LEBANON, PA 17042	Drawing Number
									017-MD-105
1	BID DEDUCT #1	03/02/2026							
#	Revisions	Date						Issue Date 11.17.25	Checked TS
								Drawn AC	

1 EXISTING UNIT TO REMAIN. INSPECT UNIT FOR CORRECT OPERATION, CLEAN COILS, REPLACE FILTERS, AND SERVICE ALL NECESSARY COMPONENTS.


$$1/16'' = 1'-0''$$

A

B

C

D

E

F

2/23/2024 11:30:31 AM


Autodesk Docs\\VLEB-016 Sterile Storage Improvements\\VLEB-016-MEP_24.rvt

HVAC GENERAL DEMOLITION NOTES

- 1 REFER TO FACILITY'S INFECTION CONTROL AND RISK ASSESSMENT (ICRA) AND SPECIFICATION SECTION 01 35 26 (SAFETY REQUIREMENTS) FOR ADDITIONAL INFORMATION.
- 2 ALL WORK MUST BE SCHEDULED AND COORDINATED JOINTLY WITH THE VA. A DETAILED JOB TIMELINE MUST BE ESTABLISHED AND SUBMITTED FOR REVIEW AND APPROVAL.
- 3 HVAC EQUIPMENT, DIFFUSERS, DUCTS, PIPING, & PENETRATIONS THROUGH CEILINGS, PARTITIONS AND SLABS ARE SHOWN IN THEIR APPROXIMATE LOCATIONS. FIELD-VERIFY EXACT LOCATIONS AND COORDINATE FINAL LOCATIONS WITH NEW WORK PLANS.
- 4 FOR EXISTING CONDITIONS TO REMAIN, PROVIDE UL LISTED ASSEMBLIES CORRESPONDING TO WALL AND FLOOR RATINGS FOR ALL HVAC & PIPING PENETRATIONS THROUGH RATED PARTITIONS WHERE MISSING OR DAMAGED. SEAL ALL HVAC & PIPING PENETRATIONS THROUGH NON-RATED FULL HEIGHT PARTITIONS WITH ACOUSTICAL SEALANT, TYPICAL BOTH SIDES OF PARTITION, WHERE MISSING OR DAMAGED.
- 5 REFER TO ARCHITECTURAL SHEETS FOR ADDITIONAL REQUIREMENTS.
- 6 CAP, SEAL AND INSULATE ALL UNUSED DUCT OPENINGS AND OPEN-END DUCTS RESULTING FROM DEMOLITION WORK AND DISCONNECTED DUCTWORK.
- 7 CONTRACTOR RESPONSIBLE TO REMOVE EXISTING CEILING, REUSE AND REINSTALL TO GREATEST EXTENT POSSIBLE FOR LAY IN CEILINGS. GYP CEILINGS TO BE CUT AND PATCHED TO MATCH EXISTING. ALL SYSTEMS IN EXISTING CEILING TO REMAIN IN WORKING ORDER, ALL SPRINKLERS AND FIRE ALARMS IN AREA OF WORK TO REMAIN ACTIVE AT ALL TIMES.

KEYNOTES

- 1 EXISTING UNIT TO REMAIN, INSPECT UNIT FOR CORRECT OPERATION, CLEAN COILS, REPLACE FILTERS, AND SERVICE ALL NECESSARY COMPONENTS.




Bldg 18-05 FIFTH FLOOR HVAC
DEMOLITION PLAN - ROOM 517A

2
1/4" = 1'-0"



Bldg 18-05 FIFTH FLOOR HVAC DEMOLITION PLAN

1
1/16" = 1'-0"




																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																					</
--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----

HVAC GENERAL DEMOLITION NOTES

- 1 REFER TO FACILITY'S INFECTION CONTROL AND RISK ASSESSMENT (ICRA) AND SPECIFICATION SECTION 01 35 26 (SAFETY REQUIREMENTS) FOR ADDITIONAL INFORMATION.
- 2 ALL WORK MUST BE SCHEDULED AND COORDINATED JOINTLY WITH THE VA. A DETAILED JOB TIMELINE MUST BE ESTABLISHED AND SUBMITTED FOR REVIEW AND APPROVAL.
- 3 HVAC EQUIPMENT, DIFFUSERS, DUCTS, PIPING, & PENETRATIONS THROUGH CEILINGS, PARTITIONS AND SLABS ARE SHOWN IN THEIR APPROXIMATE LOCATIONS. FIELD-VERIFY EXACT LOCATIONS AND COORDINATE FINAL LOCATIONS WITH NEW WORK PLANS.
- 4 FOR EXISTING CONDITIONS TO REMAIN, PROVIDE UL LISTED ASSEMBLIES CORRESPONDING TO WALL AND FLOOR RATINGS FOR ALL HVAC & PIPING PENETRATIONS THROUGH RATED PARTITIONS WHERE MISSING OR DAMAGED. SEAL ALL HVAC & PIPING PENETRATIONS THROUGH NON-RATED FULL HEIGHT PARTITIONS WITH ACOUSTICAL SEALANT, TYPICAL BOTH SIDES OF PARTITION, WHERE MISSING OR DAMAGED.
- 5 REFER TO ARCHITECTURAL SHEETS FOR ADDITIONAL REQUIREMENTS.
- 6 CAP, SEAL, AND INSULATE ALL UNUSED DUCT OPENINGS AND OPEN END DUCTS RESULTING FROM DEMOLITION WORK AND DISCONNECTED DUCTWORK.
- 7 CONTRACTOR RESPONSIBLE TO REMOVE EXISTING CEILING, REUSE AND REINSTALL TO GREATEST EXTENT POSSIBLE FOR LAY IN CEILINGS. GYP CEILINGS TO BE CUT AND PATCHED TO MATCH EXISTING. ALL SYSTEMS IN EXISTING CEILING TO REMAIN IN WORKING ORDER. ALL SPRINKLERS AND FIRE ALARMS IN AREA OF WORK TO REMAIN ACTIVE AT ALL TIMES.

KEYNOTES

- 1 EXISTING UNIT TO REMAIN. INSPECT UNIT FOR CORRECT OPERATION, CLEAN COILS, REPLACE FILTERS, AND SERVICE ALL NECESSARY COMPONENTS.
- 2 SUPPLY AND INSTALL 6 MIL HEAVY DUTY, REINFORCED, FIRE-RETARDANT POLY SHEETING (VISQUEEN), PLASTIC SHEET SHALL BE FULLY SEALED AT PERIMETER. PROVIDE ZIPPER OPENING FOR AREAS AFFECTED BY WORK. PROVIDE STORY MATS AT ENTRANCE TO THE ROOM.




1

Bldg 22-01-FIRST FLOOR HVAC DEMOLITION PLAN - ROOM 109

1/8" = 1'-0"

																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																					</
--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----



**Bldg 22-02-SECOND FLOOR HVAC
DEMOLITION PLAN - ROOM 216**


1/4" = 1'-0"

HVAC GENERAL DEMOLITION NOTES

- 1 REFER TO FACILITY'S INFECTION CONTROL AND RISK ASSESSMENT (ICRA) AND SPECIFICATION SECTION 01 35 26 (SAFETY REQUIREMENTS) FOR ADDITIONAL INFORMATION.
- 2 ALL WORK MUST BE SCHEDULED AND COORDINATED JOINTLY WITH THE VA. A DETAILED JOB TIMELINE MUST BE ESTABLISHED AND SUBMITTED FOR REVIEW AND APPROVAL.
- 3 HVAC EQUIPMENT, DIFFUSERS, DUCTS, PIPING, & PENETRATIONS THROUGH CEILINGS, PARTITIONS AND SLABS ARE SHOWN IN THEIR APPROXIMATE LOCATIONS. FIELD-VERIFY EXACT LOCATIONS AND COORDINATE FINAL LOCATIONS WITH NEW WORK PLANS.
- 4 FOR EXISTING CONDITIONS TO REMAIN, PROVIDE UL LISTED ASSEMBLIES CORRESPONDING TO WALL AND FLOOR RATINGS FOR ALL HVAC & PIPING PENETRATIONS THROUGH RATED PARTITIONS WHERE MISSING OR DAMAGED. SEAL ALL HVAC & PIPING PENETRATIONS THROUGH NON-RATED FULL HEIGHT PARTITIONS WITH ACOUSTICAL SEALANT, TYPICAL BOTH SIDES OF PARTITION, WHERE MISSING OR DAMAGED.
- 5 REFER TO ARCHITECTURAL SHEETS FOR ADDITIONAL REQUIREMENTS.
- 6 CAP, SEAL AND INSULATE ALL UNUSED DUCT OPENINGS AND OPEN-END DUCTS RESULTING FROM DEMOLITION WORK AND DISCONNECTED DUCTWORK.
- 7 CONTRACTOR RESPONSIBLE TO REMOVE EXISTING CEILING, REUSE AND REINSTALL TO GREATEST EXTENT POSSIBLE FOR LAY IN CEILINGS. GYP CEILINGS TO BE CUT AND PATCHED TO MATCH EXISTING. ALL SYSTEMS IN EXISTING CEILING TO REMAIN IN WORKING ORDER, ALL SPRINKLERS AND FIRE ALARMS IN AREA OF WORK TO REMAIN ACTIVE AT ALL TIMES.


KEYNOTES

- 1 EXISTING VAV TO REMAIN. INSPECT UNIT FOR CORRECT OPERATION. CLEAN COILS, AND SERVICE ALL NECESSARY COMPONENTS.
- 2 DISCONNECT AND REMOVE EXISTING AIR DEVICE AND ASSOCIATED DUCTWORK, DAMPERS, HANGERS, BRACKETS AND ACCESSORIES TO THE EXTENT SHOWN. CAP AND SEAL RESULTING OPEN-ENDED DUCTWORK TO REMAIN.



Bldg 22-02-SECOND FLOOR HVAC DEMOLITION PLAN

1/8" = 1'-0"



																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																					</
--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----

A

B


C

D

E

F


2/23/2024 11:30:42 AM
Autosave: Docs\\VLEB-016 Sterile Storage Improvements\\VLEB-016-MEP-24.rvt



**Bldg 37-01-FIRST FLOOR HVAC
DEMOLITION PLAN -ROOM 1A10**

2
1/4" = 1'-0"

2
037-MD-101



1 Bldg 37-01-FIRST FLOOR HVAC DEMOLITION PLAN
1/8" = 1'-0"

HVAC GENERAL DEMOLITION NOTES

- 1 REFER TO FACILITY'S INFECTION CONTROL AND RISK ASSESSMENT (ICRA) AND SPECIFICATION SECTION 01 35 26 (SAFETY REQUIREMENTS) FOR ADDITIONAL INFORMATION.
- 2 ALL WORK MUST BE SCHEDULED AND COORDINATED JOINTLY WITH THE VA. A DETAILED JOB TIMELINE MUST BE ESTABLISHED AND SUBMITTED FOR REVIEW AND APPROVAL.
- 3 HVAC EQUIPMENT, DIFFUSERS, DUCTS, PIPING, & PENETRATIONS THROUGH CEILINGS, PARTITIONS AND SLABS ARE SHOWN IN THEIR APPROXIMATE LOCATIONS. FIELD-VERIFY EXACT LOCATIONS AND COORDINATE FINAL LOCATIONS WITH NEW WORK PLANS.
- 4 FOR EXISTING CONDITIONS TO REMAIN, PROVIDE UL LISTED ASSEMBLIES CORRESPONDING TO WALL AND FLOOR RATINGS FOR ALL HVAC & PIPING PENETRATIONS THROUGH RATED PARTITIONS WHERE MISSING OR DAMAGED. SEAL ALL HVAC & PIPING PENETRATIONS THROUGH NON-RATED FULL HEIGHT PARTITIONS WITH ACOUSTICAL SEALANT, TYPICAL BOTH SIDES OF PARTITION, WHERE MISSING OR DAMAGED. REFER TO ARCHITECTURAL SHEETS FOR ADDITIONAL REQUIREMENTS.
- 5 CAP, SEAL, AND INSULATE ALL UNUSED DUCT OPENINGS AND OPEN-END DUCTS RESULTING FROM DEMOLITION WORK AND DISCONNECTED DUCTWORK.
- 6 CONTRACTOR RESPONSIBLE TO REMOVE EXISTING CEILING, REUSE AND REINSTALL TO GREATEST EXTENT POSSIBLE FOR LAY IN CEILINGS. GYP CEILINGS TO BE OUT AND PATCHED TO MATCH EXISTING. ALL SYSTEMS IN EXISTING CEILING TO REMAIN IN WORKING ORDER. ALL SPRINKLERS AND FIRE ALARMS IN AREA OF WORK TO REMAIN ACTIVE AT ALL TIMES.

KEYNOTES

- 1 DISCONNECT AND REMOVE EXISTING VAV BOX, AND CAP AND PREPARE REMAINING PIPING, DUCTWORK AND ACCESSORIES TO CONNECT TO NEW REPLACEMENT VAV.
- 2 DISCONNECT AND REMOVE EXISTING AIR DEVICE AND ASSOCIATED DUCTWORK, DAMPERS, HANGERS, BRACKETS AND ACCESSORIES TO THE EXTENT SHOWN. CAP AND SEAL RESULTING OPEN-ENDED DUCTWORK TO REMAIN.

A


B

C

D

E

F



																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																					</
--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----

$$1/4^* = 1'-0$$
$$1/4^* = 1'-0^*$$
$$1/4^{\circ} = 1'-0"$$

1/4" = 1'-0"

HVAC GENERAL DEMOLITION NOTES


- 1 REFER TO FACILITY'S INFECTION CONTROL AND RISK ASSESSMENT (ICRA) AND SPECIFICATION SECTION 31.05.36 (SAFE REQUIREMENTS) FOR ADDITIONAL INFORMATION.
- 2 ALL WORK MUST BE SCHEDULED AND COORDINATED JOINTLY WITH THE VA. A DETAILED JOB TIMELINE MUST BE ESTABLISHED AND SUBMITTED FOR REVIEW AND APPROVAL.
- 3 HVAC EQUIPMENT, DIFFUSERS, DUCTS, PIPING & PENETRATIONS THROUGH CEILINGS, WALLS, PARTITIONS AND SLAB JOINTS MUST BE IDENTIFIED AND MARKED WITH RED TAPE. EXISTING LOCATIONS AND COORDINATE WITH NEW WORK PLANS.
- 4 FOR EXISTING CONDITIONS TO REMAIN, PROVIDE UL LISTED ASSEMBLIES CORRESPONDING TO WALL AND FLOOR RATINGS FOR ALL HVAC & PIPING PENETRATIONS THROUGH PARTITION WALLS. PROVIDE UL LISTED ASSEMBLIES FOR HVAC & PIPING PENETRATIONS THROUGH NON-RATED FULL HEIGHT PARTITIONS WITH ACOUSTICAL SEALANT, TYPICAL BOTH SIDES OF PARTITION, WHERE MISSING OR DAMAGED.
- 5 REFER TO ARCHITECTURAL SHEETS FOR ADDITIONAL REQUIREMENTS.
- 6 CAP SECS. AND INSULATE ALL EXISTING AIR HANDLING DUCTS RESULTING FROM DEMOLITION WORK AND DISCONNECTED DUCTWORK.
- 7 CONTRACTOR RESPONSIBLE TO REMOVE EXISTING CEILING, REUSE AND REINSTALL TO GREATEST EXTENT POSSIBLE FOR LAV IN CEILING. GYP CEILINGS TO BE CEILING AND PATCHED TO MATCH EXISTING. ALL SYSTEMS IN EXISTING CEILING TO REMAIN IN WORKING ORDER. ALL SPRINKLERS AND FIRE ALARMS IN AREA OF WORK TO REMAIN ACTIVE AT ALL TIMES.

KEYNOTES

- 1 RELOCATE EXISTING THERMOSTAT TO LARGEST SPACE SERVED BY THE RESPECTIVE CONSTANT VOLUME REHEAT COIL.
- 2 DISCONNECT AND REMOVE EXISTING AIR DEVICE AND ASSOCIATED DUCTWORK, DAMPERS, HANGERS, BRACKETS AND ACCESSORIES TO THE EXTENT SHOWN. CAP AND SEAL RESULTING OPEN-ENDED DUCTWORK TO REMAIN.
- 3 EXISTING REHEAT COIL TO REMAIN. REMOVE AND REPLACE HOT WATER CONTROL VALVE. CLEAN COIL, AND SERVICE ALL NECESSARY COMPONENTS.
- 4 DISCONNECT AND REMOVE EXISTING DUCT HEATING COIL AND ASSOCIATED VALVES, CONTROLS, AND ACCESSORIES. CAP AND PREPARE REMAINING PIPING, DUCTWORK AND ACCESSORIES TO CONNECT TO NEW COIL.

1 Bldg 101-01-FIRST FLOOR HVAC DEMOLITION PLAN






[illegible]



Bldg 102-01-FIRST FLOOR HVAC DEMOLITION PLAN

1. DISCONNECT AND REMOVE EXISTING AIR DEVICE AND ASSOCIATED DUCTWORK, DAMPERS, HANGERS, BRACKETS AND ACCESSORIES TO THE EXTENT SHOWN. CAP AND SEAL RESULTING OPEN-ENDED DUCTWORK TO REMAIN.
2. DISTRIBUTE THE DEMOLISHED 200 CFM TO THE (7) EXISTING-TO-REMAIN SUPPLY DIFFUSERS. EXISTING DRAWINGS INDICATE REMAINING DIFFUSERS TO BE 200 CFM - REBALANCE TO (6x)230 CFM, (1x)220 CFM.

1) Drag $1/16'' = 1'-0''$

VA FORM 08-6231


$$1/4^{\circ} = 1'-0"$$

$$1/4^{\circ} = 1'-0"$$


1/16" = 1'-0"

KEYNOTES

- 1 EXISTING VAV TO REMAIN. INSPECT UNIT FOR CORRECT OPERATION, CLEAN COILS, AND SERVICE ALL NECESSARY COMPONENTS.
- 2 DISCONNECT AND REMOVE EXISTING AIR DEVICE AND ASSOCIATED DUCTWORK, DAMPERS, HANGERS, BRACKETS AND ACCESSORIES TO THE EXTENT SHOWN. CAP AND SEAL RESULTING OPEN-ENDED DUCTWORK TO REMAIN.

A

B

C

D

E

F

2/23/2024 11:31:08 AM

Autosave Doc:\VLEB-016 Sterile Storage Improvements\VLEB-016-MEP_24.rvt

A

B

C

D

E




F

HVAC GENERAL NOTES

- REFER TO FACILITY'S INFECTION CONTROL AND RISK ASSESSMENT (ICRA) AND SPECIFICATION SECTION 01 35 26 (SAFETY REQUIREMENTS) FOR ADDITIONAL INFORMATION.
- ALL WORK MUST BE SCHEDULED AND COORDINATED JOINTLY WITH THE OWNER. A DETAILED JOB TIMELINE MUST BE ESTABLISHED AND SUBMITTED FOR REVIEW AND APPROVAL.
- REFER TO ARCHITECTURAL FOR ADDITIONAL REQUIREMENTS.
- MAINTAIN 6-IN MINIMUM CLEARANCE FROM RATED WALLS AND HVAC EQUIPMENT.
- CONTRACTOR TO PROVIDE REMOTE OPERATORS FOR ALL MANUAL VOLUME DAMPERS LOCATED ABOVE GYPSUM BOARD CEILINGS.
- RUNOUT BRANCH DUCTWORK TO SUPPLY DIFFUSERS, RETURN AND EXHAUST GRILLES TO BE THE SAME SIZE AS THE NECK SIZE ON THE AIR DEVICE UNLESS NOTED OTHERWISE.
- ALL BRANCH DUCTS TO DIFFUSERS, REGISTERS, AND GRILLES MUST BE INSTALLED WITH A VOLUME DAMPER.
- DO NOT PLACE ANY RACKS OR SHELVES IN FRONT OF SENSORS OR HUMIDIFIERS. A MINIMUM CLEARANCE OF 2'-0" IN FRONT OF THE HUMIDIFIER WILL BE MAINTAINED AT ALL TIMES.
- THERMOSTAT SETTINGS WILL BE 68 DEG F FOR ALL STERILE STORAGE ROOMS.
- WHERE AIRFLOWS ARE SHOWN ON NEW WORK PLANS, (RE)BALANCE AIR DEVICES TO THE INDICATED AIRFLOWS.
- SPACES SERVED BY 2-PIPE COOLING-ONLY FCU HAVE EXISTING PERIMETER HEATING CONNECTORS. TEMPRAK WINTER DATA SUGGESTS THERE IS NO NEED TO REVISE EXISTING HEATING TO THE SPACE. SEE PIPING PLANS FOR CONNECTORS WORK.
- CONTRACTOR RESPONSIBLE TO REMOVE EXISTING CEILING, REUSE AND REINSTALL TO GREATEST EXTENT POSSIBLE FOR LAY IN CEILINGS. GYP CEILINGS TO BE CUT AND PATCHED TO MATCH EXISTING. ALL SYSTEMS IN EXISTING CEILING TO REMAIN IN WORKING ORDER. ALL SPRINKLERS AND FIRE ALARMS IN AREA OF WORK TO REMAIN ACTIVE AT ALL TIMES.
- REBALANCE DUCTED SYSTEMS IN SCOPE TO AIRFLOWS INDICATED ON DRAWINGS.
- TEMPRAK SENSORS ARE PART OF AN EXISTING CAMPUS-WIDE INDEPENDENT TEMPERATURE AND HUMIDITY MONITORING SYSTEM. COORDINATE NEW AND REPLACEMENT SENSORS WITH THE VA TO ENSURE COMPATIBILITY.

KEYNOTES

- EXISTING FCU, CLEAN COILS, INSPECT AND TEST UNIT TO ENSURE FULL FUNCTIONALITY.
- EXISTING WALL-MOUNTED DUCTLESS SPLIT SYSTEM. CLEAN COILS, INSPECT AND TEST UNIT TO ENSURE FUNCTIONALITY. PROVIDE NEW HARD-WIRED DIGITAL THERMOSTAT.
- REPLACE THERMOSTAT WITH NEW DIGITAL THERMOSTAT CONNECTED TO BAS.
- PROVIDE AND INSTALL NEW TEMPRAK SENSOR.
- EXISTING EQUIPMENT.
- PROVIDE AND INSTALL ROOM PRESSURE SENSOR, SETRA LITE WITH VISUAL ALARM (OR EQUAL).
- HUMIDIFIER MOUNTED AT 1'-0" BELOW THE CEILING. MOUNT THE UNIT'S HUMIDITY SENSOR ON WALL ABOVE THE TEMPRAK SENSOR, UNLESS OTHERWISE SHOWN. HUMIDIFIER SETTINGS SHALL BE 40% RH.
- EXISTING W/W. CLEAN, INSPECT AND TEST TO ENSURE FULL FUNCTIONALITY. RESET BOX CONSTANT AIRFLOW TO TOTAL CONNECTED CFM SHOWN.
- PROVIDE NEW WIRED DIGITAL THERMOSTAT FOR DUCTLESS SPLIT SYSTEM.
- EXISTING THERMOSTAT SHALL BE LOCATED HERE. RELOCATE IF NECESSARY.
- EXISTING TEMPRAK SENSOR SHALL BE LOCATED HERE. RELOCATE IF NECESSARY.
- EXISTING OA CONNECTION TO FCU. BALANCE TO 50 CFM.
- IN-LINE BAROMETRIC DAMPER, RUSKIN MODEL ZB802S OR APPROVED EQUAL. SET THE DAMPER'S COUNTER-BALANCED CLOSING WEIGHT TO RELIEVE SPACE PRESSURE WHILE STILL MAINTAINING THE REQUIRED POSITIVE PRESSURIZATION OF 0.02"-0.05" W.G.



Bldg 01-00 BASEMENT FLOOR HVAC PLAN - ROOM G036


3

1/4" = 1'-0"

Bldg 01-00 BASEMENT FLOOR HVAC PLAN - ROOM 16

2

1/4" = 1'-0"



Bldg 01-00 BASEMENT FLOOR HVAC PLAN - ROOM 51

4




1/4" = 1'-0"

Bldg 01-00 BASEMENT FLOOR HVAC PLAN

1

1/16" = 1'-0"

																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																					</
--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----



- 1 EXISTING FCU, CLEAN COILS, INSPECT AND TEST UNIT TO ENSURE FULL FUNCTIONALITY.
- 2 REPLACE THERMOSTAT WITH NEW DIGITAL THERMOSTAT CONNECTED TO BAS.
- 3 EXISTING EQUIPMENT.
- 4 PROVIDE AND INSTALL ROOM PRESSURE SENSOR, SETRA LITE WITH VISUAL ALARM (OR EQUAL).
- 5 DEHUMIDIFIER MOUNTED AT 1' 0" BELOW THE CEILING. MOUNT THE UNIT'S HUMIDITY SENSOR ON WALL ABOVE THE TEMPRATUR SENSOR, UNLESS OTHERWISE SHOWN.
- 6 DEHUMIDIFIER SETTING SHALL BE 40 %RH.
- 7 DEHUMIDIFIER MOUNTED AT 2' 0" AFF. DEHUMIDIFIER SETTING SHALL BE 50 %RH
- 8 EXISTING TEMPRATUR SENSOR SHALL BE LOCATED HERE. RELOCATE IF NECESSARY.
- 9 EXISTING OA CONNECTION TO FCU. LOCATE TO 50 CFM.

A

B

C


D

E

F


2/23/2028 11:31:15 AM

Autodesk Docs\\VLEB-016 Sterile Storage Improvements\\VLEB-016-MEP_24.rvt




**Bldg 01-02 SECOND FLOOR HVAC
PLAN - ROOM 216**

2
1/4" = 1'-0"




**Bldg 01-02 SECOND FLOOR HVAC
PLAN - ROOM 257**

3
1/4" = 1'-0"



**Bldg 01-02 SECOND FLOOR HVAC
PLAN - ROOM 293**

4
1/4" = 1'-0"



1 Bldg 01-02 SECOND FLOOR HVAC PLAN
1/16" = 1'-0"

HVAC GENERAL NOTES

- 1 REFER TO FACILITY'S INFECTION CONTROL AND RISK ASSESSMENT (ICRA) AND SPECIFICATION SECTION 01 55 26 (SAFETY REQUIREMENTS) FOR ADDITIONAL INFORMATION.
- 2 ALL WORK MUST BE SCHEDULED AND COORDINATED JOINTLY WITH THE OWNER. A DETAILED JOB TIMELINE MUST BE ESTABLISHED AND SUBMITTED FOR REVIEW AND APPROVAL.
- 3 REFER TO ARCHITECTURAL FOR ADDITIONAL REQUIREMENTS.
- 4 MAINTAIN 6-IN MINIMUM CLEARANCE FROM RATED WALLS AND HVAC EQUIPMENT.
- 5 CONTRACTOR TO PROVIDE REMOTE OPERATORS FOR ALL MANUAL VOLUME DAMPERS LOCATED ABOVE GYPSUM BOARD CEILINGS.
- 6 RUNOUT BRANCH DUCTWORK TO SUPPLY DIFFUSERS, RETURN AND EXHAUST GRILLES TO BE THE SAME SIZE AS THE NECK SIZE ON THE AIR DEVICE UNLESS NOTED OTHERWISE.
- 7 ALL BRANCH DUCTS TO DIFFUSERS, REGISTERS, AND GRILLES MUST BE INSTALLED WITH A VOLUME DAMPER.
- 8 DO NOT PLACE ANY RACKS OR SHELVES IN FRONT OF SENSORS OR HUMIDIFIERS. A MINIMUM CLEARANCE OF 2'-0" IN FRONT OF THE HUMIDIFIER WILL BE MAINTAINED AT ALL TIMES.
- 9 THERMOSTAT SETTING WILL BE 68 DEG F FOR ALL STERILE STORAGE ROOMS.
- 10 WHERE AIRFLOWS ARE SHOWN ON NEW WORK PLANS, (RE)BALANCE AIR DEVICES TO THE INDICATED AIRFLOWS.
- 11 SPACES SERVED BY 2-PIPE COOLING-ONLY FCU HAVE EXISTING PERIMETER HEATING CONVECTORS. TEMPTRAK WINTER DATA SUGGESTS THERE IS NO NEED TO REVISE EXISTING HEATING TO THE SPACE. SEE PIPING PLANS FOR CONVECTORS WORK.
- 12 CONTRACTOR RESPONSIBLE TO REMOVE EXISTING CEILING, REUSE AND REINSTALL TO GREATEST EXTENT POSSIBLE FOR LAY IN CEILINGS. GYP CEILINGS TO BE CUT AND PATCHED TO MATCH EXISTING. ALL SYSTEMS IN EXISTING CEILING TO REMAIN IN WORKING ORDER. ALL SPRINKLERS AND FIRE ALARMS IN AREA OF WORK TO REMAIN ACTIVE AT ALL TIMES.
- 13 REBALANCE DUCTED SYSTEMS IN SCOPE TO AIRFLOWS INDICATED ON DRAWINGS.
- 14 TEMPTRAK SENSORS ARE PART OF AN EXISTING CAMPUS-WIDE INDEPENDENT TEMPERATURE AND HUMIDITY MONITORING SYSTEM. COORDINATE NEW AND REPLACEMENT SENSORS WITH THE VA TO ENSURE COMPATIBILITY.

KEYNOTES

- 1 PROVIDE AND INSTALL NEW DIGITAL THERMOSTAT CONNECTED TO BAS.
- 2 HUMIDIFIER MOUNTED AT 1'-0" BELOW THE CEILING. MOUNT THE UNITS' HUMIDITY SENSOR ON WALL ABOVE THE TEMPTRAK SENSOR. UNLESS OTHERWISE SHOWN, HUMIDIFIER SETTING SHALL BE 40 %RH.
- 3 EXISTING VAV, CLEAN, INSPECT AND TEST TO ENSURE FULL FUNCTIONALITY. RESET MAXIMUM AIRFLOW TO TOTAL CONNECTED CFM SHOWN.
- 4 PROVIDE AND INSTALL ROOM PRESSURE SENSOR, SETRA LITE WITH VISUAL ALARM (OR EQUAL).
- 5 PROVIDE AND INSTALL NEW TEMPTRAK SENSOR.
- 6 EXISTING THERMOSTAT SHALL BE LOCATED HERE. RELOCATE IF NECESSARY.
- 7 CONFIRM EXISTING ROUND DUCT AND RESPECTIVE DIFFUSER NECK SIZE ARE MINIMUM 8 INCH DIAMETER. IF NOT, DISCONNECT AND REMOVE EXISTING AND PROVIDE NEW 8" DUCT AND DIFFUSER.
- 8 CONFIRM EXISTING DUCT AND RESPECTIVE GRILLE NECK SIZE ARE MINIMUM 10x6 OR EQUAL DIMENSIONS. IF NOT, DISCONNECT AND REMOVE EXISTING AND PROVIDE NEW 10x6 DUCT AND 8x6 NECK GRILLE.

A


B

C

D

E


F




																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																										</
--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----

- HVAC GENERAL NOTES**
- REFER TO FACILITY'S INFECTION CONTROL AND RISK ASSESSMENT (ICRA) AND SPECIFICATION SECTION 01 35 26 (SAFETY REQUIREMENTS) FOR ADDITIONAL INFORMATION.
 - ALL WORK MUST BE SCHEDULED AND COORDINATED JOINTLY WITH THE OWNER. A DETAILED JOB TIMELINE MUST BE ESTABLISHED AND SUBMITTED FOR REVIEW AND APPROVAL.
 - REFER TO ARCHITECTURAL FOR ADDITIONAL REQUIREMENTS.
 - MAINTAIN 6-IN MINIMUM CLEARANCE FROM RATED WALLS AND HVAC EQUIPMENT.
 - CONTRACTOR TO PROVIDE REMOTE OPERATORS FOR ALL MANUAL VOLUME DAMPERS LOCATED ABOVE GYPSUM BOARD CEILINGS.
 - RUNOUT BRANCH DUCTWORK TO SUPPLY DIFFUSERS, RETURN AND EXHAUST GRILLES TO BE THE SAME SIZE AS THE NECK SIZE ON THE AIR DEVICE UNLESS NOTED OTHERWISE.
 - ALL BRANCH DUCTS TO DIFFUSERS, REGISTERS, AND GRILLES MUST BE INSTALLED WITH A VOLUME DAMPER.
 - DO NOT PLACE ANY RACKS OR SHELVES IN FRONT OF SENSORS OR HUMIDIFIERS. A MINIMUM CLEARANCE OF 2'-0" IN FRONT OF THE HUMIDIFIER WILL BE MAINTAINED AT ALL TIMES.
 - CONTRACTOR TO PROVIDE REMOTE OPERATORS FOR ALL MANUAL VOLUME DAMPERS LOCATED ABOVE GYPSUM BOARD CEILINGS.
 - THERMOSTAT SETTING WILL BE 68 DEG F FOR ALL STERILE STORAGE ROOMS.
 - WHERE AIRFLOWS ARE SHOWN ON NEW WORK PLANS, (RE)BALANCE AIR DEVICES TO THE INDICATED AIRFLOWS.
 - SPACES SERVED BY 2-PIPE COOLING-ONLY FCU HAVE EXISTING PERIMETER HEATING CONVECTORS. TEMPRAK WINTER DATA SUGGESTS THERE IS NO NEED TO REVISE EXISTING HEATING TO THE SPACE. SEE PIPING PLANS FOR CONVECTORS WORK.
 - CONTRACTOR RESPONSIBLE TO REMOVE EXISTING CEILING, REUSE AND REINSTALL TO GREATEST EXTENT POSSIBLE FOR LAY IN CEILINGS. GYP CEILINGS TO BE CUT AND PATCHED TO MATCH EXISTING. ALL SYSTEMS IN EXISTING CEILING TO REMAIN IN WORKING ORDER. ALL SPRINKLERS AND FIRE ALARMS IN AREA OF WORK TO REMAIN ACTIVE AT ALL TIMES.
 - REBALANCE DUCTED SYSTEMS IN SCOPE TO AIRFLOWS INDICATED ON DRAWINGS.
 - TEMPTRAK SENSORS ARE PART OF AN EXISTING CAMPUS-WIDE INDEPENDENT TEMPERATURE AND HUMIDITY MONITORING SYSTEM. COORDINATE NEW AND REPLACEMENT SENSORS WITH THE VA TO ENSURE COMPATIBILITY.


- KEYNOTES**
- EXISTING TEMPRAK SENSOR SHALL BE LOCATED HERE. RELOCATE IF NECESSARY.
 - HUMIDIFIER MOUNTED AT 1'-0" BELOW THE CEILING. MOUNT THE UNIT'S HUMIDITY SENSOR ON WALL ABOVE THE TEMPRAK SENSOR, UNLESS OTHERWISE SHOWN. HUMIDIFIER SETTING SHALL BE 40 %RH.
 - PROVIDE AND INSTALL NEW DIGITAL THERMOSTAT CONNECTED TO BAS.
 - EXISTING TEMPRAK SENSOR SHALL BE LOCATED HERE. RELOCATE IF NECESSARY.
 - PROVIDE AND INSTALL ROOM PRESSURE SENSOR, SETRA LITE WITH VISUAL ALARM (OR EQUAL).
 - REPLACE THERMOSTAT WITH NEW DIGITAL THERMOSTAT CONNECTED TO BAS.
 - REPLACE TEMPRAK SENSOR WITH NEW.
 - DEHUMIDIFIER MOUNTED AT 2'-0" AFF. DEHUMIDIFIER SETTING SHALL BE 50 %RH.
 - PROVIDE AND INSTALL NEW DIGITAL THERMOSTAT CONNECTED TO BAS.
 - EXISTING FCU, CLEAN COILS, INSPECT AND TEST UNIT TO ENSURE FULL FUNCTIONALITY.
 - EXISTING THERMOSTAT SHALL BE LOCATED HERE. RELOCATE IF NECESSARY.
 - EXISTING OA CONNECTION TO FCU. BALANCE TO 80 CFM.




3 Bldg 01-03 THIRD FLOOR HVAC PLAN - ROOM 346 & 346A
1/4" = 1'-0"



4 Bldg 01-03 THIRD FLOOR HVAC PLAN - ROOM 370
1/4" = 1'-0"




2 Bldg 01-03 THIRD FLOOR HVAC PLAN - ROOM 307
1/4" = 1'-0"




1 Bldg 01-03 THIRD FLOOR HVAC PLAN
1/16" = 1'-0"


																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		</
--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----



**Bldg 01-04 FOURTH FLOOR HVAC
PLAN - ROOM 406**



**Bldg 01-04 FOURTH FLOOR HVAC
PLAN - ROOM 472**



Bldg 01-04 FOURTH FLOOR HVAC PLAN

[illegible]

A

B

C


D

E

F

2/23/2024 11:31:25 AM

Autosave: Docs\VLB-016 Sterile Storage Improvements\VLB-016-MEP_24.rvt



Bldg 01-05 FIFTH FLOOR HVAC PLAN - ROOM 572


2
1/4" = 1'-0"

HVAC GENERAL NOTES


- 1 REFER TO FACILITY'S INFECTION CONTROL AND RISK ASSESSMENT (ICRA) AND SPECIFICATION SECTION 01 35 26 (SAFETY REQUIREMENTS) FOR ADDITIONAL INFORMATION.
- 2 ALL WORK MUST BE SCHEDULED AND COORDINATED JOINTLY WITH THE OWNER. A DETAILED JOB TIMELINE MUST BE ESTABLISHED AND SUBMITTED FOR REVIEW AND APPROVAL.
- 3 REFER TO ARCHITECTURAL FOR ADDITIONAL REQUIREMENTS.
- 4 MAINTAIN 6-IN MINIMUM CLEARANCE FROM RATED WALLS AND HVAC EQUIPMENT.
- 5 CONTRACTOR TO PROVIDE REMOTE OPERATORS FOR ALL MANUAL VOLUME DAMPERS LOCATED ABOVE GYPSUM BOARD CEILINGS.
- 6 RUNOUT BRANCH DUCTWORK TO SUPPLY DIFFUSERS, RETURN AND EXHAUST GRILLES TO BE THE SAME SIZE AS THE NECK SIZE ON THE AIR DEVICE UNLESS NOTED OTHERWISE.
- 7 ALL BRANCH DUCTS TO DIFFUSERS, REGISTERS, AND GRILLES MUST BE INSTALLED WITH A VOLUME DAMPER.
- 8 DO NOT PLACE ANY RACKS OR SHELVES IN FRONT OF SENSORS OR HUMIDIFIERS. A MINIMUM CLEARANCE OF 2'-0" IN FRONT OF THE HUMIDIFIER WILL BE MAINTAINED AT ALL TIMES.
- 9 THERMOSTAT SETTINGS WILL BE 68 DEG F FOR ALL STERILE STORAGE ROOMS.
- 10 WHERE AIRFLOWS ARE SHOWN ON NEW WORK PLANS, (RE)BALANCE AIR DEVICES TO THE INDICATED AIRFLOWS.
- 11 SPACES SERVED BY 2-PIPE COOLING-ONLY FCU HAVE EXISTING PERIMETER HEATING CONVECTORS. TEMPTRAK WINTER DATA SUGGESTS THERE IS NO NEED TO REVISE EXISTING HEATING TO THE SPACE. SEE PIPING PLANS FOR CONVECTORS WORK.
- 12 CONTRACTOR RESPONSIBLE TO REMOVE EXISTING CEILING, REUSE AND REINSTALL TO GREATEST EXTENT POSSIBLE FOR LAY IN CEILING. GYP CEILINGS TO BE CUT AND PATCHED TO MATCH EXISTING. ALL SYSTEMS IN EXISTING CEILING TO REMAIN IN WORKING ORDER. ALL SPRINKLERS AND FIRE ALARMS IN AREA OF WORK TO REMAIN ACTIVE AT ALL TIMES.
- 13 REBALANCE DUCTED SYSTEMS IN SCOPE TO AIRFLOWS INDICATED ON DRAWINGS.
- 14 TEMPTRAK SENSORS ARE PART OF AN EXISTING CAMPUS-WIDE INDEPENDENT TEMPERATURE AND HUMIDITY MONITORING SYSTEM. COORDINATE NEW AND REPLACEMENT SENSORS WITH THE VA TO ENSURE COMPATIBILITY.

KEYNOTES

- 1 OA CONNECTION TO FCU. BALANCE TO 150 CFM.
- 2 HUMIDIFIER MOUNTED AT 1'-0" BELOW THE CEILING. MOUNT THE UNITS HUMIDITY SENSOR ON WALL ABOVE THE TEMPTRAK SENSOR, UNLESS OTHERWISE SHOWN. HUMIDIFIER SETTING SHALL BE 40 %RH.
- 3 PROVIDE AND INSTALL ROOM PRESSURE SENSOR, SETRA LITE WITH VISUAL ALARM (OR EQUAL).
- 4 EXISTING TEMPTRAK SENSOR SHALL BE LOCATED HERE. RELOCATE IF NECESSARY.
- 5 PROVIDE AND INSTALL NEW DIGITAL THERMOSTAT CONNECTED TO BAS.



1 Bldg 01-05 FIFTH FLOOR HVAC PLAN
1/16" = 1'-0"



																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																					</
--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----

A

B

C

D

E

F

A

B

C

D

E


F

HVAC GENERAL NOTES


- REFER TO FACILITY'S INFECTION CONTROL AND RISK ASSESSMENT (ICRA) AND SPECIFICATION SECTION 01 55 26 (SAFETY REQUIREMENTS) FOR ADDITIONAL INFORMATION.
- ALL WORK MUST BE SCHEDULED AND COORDINATED JOINTLY WITH THE OWNER. A DETAILED JOB TIMELINE MUST BE ESTABLISHED AND SUBMITTED FOR REVIEW AND APPROVAL.
- REFER TO ARCHITECTURAL FOR ADDITIONAL REQUIREMENTS.
- MAINTAIN 6-IN MINIMUM CLEARANCE FROM RATED WALLS AND HVAC EQUIPMENT.
- CONTRACTOR TO PROVIDE REMOTE OPERATORS FOR ALL MANUAL VOLUME DAMPERS LOCATED ABOVE GYPSUM BOARD CEILINGS.
- RUN/OUT BRANCH DUCTWORK TO SUPPLY DIFFUSERS, RETURN AND EXHAUST GRILLES TO BE THE SAME SIZE AS THE NECK SIZE ON THE AIR DEVICE UNLESS NOTED OTHERWISE.
- ALL BRANCH DUCTS TO DIFFUSERS, REGISTERS, AND GRILLES MUST BE INSTALLED WITH A VOLUME DAMPER.
- DO NOT PLACE ANY RACKS OR SHELVES IN FRONT OF SENSORS OR HUMIDIFIERS. A MINIMUM CLEARANCE OF 2'-0" IN FRONT OF THE HUMIDIFIER WILL BE MAINTAINED AT ALL TIMES.
- THERMOSTAT SETTING WILL BE 68 DEG F FOR ALL STERILE STORAGE ROOMS.
- WHERE AIRFLOWS ARE SHOWN ON NEW WORK PLANS, (RE)BALANCE AIR DEVICES TO THE INDICATED AIRFLOWS.
- SPACES SERVED BY 2-PIPE COOLING-ONLY FCU HAVE EXISTING PERIMETER HEATING CONVECTORS. TEMPRAK WINTER DATA SUGGESTS THERE IS NO NEED TO REVISE EXISTING HEATING TO THE SPACE. SEE PIPING PLANS FOR CONVECTORS WORK.
- CONTRACTOR RESPONSIBLE TO REMOVE EXISTING CEILING, REUSE AND REINSTALL TO GREATEST EXTENT POSSIBLE FOR LAY IN CEILINGS. GYP CEILINGS TO BE CUT AND PATCHED TO MATCH EXISTING. ALL SYSTEMS IN EXISTING CEILING TO REMAIN IN WORKING ORDER. ALL SPRINKLERS AND FIRE ALARMS IN AREA OF WORK TO REMAIN ACTIVE AT ALL TIMES.
- REBALANCE DUCTED SYSTEMS IN SCOPE TO AIRFLOWS INDICATED ON DRAWINGS.
- TEMPTRAK SENSORS ARE PART OF AN EXISTING CAMPUS-WIDE INDEPENDENT TEMPERATURE AND HUMIDITY MONITORING SYSTEM. COORDINATE NEW AND REPLACEMENT SENSORS WITH THE VA TO ENSURE COMPATIBILITY.

KEYNOTES

- HUMIDIFIER MOUNTED AT 1'-0" BELOW THE CEILING. MOUNT THE UNITS HUMIDITY SENSOR ON WALL ABOVE THE TEMPRAK SENSOR. UNLESS OTHERWISE SHOWN. HUMIDIFIER SETTING SHALL BE 40 %RH.
- PROVIDE AND INSTALL NEW DIGITAL THERMOSTAT CONNECTED TO BAS.
- EXISTING TEMPRAK SENSOR SHALL BE LOCATED HERE. RELOCATE IF NECESSARY.
- PROVIDE AND INSTALL ROOM PRESSURE SENSOR, SETRA LITE WITH VISUAL ALARM (OR EQUAL).
- FURNISH AND INSTALL WALL CAP, COLLAR AND 6" DIAMETER DUCT CONNECTION, SEIHO SFX-6 OR APPROVED EQUAL. PROVIDE WITH INSECT SCREEN.



1 Bldg 04-01 FIRST FLOOR HVAC PLAN - ROOM 105
1/4" = 1'-0"



																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																					</
--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----



- 1 EXISTING FCU, CLEAN COILS, INSPECT AND TEST UNIT TO ENSURE FULL FUNCTIONALITY.
- 2 EXISTING THERMOSTAT SET TO 68 DEG F.
- 3 PROVIDE AND INSTALL ROOM PRESSURE SENSOR, SETRA LITE WITH VISUAL ALARM (OR EQUAL).
- 4 REPLACE TEMPRTRAK SENSOR WITH NEW.
- 5 EXISTING TEMPRTRAK SENSOR
- 6 EXISTING OA CONNECTION TO FCU, BALANCE TO 80 CFM.
- 7 PROVIDE MINIMUM 1/2" DOOR UNDERCUT FOR RELIEF AIR.


Autodesk Docs://V/LEB-016 Sterile Storage Improvements/V/LEB-016-MEP_24.rvt 2/23/2026 11:31:31 AM

HVAC GENERAL NOTES

- 1 REFER TO FACILITY'S INFECTION CONTROL AND RISK ASSESSMENT (ICRA) AND SPECIFICATION SECTION 01 36 26 (SAFETY REQUIREMENTS) FOR ADDITIONAL INFORMATION.
- 2 ALL WORK MUST BE SCHEDULED AND COORDINATED JOINTLY WITH THE OWNER. A DETAILED JOB TIMELINE MUST BE ESTABLISHED AND SUBMITTED FOR REVIEW AND APPROVAL.
- 3 REFER TO ARCHITECTURAL FOR ADDITIONAL REQUIREMENTS.
- 4 MAINTAIN 6-IN MINIMUM CLEARANCE FROM RATED WALLS AND HVAC EQUIPMENT.
- 5 CONTRACTOR TO PROVIDE REMOTE OPERATORS FOR ALL MANUAL VOLUME DAMPERS LOCATED ABOVE GYPSUM BOARD CEILINGS.
- 6 RUNOUT BRANCH DUCTWORK TO SUPPLY DIFFUSERS, RETURN AND EXHAUST GRILLES TO BE THE SAME SIZE AS THE NECK SIZE ON THE AIR DEVICE UNLESS NOTED OTHERWISE.
- 7 ALL BRANCH DUCTS TO DIFFUSERS, REGISTERS, AND GRILLES MUST BE INSTALLED WITH A VOLUME DAMPER.
- 8 DO NOT PLACE ANY RACKS OR SHELVES IN FRONT OF SENSORS OR HUMIDIFIERS. A MINIMUM CLEARANCE OF 2'-0" IN FRONT OF THE HUMIDIFIER WILL BE MAINTAINED AT ALL TIMES.
- 9 THERMOSTAT SETTING WILL BE 68 DEG F FOR ALL STERILE STORAGE ROOMS.
- 10 WHERE AIRFLOWS ARE SHOWN ON NEW WORK PLANS, (RE)BALANCE AIR DEVICES TO THE INDICATED AIRFLOWS.
- 11 SPACES SERVED BY 2-PIPE COOLING-ONLY FCU HAVE EXISTING PERIMETER HEATING CONNECTORS. TEMPRAK WINTER DATA SUGGESTS THERE IS NO NEED TO REVISE EXISTING HEATING TO THE SPACE. SEE PIPING PLANS FOR CONNECTORS WORK.
- 12 CONTRACTOR RESPONSIBLE TO REMOVE EXISTING CEILING, REUSE AND REINSTALL TO GREATEST EXTENT POSSIBLE FOR LAY IN CEILINGS. GYP CEILINGS TO BE CUT AND PATCHED TO MATCH EXISTING. ALL SYSTEMS IN EXISTING CEILING TO REMAIN IN WORKING ORDER. ALL SPRINKLERS AND FIRE ALARMS IN AREA OF WORK TO REMAIN ACTIVE AT ALL TIMES.
- 13 REBALANCE DUCTED SYSTEMS IN SCOPE TO AIRFLOWS INDICATED ON DRAWINGS.
- 14 TEMPRAK SENSORS ARE PART OF AN EXISTING CAMPUS-WIDE INDEPENDENT TEMPERATURE AND HUMIDITY MONITORING SYSTEM. COORDINATE NEW AND REPLACEMENT SENSORS WITH THE VA TO ENSURE COMPATIBILITY.


KEYNOTES

- 1 EXISTING FCU. CLEAN COILS, INSPECT AND TEST UNIT TO ENSURE FULL FUNCTIONALITY.
- 2 HUMIDIFIER MOUNTED AT 1'-0" BELOW THE CEILING. MOUNT THE UNIT'S HUMIDITY SENSOR ON WALL ABOVE THE TEMPRAK SENSOR, UNLESS OTHERWISE SHOWN. HUMIDIFIER SETTING SHALL BE 40 %RH.
- 3 EXISTING THERMOSTAT SHALL BE LOCATED HERE. RELOCATE IF NECESSARY.
- 4 PROVIDE AND INSTALL ROOM PRESSURE SENSOR. SETRA LITE WITH VISUAL ALARM (OR EQUAL).
- 5 EXISTING TEMPRAK SENSOR SHALL BE LOCATED HERE. RELOCATE IF NECESSARY.
- 6 RELOCATED EXISTING THERMOSTAT.
- 7 DEHUMIDIFIER MOUNTED AT 2'-0" AFF. DEHUMIDIFIER SETTING SHALL BE 50 %RH.
- 8 OA CONNECTION TO FCU. BALANCE TO 50 CFM.




BID DEDUCT 1 - Bldg
17-02-SECOND FLOOR HVAC PLAN
- ROOM 209

2
1/4" = 1'-0"



BID DEDUCT 1 - Bldg
17-02-SECOND FLOOR HVAC PLAN
- ROOM 264

3
1/4" = 1'-0"



[illegible]

A

B

C


D

E


F

2/23/2024 11:31:40 AM


Autodesk Docs\\VLEB-016 Sterile Storage Improvements\\VLEB-016-MEP_24.rvt




BID DEDUCT 1 - Bldg 17-04 FOURTH FLOOR HVAC PLAN - ROOM 460
1/4" = 1'-0"



BID DEDUCT 1 - Bldg 17-04 FOURTH FLOOR HVAC PLAN - ROOM 426
1/4" = 1'-0"



BID DEDUCT 1 - Bldg 17-04 FOURTH FLOOR HVAC PLAN - ROOM 472
1/4" = 1'-0"



BID DEDUCT 1 - Bldg 17-04 FOURTH FLOOR HVAC PLAN
1/16" = 1'-0"

HVAC GENERAL NOTES

- 1 REFER TO FACILITY'S INFECTION CONTROL AND RISK ASSESSMENT (ICRA) AND SPECIFICATION SECTION 01 36 00 (SAFETY REQUIREMENTS) FOR ADDITIONAL INFORMATION.
- 2 ALL WORK MUST BE SCHEDULED AND COORDINATED JOINTLY WITH THE OWNER. A DETAILED JOB TIMELINE MUST BE ESTABLISHED AND SUBMITTED FOR REVIEW AND APPROVAL.
- 3 REFER TO ARCHITECTURAL FOR ADDITIONAL REQUIREMENTS.
- 4 MAINTAIN 6-IN MINIMUM CLEARANCE FROM RATED WALLS AND HVAC EQUIPMENT.
- 5 CONTRACTOR TO PROVIDE REMOTE OPERATORS FOR ALL MANUAL VOLUME DAMPERS LOCATED ABOVE GYPSUM BOARD CEILINGS.
- 6 RUNOUT BRANCH DUCTWORK TO SUPPLY DIFFUSERS, RETURN AND EXHAUST GRILLES TO BE THE SAME SIZE AS THE NECK SIZE ON THE AIR DEVICE UNLESS NOTED OTHERWISE.
- 7 ALL BRANCH DUCTS TO DIFFUSERS, REGISTERS, AND GRILLES MUST BE INSTALLED WITH A VOLUME DAMPER.
- 8 DO NOT PLACE ANY RACKS OR SHELVES IN FRONT OF SENSORS OR HUMIDIFIERS. A MINIMUM CLEARANCE OF 2'-0" IN FRONT OF THE HUMIDIFIER WILL BE MAINTAINED AT ALL TIMES.
- 9 THERMOSTAT SETTING WILL BE 68 DEG F FOR ALL STERILE STORAGE ROOMS.
- 10 WHERE AIRFLOWS ARE SHOWN ON NEW WORK PLANS, (RE)BALANCE AIR DEVICES TO THE INDICATED AIRFLOWS.
- 11 SPACES SERVED BY 2-PIPE COOLING-ONLY FOU HAVE EXISTING PERIMETER HEATING CONNECTORS. TEMPRAK WINTER DATA SUGGESTS THERE IS NO NEED TO REVISE EXISTING HEATING TO THE SPACE. SEE PIPING PLANS FOR CONNECTORS WORK.
- 12 CONTRACTOR RESPONSIBLE TO REMOVE EXISTING CEILING, REUSE AND REINSTALL TO GREATEST EXTENT POSSIBLE FOR LAY IN CEILINGS. GYP CEILINGS TO BE CUT AND PATCHED TO MATCH EXISTING. ALL SYSTEMS IN EXISTING CEILING TO REMAIN IN WORKING ORDER, ALL SPRINKLERS AND FIRE ALARMS IN AREA OF WORK TO REMAIN ACTIVE AT ALL TIMES.
- 13 REBALANCE DUCTED SYSTEMS IN SCOPE TO AIRFLOWS INDICATED ON DRAWINGS.
- 14 TEMPRAK SENSORS ARE PART OF AN EXISTING CAMPUS-WIDE INDEPENDENT TEMPERATURE AND HUMIDITY MONITORING SYSTEM. COORDINATE NEW AND REPLACEMENT SENSORS WITH THE VA TO ENSURE COMPATIBILITY.

KEYNOTES

- 1 PROVIDE AND INSTALL NEW FOU, CONNECT TO REUSE EXISTING PIPING AND ACCESSORIES.
- 2 HUMIDIFIER MOUNTED AT 1'-0" BELOW THE CEILING. MOUNT THE UNITS HUMIDITY SENSOR ON WALL ABOVE THE TEMPRAK SENSOR, UNLESS OTHERWISE SHOWN. HUMIDIFIER SETTING SHALL BE 40 %RH.
- 3 PROVIDE AND INSTALL NEW DIGITAL THERMOSTAT CONNECTED TO BAS.
- 4 EXISTING TEMPRAK SENSOR SHALL BE LOCATED HERE. RELOCATE IF NECESSARY.
- 5 PROVIDE AND INSTALL ROOM PRESSURE SENSOR, SETRA LITE WITH VISUAL ALARM (OR EQUAL).
- 6 PROVIDE AND INSTALL NEW TEMPRAK SENSOR.
- 7 OA CONNECTION TO FOU, BALANCE TO 50 CFM.
- 8 OA CONNECTION TO FOU, BALANCE TO 100 CFM.

A


B


C

D

E

F



			Consultant		Architect/Engineer of Record		Stamp	OFFICE OF CONSTRUCTION AND FACILITIES MANAGEMENT		Drawing Title BUILDING 17 - FOURTH FLOOR HVAC PLAN		Phase BID DOCUMENTS		Project Title STERILE STORAGE IMPROVEMENTS		Project Number VLEB-016	
					 AE WORKS			VA U.S. Department of Veterans Affairs		Approved:	Sprinkler Status FULLY SPRINKLERED	Location 1700 S LINCOLN AVE, LEBANON, PA 17042		Building Number 17			
1 BID DEDUCT #1								Issue Date 11.17.25				Drawing Number 017-M-104					
#	Revisions	Date										Checked TS		Drawn AC			

A

B

C


D

E


F

2/23/2026 11:31:44 AM


Autosave: Docs\VLB-016 Sterile Storage Improvements\VLB-016-MEP_24.rvt




BID DEDUCT 1 - Bldg 17-05 FIFTH FLOOR HVAC PLAN - ROOM 536
1/4" = 1'-0"




BID DEDUCT 1 - Bldg 17-05 FIFTH FLOOR HVAC PLAN - ROOM 521
1/4" = 1'-0"



BID DEDUCT 1 - Bldg 17-05 FIFTH FLOOR HVAC PLAN - ROOM 555G
1/4" = 1'-0"



BID DEDUCT 1 - Bldg 17-05 FIFTH FLOOR HVAC PLAN - ROOM 578
1/4" = 1'-0"




BID DEDUCT 1 - Bldg 17-05 FIFTH FLOOR HVAC PLAN
1/16" = 1'-0"

HVAC GENERAL NOTES


- 1 REFER TO FACILITY'S INFECTION CONTROL AND RISK ASSESSMENT (ICRA) AND SPECIFICATION SECTION 01 35 26 (SAFETY REQUIREMENTS) FOR ADDITIONAL INFORMATION.
- 2 ALL WORK MUST BE SCHEDULED AND COORDINATED JOINTLY WITH THE OWNER. A DETAILED JOB TIMELINE MUST BE ESTABLISHED AND SUBMITTED FOR REVIEW AND APPROVAL.
- 3 REFER TO ARCHITECTURAL FOR ADDITIONAL REQUIREMENTS.
- 4 MAINTAIN 6-IN MINIMUM CLEARANCE FROM RATED WALLS AND HVAC EQUIPMENT.
- 5 CONTRACTOR TO PROVIDE REMOTE OPERATORS FOR ALL MANUAL VOLUME DAMPERS LOCATED ABOVE GYPSUM BOARD CEILINGS.
- 6 RUNOUT BRANCH DUCTWORK TO SUPPLY DIFFUSERS, RETURN AND EXHAUST GRILLES TO BE THE SAME SIZE AS THE NECK SIZE ON THE AIR DEVICE UNLESS NOTED OTHERWISE.
- 7 ALL BRANCH DUCTS TO DIFFUSERS, REGISTERS, AND GRILLES MUST BE INSTALLED WITH A VOLUME DAMPER.
- 8 DO NOT PLACE ANY RACKS OR SHELVES IN FRONT OF SENSORS OR HUMIDIFIERS. A MINIMUM CLEARANCE OF 2'-0" IN FRONT OF THE HUMIDIFIER WILL BE MAINTAINED AT ALL TIMES.
- 9 THERMOSTAT SETTING WILL BE 66 DEGS F FOR ALL STERILE STORAGE ROOMS
- 10 WHERE AIRFLOWS ARE SHOWN ON NEW WORK PLANS, (RE)BALANCE AIR DEVICES TO THE INDICATED AIRFLOWS.
- 11 SPACES SERVED BY 2-PIPE COOLING-ONLY FOU HAVE EXISTING PERIMETER HEATING CONNECTORS. TEMPTRAK WINTER DATA SUGGESTS THERE IS NO NEED TO REVISE EXISTING HEATING TO THE SPACE. SEE PIPING PLANS FOR CONVECTORS WORK.
- 12 CONTRACTOR RESPONSIBLE TO REMOVE EXISTING CEILING, REUSE AND REINSTALL TO GREATEST EXTENT POSSIBLE FOR LAY IN CEILINGS. GYP CEILINGS TO BE CUT AND PATCHED TO MATCH EXISTING. ALL SYSTEMS IN EXISTING CEILING TO REMAIN IN WORKING ORDER. ALL SPRINKLERS AND FIRE ALARMS IN AREA OF WORK TO REMAIN ACTIVE AT ALL TIMES.
- 13 REBALANCE DUCTED SYSTEMS IN SCOPE TO AIRFLOWS INDICATED ON DRAWINGS.
- 14 TEMPTRAK SENSORS ARE PART OF AN EXISTING CAMPUS-WIDE INDEPENDENT TEMPERATURE AND HUMIDITY MONITORING SYSTEM. COORDINATE NEW AND REPLACEMENT SENSORS WITH THE VA TO ENSURE COMPATIBILITY.

KEYNOTES

- 1 EXISTING FOU: CLEAN COILS, INSPECT AND TEST UNIT TO ENSURE FULL FUNCTIONALITY.
- 2 HUMIDIFIER MOUNTED AT 1'-0" BELOW THE CEILING. MOUNT THE UNIT'S HUMIDITY SENSOR ON WALL ABOVE THE TEMPTRAK SENSOR, UNLESS OTHERWISE SHOWN. HUMIDIFIER SETTING SHALL BE 40 %RH.
- 3 EXISTING TEMPTRAK SENSOR SHALL BE LOCATED HERE. RELOCATE IF NECESSARY.
- 4 PROVIDE AND INSTALL ROOM PRESSURE SENSOR, SETRA LITE WITH VISUAL ALARM (OR EQUAL).
- 5 PROVIDE AND INSTALL NEW VAV BOX.
- 6 PROVIDE AND INSTALL NEW DIGITAL THERMOSTAT CONNECTED TO BAS.
- 7 REPLACE TEMPTRAK SENSOR WITH NEW.
- 8 EXISTING RETURN AIR GRILLE. RE-BALANCE AIRFLOW TO CFM SHOWN.
- 9 PROVIDE AND INSTALL NEW FOU, CONNECT TO REUSE EXISTING PIPING AND ACCESSORIES.
- 10 EXISTING THERMOSTAT SHALL BE LOCATED HERE. RELOCATE IF NECESSARY.
- 11 6" OA CONNECTION TO FOU. BALANCE TO 90 CFM.



--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

 $1/16'' = 1'-4$ 

1	2	3	4	5	6	7	8	9	10
---	---	---	---	---	---	---	---	---	----

A

B

C

D

E

F

2/23/2024 11:31:48 AM


Autodesk Docs\\VLEB-018 Sterile Storage Improvements\\VLEB-018-MEP_24.rvt

HVAC GENERAL NOTES

- 1 REFER TO FACILITY'S INFECTION CONTROL AND RISK ASSESSMENT (ICRA) AND SPECIFICATION SECTION 01 35 26 (SAFETY REQUIREMENTS) FOR ADDITIONAL INFORMATION.
- 2 ALL WORK MUST BE SCHEDULED AND COORDINATED JOINTLY WITH THE OWNER. A DETAILED JOB TIMELINE MUST BE ESTABLISHED AND SUBMITTED FOR REVIEW AND APPROVAL.
- 3 REFER TO ARCHITECTURAL FOR ADDITIONAL REQUIREMENTS.
- 4 MAINTAIN 6-IN MINIMUM CLEARANCE FROM RATED WALLS AND HVAC EQUIPMENT.
- 5 CONTRACTOR TO PROVIDE REMOTE OPERATORS FOR ALL MANUAL VOLUME DAMPERS LOCATED ABOVE GYPSUM BOARD CEILINGS.
- 6 RUNOUT BRANCH DUCTWORK TO SUPPLY DIFFUSERS, RETURN AND EXHAUST GRILLES TO BE THE SAME SIZE AS THE NECK SIZE ON THE AIR DEVICE UNLESS NOTED OTHERWISE.
- 7 ALL BRANCH DUCTS TO DIFFUSERS, REGISTERS, AND GRILLES MUST BE INSTALLED WITH A VOLUME DAMPER.
- 8 DO NOT PLACE ANY RACKS OR SHELVES IN FRONT OF SENSORS OR HUMIDIFIERS. A MINIMUM CLEARANCE OF 2'-0" IN FRONT OF THE HUMIDIFIER WILL BE MAINTAINED AT ALL TIMES.
- 9 THERMOSTAT SETTINGS WILL BE 68 DEG F FOR ALL STERILE STORAGE ROOMS.
- 10 WHERE AIRFLOWS ARE SHOWN ON NEW WORK PLANS, (RE)BALANCE AIR DEVICES TO THE INDICATED AIRFLOWS.
- 11 SPACES SERVED BY 2-PIPE COOLING-ONLY FCU HAVE EXISTING PERIMETER HEATING CONVECTORS. TEMPRAK WINTER DATA SUGGESTS THERE IS NO NEED TO REVISE EXISTING HEATING TO THE SPACE. SEE PIPING PLANS FOR CONVECTORS WORK.
- 12 CONTRACTOR RESPONSIBLE TO REMOVE EXISTING CEILING, REUSE AND REINSTALL TO GREATEST EXTENT POSSIBLE FOR LAY IN CEILINGS. GYP CEILINGS TO BE CUT AND PATCHED TO MATCH EXISTING. ALL SYSTEMS IN EXISTING CEILING TO REMAIN IN WORKING ORDER. ALL SPRINKLERS AND FIRE ALARMS IN AREA OF WORK TO REMAIN ACTIVE AT ALL TIMES.
- 13 REBALANCE DUCTED SYSTEMS IN SCOPE TO AIRFLOWS INDICATED ON DRAWINGS.
- 14 TEMPRAK SENSORS ARE PART OF AN EXISTING CAMPUS-WIDE INDEPENDENT TEMPERATURE AND HUMIDITY MONITORING SYSTEM. COORDINATE NEW AND REPLACEMENT SENSORS WITH THE VA TO ENSURE COMPATIBILITY.

KEYNOTES


- 1 EXISTING FCU, CLEAN COILS, INSPECT AND TEST UNIT TO ENSURE FULL FUNCTIONALITY.
- 2 HUMIDIFIER MOUNTED AT 1'-0" BELOW THE CEILING. MOUNT THE UNIT'S HUMIDITY SENSOR ON WALL ABOVE THE TEMPRAK SENSOR, UNLESS OTHERWISE SHOWN. HUMIDIFIER SETTING SHALL BE 40 %RH.
- 3 EXISTING THERMOSTAT SHALL BE LOCATED HERE. RELOCATE IF NECESSARY.
- 4 EXISTING TEMPRAK SENSOR SHALL BE LOCATED HERE. RELOCATE IF NECESSARY.
- 5 PROVIDE AND INSTALL ROOM PRESSURE SENSOR, SETRA LITE WITH VISUAL ALARM (OR EQUAL).
- 6 EXISTING OA CONNECTION TO FCU, BALANCE TO 50 CFM.



Bldg 18-05 FIFTH FLOOR HVAC PLAN - ROOM 517A

2


1/4" = 1'-0"



1

Bldg 18-05 FIFTH FLOOR HVAC PLAN

1/16" = 1'-0"



--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

A

B

C

D

E

F

2/23/2024 11:31:59 AM

Autodesk Docs\\VLEB-016 Sterile Storage Improvements\\VLEB-016-MEP_24.rvt

A

B

C

D

E


F

HVAC GENERAL NOTES

- 1 REFER TO FACILITY'S INFECTION CONTROL AND RISK ASSESSMENT (ICRA) AND SPECIFICATION SECTION 01 35 26 (SAFETY REQUIREMENTS) FOR ADDITIONAL INFORMATION.
- 2 ALL WORK MUST BE SCHEDULED AND COORDINATED JOINTLY WITH THE OWNER. A DETAILED JOB TIMELINE MUST BE ESTABLISHED AND SUBMITTED FOR REVIEW AND APPROVAL.
- 3 REFER TO ARCHITECTURAL FOR ADDITIONAL REQUIREMENTS.
- 4 MAINTAIN 6-IN MINIMUM CLEARANCE FROM RATED WALLS AND HVAC EQUIPMENT.
- 5 CONTRACTOR TO PROVIDE REMOTE OPERATORS FOR ALL MANUAL VOLUME DAMPERS LOCATED ABOVE GYPSUM BOARD CEILINGS.
- 6 RUNOUT BRANCH DUCTWORK TO SUPPLY DIFFUSERS, RETURN AND EXHAUST GRILLES TO BE THE SAME SIZE AS THE NECK SIZE ON THE AIR DEVICE UNLESS NOTED OTHERWISE.
- 7 ALL BRANCH DUCTS TO DIFFUSERS, REGISTERS, AND GRILLES MUST BE INSTALLED WITH A VOLUME DAMPER.
- 8 DO NOT PLACE ANY RACKS OR SHELVES IN FRONT OF SENSORS OR HUMIDIFIERS. A MINIMUM CLEARANCE OF 2'-0" IN FRONT OF THE HUMIDIFIER WILL BE MAINTAINED AT ALL TIMES.
- 9 THERMOSTAT SETTING WILL BE 68 DEG F FOR ALL STERILE STORAGE ROOMS.
- 10 WHERE AIRFLOWS ARE SHOWN ON NEW WORK PLANS, (RE)BALANCE AIR DEVICES TO THE INDICATED AIRFLOWS.
- 11 SPACES SERVED BY 2-PIPE COOLING-ONLY FOU HAVE EXISTING PERIMETER HEATING CONVECTORS. TEMPTRAK WINTER DATA SUGGESTS THERE IS NO NEED TO REVISE EXISTING HEATING TO THE SPACE. SEE PIPING PLANS FOR CONVECTORS WORK.
- 12 CONTRACTOR RESPONSIBLE TO REMOVE EXISTING CEILING, REUSE AND REINSTALL TO GREATEST EXTENT POSSIBLE FOR LAY IN CEILINGS. GYP CEILINGS TO BE CUT AND PATCHED TO MATCH EXISTING. ALL SYSTEMS IN EXISTING CEILING TO REMAIN IN WORKING ORDER, ALL SPRINKLERS AND FIRE ALARMS IN AREA OF WORK TO REMAIN ACTIVE AT ALL TIMES.
- 13 REBALANCE DUCTED SYSTEMS IN SCOPE TO AIRFLOWS INDICATED ON DRAWINGS.
- 14 TEMPTRAK SENSORS ARE PART OF AN EXISTING CAMPUS-WIDE INDEPENDENT TEMPERATURE AND HUMIDITY MONITORING SYSTEM. COORDINATE NEW AND REPLACEMENT SENSORS WITH THE VA TO ENSURE COMPATIBILITY.

KEYNOTES

- 1 EXISTING FOU, CLEAN COILS, INSPECT AND TEST UNIT TO ENSURE FULL FUNCTIONALITY.
- 2 (E)FCU TO REMAIN ENABLED AND OPERATIONAL IN BAS. SUBJECT TO CHANGE AS CONDITIONS ARE FINE-TUNED WITH RE-USING OF EXISTING SYSTEMS FOR THE NEW STERILE STORAGE USE. FAN SHALL BE CONSTANTLY ENERGIZED FOR CONTINUOUS OPERATION.
- 3 (E)FCU TO BE DISABLED IN BAS. SUBJECT TO CHANGE AS CONDITIONS ARE FINE-TUNED WITH RE-USING OF EXISTING SYSTEMS FOR THE NEW STERILE STORAGE USE.
- 4 ABANDONED EXISTING OUTSIDE AIR SUPPLY REGISTERS ALONG THIS WALL TO REMAIN. CONFIRM THERE IS NO ACTIVE SUPPLY AIRFLOW.
- 5 PROVIDE AND INSTALL NEW DIGITAL THERMOSTAT CONNECTED TO BAS.
- 6 PROVIDE AND INSTALL NEW TEMPTRAK SENSOR.
- 7 PROVIDE AND INSTALL ROOM PRESSURE SENSOR, SETRA LITE WITH VISUAL ALARM (OR EQUAL).
- 8 DEHUMIDIFIER MOUNTED AT 2'-0" AFF. DEHUMIDIFIER SETTING SHALL BE 50 %RH.



1


Bldg 22-01-FIRST FLOOR HVAC PLAN - ROOM 109

1/8" = 1'-0"

--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--



- 1 RESET AIRFLOW AT THE EXISTING VAV BOX TO 250 CFM CONSTANT FLOW.
- 2 HUMIDIFIER MOUNTED AT 1'-0" BELOW THE CEILING, MOUNT THE UNIT'S HUMIDITY SENSOR ON WALL ABOVE THE TEMPRTRX SENSOR, UNLESS OTHERWISE SHOWN HUMIDIFIER SETTING SHALL BE 40 %RH.
- 3 EXISTING THERMOSTAT SHALL BE LOCATED HERE. RELOCATE IF NECESSARY.
- 4 PROVIDE AND INSTALL ROOM PRESSURE SENSOR, SETRA LITE WITH VISUAL ALARM (OR EQUAL).
- 5 EXISTING TEMPRTRX SENSOR SHALL BE LOCATED HERE. RELOCATE IF NECESSARY.
- 6 DEHUMIDIFIER MOUNTED AT 2'-0" AFF. DEHUMIDIFIER SETTING SHALL BE 50 %RH.



1 Bldg 22-02-SECOND FLOOR HVAC PLAN
1/8" = 1'-0"

[illegible]

A

B

C


D

E

F


2/23/2024 11:31:55 AM

Autodesk Docs\\VLEB-016 Sterile Storage Improvements\\VLEB-016-MEP_24.rvt



Bldg 37-01-FIRST FLOOR HVAC
PLAN - ROOM 1A10

1/4" = 1'-0"



1 Bldg 37-01-FIRST FLOOR HVAC PLAN


1/8" = 1'-0"

HVAC GENERAL NOTES

- 1 REFER TO FACILITY'S INFECTION CONTROL AND RISK ASSESSMENT (ICRA) AND SPECIFICATION SECTION 01 35 26 (SAFETY REQUIREMENTS) FOR ADDITIONAL INFORMATION.
- 2 ALL WORK MUST BE SCHEDULED AND COORDINATED JOINTLY WITH THE OWNER. A DETAILED JOB TIMELINE MUST BE ESTABLISHED AND SUBMITTED FOR REVIEW AND APPROVAL.
- 3 REFER TO ARCHITECTURAL FOR ADDITIONAL REQUIREMENTS.
- 4 MAINTAIN 6-IN MINIMUM CLEARANCE FROM RATED WALLS AND HVAC EQUIPMENT.
- 5 CONTRACTOR TO PROVIDE REMOTE OPERATORS FOR ALL MANUAL VOLUME DAMPERS LOCATED ABOVE GYPSUM BOARD CEILINGS.
- 6 RUNOUT BRANCH DUCTWORK TO SUPPLY DIFFUSERS, RETURN AND EXHAUST GRILLES TO BE THE SAME SIZE AS THE NECK SIZE ON THE AIR DEVICE UNLESS NOTED OTHERWISE.
- 7 ALL BRANCH DUCTS TO DIFFUSERS, REGISTERS, AND GRILLES MUST BE INSTALLED WITH A VOLUME DAMPER.
- 8 DO NOT PLACE ANY RACKS OR SHELVES IN FRONT OF SENSORS OR HUMIDIFIERS. A MINIMUM CLEARANCE OF 2'-0" IN FRONT OF THE HUMIDIFIER WILL BE MAINTAINED AT ALL TIMES.
- 9 THERMOSTAT SETTING WILL BE 68 DEG F FOR ALL STERILE STORAGE ROOMS.
- 10 WHERE AIRFLOWS ARE SHOWN ON NEW WORK PLANS, (RE)BALANCE AIR DEVICES TO THE INDICATED AIRFLOWS.
- 11 SPACES SERVED BY 2-PIPE COOLING-ONLY FCU HAVE EXISTING PERIMETER HEATING CONVECTORS. TEMPTRAK WINTER DATA SUGGESTS THERE IS NO NEED TO REVISE EXISTING HEATING TO THE SPACE. SEE PIPING PLANS FOR CONVECTORS WORK.
- 12 CONTRACTOR RESPONSIBLE TO REMOVE EXISTING CEILING, REUSE AND REINSTALL TO GREATEST EXTENT POSSIBLE FOR LAY IN CEILING. GYP CEILINGS TO BE CUT AND PATCHED TO MATCH EXISTING. ALL SYSTEMS IN EXISTING CEILING TO REMAIN IN WORKING ORDER. ALL SPRINKLERS AND FIRE ALARMS IN AREA OF WORK TO REMAIN ACTIVE AT ALL TIMES.
- 13 REBALANCE DUCTED SYSTEMS IN SCOPE TO AIRFLOWS INDICATED ON DRAWINGS.
- 14 TEMPTRAK SENSORS ARE PART OF AN EXISTING CAMPUS-WIDE INDEPENDENT TEMPERATURE AND HUMIDITY MONITORING SYSTEM. COORDINATE NEW AND REPLACEMENT SENSORS WITH THE VA TO ENSURE COMPATIBILITY.

KEYNOTES

- 1 PROVIDE AND INSTALL ROOM PRESSURE SENSOR, SETRA LITE WITH VISUAL ALARM (OR EQUAL).
- 2 HUMIDIFIER MOUNTED AT 1'-0" BELOW THE CEILING. MOUNT THE UNIT'S HUMIDITY SENSOR ON WALL ABOVE THE TEMPTRAK SENSOR, UNLESS OTHERWISE SHOWN. HUMIDIFIER SETTING SHALL BE 40 %RH.
- 3 EXISTING THERMOSTAT SHALL BE LOCATED HERE. RELOCATE IF NECESSARY.
- 4 EXISTING TEMPTRAK SENSOR SHALL BE LOCATED HERE. RELOCATE IF NECESSARY.



																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																					</
--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----

A

B

C


D

E

F


2/23/2024 11:31:59 AM

Autosave Docs\\VLEB-016 Sterile Storage Improvements\\VLEB-016-MEP_24.rvt




Bldg 101-01-FIRST FLOOR HVAC
PLAN - ROOM 132

3
1/4" = 1'-0"




Bldg 101-01-FIRST FLOOR HVAC
PLAN - ROOM 104

2
1/4" = 1'-0"



Bldg 101-01-FIRST FLOOR HVAC
PLAN - ROOM 163, 163A, 163B

5
1/4" = 1'-0"



Bldg 101-01-FIRST FLOOR HVAC
PLAN - ROOM 145B


4
1/4" = 1'-0"

HVAC GENERAL NOTES

- 1 REFER TO FACILITY'S INFECTION CONTROL, AND RISK ASSESSMENT (ICRA) AND SPECIFICATION SECTION 01 35 26 (SAFETY REQUIREMENTS) FOR ADDITIONAL INFORMATION.
- 2 ALL WORK MUST BE SCHEDULED AND COORDINATED JOINTLY WITH THE OWNER. A DETAILED JOB TIMELINE MUST BE ESTABLISHED AND SUBMITTED FOR REVIEW AND APPROVAL.
- 3 REFER TO ARCHITECTURAL FOR ADDITIONAL REQUIREMENTS.
- 4 MAINTAIN 6-IN MINIMUM CLEARANCE FROM RATED WALLS AND HVAC EQUIPMENT.
- 5 CONTRACTOR TO PROVIDE REMOTE OPERATORS FOR ALL MANUAL VOLUME DAMPERS LOCATED ABOVE GYPSUM BOARD CEILINGS.
- 6 RUNOUT BRANCH DUCTWORK TO SUPPLY DIFFUSERS, RETURN AND EXHAUST GRILLES TO BE THE SAME SIZE AS THE NECK SIZE ON THE AIR DEVICE UNLESS NOTED OTHERWISE.
- 7 ALL BRANCH DUCTS TO DIFFUSERS, REGISTERS, AND GRILLES MUST BE INSTALLED WITH A VOLUME DAMPER.
- 8 DO NOT PLACE ANY RACKS OR SHELVES IN FRONT OF SENSORS OR HUMIDIFIERS. A MINIMUM CLEARANCE OF 2'-0" IN FRONT OF THE HUMIDIFIER WILL BE MAINTAINED AT ALL TIMES.
- 9 THERMOSTAT SETTING WILL BE 68 DEG F FOR ALL STERILE STORAGE ROOMS.
- 10 WHERE AIRFLOWS ARE SHOWN ON NEW WORK PLANS, (RE)BALANCE AIR DEVICES TO THE INDICATED AIRFLOWS.
- 11 SPACES SERVED BY 2-PIPE COOLING-ONLY FCU HAVE EXISTING PERIMETER HEATING CONVECTORS. TEMPRAK WINTER DATA SUGGESTS THERE IS NO NEED TO REVISE EXISTING HEATING TO THE SPACE. SEE PIPING PLANS FOR CONVECTORS WORK.
- 12 CONTRACTOR RESPONSIBLE TO REMOVE EXISTING CEILING, REUSE AND REINSTALL TO GREATEST EXTENT POSSIBLE FOR LAY IN CEILINGS. GYP CEILINGS TO BE CUT AND PATCHED TO MATCH EXISTING. ALL SYSTEMS IN EXISTING CEILING TO REMAIN IN WORKING ORDER. ALL SPRINKLERS AND FIRE ALARMS IN AREA OF WORK TO REMAIN ACTIVE AT ALL TIMES.
- 13 REBALANCE DUCTED SYSTEMS IN SCOPE TO AIRFLOWS INDICATED ON DRAWINGS.
- 14 TEMPRAK SENSORS ARE PART OF AN EXISTING CAMPUS-WIDE INDEPENDENT TEMPERATURE AND HUMIDITY MONITORING SYSTEM. COORDINATE NEW AND REPLACEMENT SENSORS WITH THE VA TO ENSURE COMPATIBILITY.


KEYNOTES

- 1 REPLACE TEMPRAK SENSOR WITH NEW.
- 2 HUMIDIFIER MOUNTED AT 1'-0" BELOW THE CEILING. MOUNT THE UNITS HUMIDITY SENSOR ON WALL ABOVE THE TEMPRAK SENSOR, UNLESS OTHERWISE SHOWN. HUMIDIFIER SETTING SHALL BE 40 %RH.
- 3 PROVIDE AND INSTALL NEW DIGITAL THERMOSTAT CONNECTED TO BAS.
- 4 EXISTING TEMPRAK SENSOR SHALL BE LOCATED HERE. RELOCATE IF NECESSARY.
- 5 PROVIDE AND INSTALL ROOM PRESSURE SENSOR, SETRA LITE WITH VISUAL ALARM (OR EQUAL).
- 6 EXISTING THERMOSTAT SHALL BE LOCATED HERE. RELOCATE IF NECESSARY.
- 7 EXISTING DIFFUSER, RE-BALANCE AIRFLOW TO CFM SHOWN.
- 8 RELOCATED EXISTING THERMOSTAT SERVING (E)DHC.



Bldg 101-01-FIRST FLOOR HVAC PLAN

1
1/8" = 1'-0"



																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													</
--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----

REFER TO FACILITY'S INFECTION CONTROL AND RISK ASSESSMENT (ICRA) AND SPECIFICATION SECTION 01 25 26 (SAFETY REQUIREMENTS) FOR ADDITIONAL INFORMATION.

ALL WORK MUST BE COMPLETED WITHIN THE SPECIFIED TIME FRAME. A DETAILED WORK TIMELINE MUST BE ESTABLISHED AND SUBMITTED FOR REVIEW AND APPROVAL.

REFER TO ARCHITECTURAL FOR ADDITIONAL REQUIREMENTS.

MAINTAIN 6 IN MINIMUM CLEARANCE FROM RATED WALLS AND HVAC EQUIPMENT.

CONTRACTOR TO PROVIDE PROTECTIVE COVERINGS FOR ALL MANUAL VOLUME DAMPERS LOCATED ABOVE GYPSUM BOARD CEILINGS.

RUN/OUT BRANCH DUCTWORK TO SUPPLY DIFFUSERS, RETURN AND EXHAUST GRILLES TO BE INSTALLED TO MATCH EXISTING.

ALL BRANCH DUCTS TO DIFFUSERS, REGISTERS, AND GRILLES MUST BE INSTALLED WITH A VOLUME DAMPER.

DO NOT PLACE ANY RACKS OR SHELVES IN FRONT OF SENSORS OR HUMMERS. A MINIMUM CLEARANCE OF 18 IN FRONT OF THE HUMMER MUST BE MAINTAINED AT ALL TIMES.

THERMOSTAT SETTING WILL BE 68 DEG F FOR ALL STERILE STORAGE ROOMS.

WHERE AIRFLOWS ARE SHOWN ON NEW WORK PLANS, (RE)BALANCE AIR DEVICES TO THE INDICATED AIRFLOWS.


SPACES SERVED BY 2 PIPE COOLING-ONLY FAN HAVE EXISTING PERIMETER HEATING ELEMENTS. TEMPRAX TEMPERAT VOLUME DUCT SUGGESTS THERE IS NO NEED TO REVERSE EXISTING FAN TO REVERSE FLOW.

CONTRACTOR RESPONSIBLE TO REMOVE EXISTING CEILING, REUSE AND REINSTALL TO GREATEST EXTENT POSSIBLE FOR FAN IN CEILINGS. GYV CEILING TO BE CUT AND PATCHED TO MATCH EXISTING. ALL SYSTEMS IN EXISTING CEILING TO REMAIN IN WORKING ORDER. ALL FAN HUMMERS TO REMAIN IN WORKING ORDER.

REBALANCE DUCTED SYSTEMS IN SCOPE TO AIRFLOWS INDICATED ON DRAWINGS.

TEMPTRAX SENSORS ARE PART OF AN EXISTING CAMPUS-WIDE INDEPENDENT TEMPERATURE MONITORING SYSTEM. CONTRACTOR TO COORDINATE NEW AND REPLACEMENT SENSORS WITH THE VAO TO ENSURE COMPLETION.

- 1 EXISTING RETURN GRILLE: RE-BALANCE AIRFLOW TO 1400 CFM.
- 2 HUMIDIFIER MOUNTED AT 1'-0" BELOW THE CEILING. MOUNT THE UNITS HUMIDITY
3 SENSOR ON WALL ABOVE THE TEMPTRAK SENSOR, UNLESS OTHERWISE SHOWN.
4 HUMIDIFIER SETTING SHALL BE 40 %RH.
- 5 PROVIDE AND INSTALL NEW DIGITAL THERMOSTAT CONNECTED TO BAS.
- 6 PROVIDE AND INSTALL NEW TEMPTRAK SENSOR.
- 7 PROVIDE AND INSTALL ROOM PRESSURE SENSOR, SETRA LITE WITH VISUAL
8 ALARM (OR EQUAL).
- 9 EXISTING DRAWINGS INDICATE (7) EXISTING-TO-REMAIN DIFFUSERS TO BE 200
10 CFM- REBALANCE TO (6x)230 CFM, (1x)220 CFM.



1 Bldg 102-01-FIRST FLOOR HVAC PLAN
1/16" = 1'-0"

[illegible]

VA FORM 08-6231										
1	2	3	4	5	6	7	8	9	10	

- 1 REFER TO FACILITY'S INFECTION CONTROL AND RISK ASSESSMENT (ICRA) AND SPECIFICATION SECTION 01 35 26 (SAFETY REQUIREMENTS) FOR ADDITIONAL INFORMATION.
- 2 ALL WORK MUST BE SCHEDULED AND COORDINATED JOINTLY WITH THE OWNER. A DETAILED WORK SCHEDULE MUST BE ESTABLISHED AND SUBMITTED TO THE OWNER AND APPROVED.
- 3 REFER TO ARCHITECTURAL FOR ADDITIONAL REQUIREMENTS.
- 4 MAINTAIN A MINIMUM CLEARANCE FROM RATED WALLS AND HVAC EQUIPMENT.
- 5 CONTRACTOR TO PROVIDE REMOTE OPERATORS FOR ALL MANUAL VOLUME DAMPERS LOCATED ABOVE THE CEILING.
- 6 RUNOUT BRANCH DUCTWORK TO SUPPLY DIFFUSERS, RETURN AND EXHAUST GRILLES MUST BE THE SAME SIZE AS THE NECK SIZE ON THE AIR DEVICE UNLESS NOTED OTHERWISE.
- 7 ALL BRANCH DUCTWORK TO DIFFUSERS, REGISTERS, AND GRILLES MUST BE INSTALLED WITH VOLUME DAMPER.
- 8 DO NOT PLACE ANY RACKS OR BELTSTAYS IN FRONT OF SENSORS OR HUMIDIFIERS. A MINIMUM CLEARANCE OF 18 INCHES MUST BE MAINTAINED AT ALL TIMES.
- 9 THERMOSTAT SETTING WILL BE 68 DEG F FOR ALL STERILE STORAGE AREAS.
- 10 WHERE AIRFLOWS ARE SHOWN ON NEW WORK PLANS, (RE)BALANCE AIR DEVICES TO THE INDICATED AIRFLOWS.
- 11 FOR SERVICE OF 2 PIPE COOLING-ONLY FLOW EXISTING PERIMETER HEATING TO CONVECTORS. TEMPRAT VENTRATOR DATA SUGGESTS THERE IS NO NEED TO REVERSE EXISTING HEATING TO THE SPACE. SEE PIPING PLANS FOR CONVECTORS WORK.
- 12 REPAIR OR REPLACE EXISTING DAMPERS AND GRILLES TO MATCH EXISTING. REINSTALL TO GREATEST EXTENT POSSIBLE FOR LAY IN CEILINGS. GY GY CELINGS TO BE CUT AND PATCHED TO MATCH EXISTING. ALL SYSTEMS IN EXISTING CEILING TO REMAIN IN WORKING ORDER. ALL NEW GRILLES AND DAMPERS TO BE MATCHED TO EXISTING.
- 13 REBALANCE DUCTED SYSTEMS IN SCOPE TO AIRFLOWS INDICATED ON DRAWINGS.
- 14 TEMPRAT SENSORS ARE PART OF AN EXISTING CAMPUS-WIDE INDEPENDENT TEMPERATURE MONITORING SYSTEM. CONTRACTOR TO COORDINATE NEW AND REPLACEMENT SENSORS WITH THE VA TO ENSURE COMPATIBILITY.

1 RE-SET BOX AIRFLOW IN BAS PER EXISTING VAV SCHEDULE ON SHEET M-701
3 EXISTING RETURN AIR GRILLE, RE-BALANCE AIRFLOW TO CFM SHOWN.
4 PROVIDE AND INSTALL ROOM PRESSURE SENSOR, SETRA LITE WITH VISUAL
5 ALARM (OR EQUAL).
EXISTING EQUIPMENT.



1/4" = 1'-0"



1/4" = 1'-0"


$$1/16'' = 1'-0''$$
[illegible]

A

B

C


D

E


F

2/23/2024 11:32:18 AM

Autosave: Docs\\VLEB-016 Sterile Storage Improvements\\VLEB-016-MEP-24.rvt




4 Bldg 01-00 BASEMENT FLOOR PIPING PLAN - ROOM 51
1/4\"/>



2 Bldg 01-00 BASEMENT FLOOR PIPING PLAN - ROOM 16
1/4\"/>

3 Bldg 01-00 BASEMENT FLOOR PIPING PLAN - ROOM G036
1/4\"/>



1 Bldg 01-00 BASEMENT FLOOR PIPING PLAN
1/16\"/>

HYDRONIC GENERAL NOTES

- 1 REFER TO FACILITY'S INFECTION CONTROL AND RISK ASSESSMENT (ICRA) AND SPECIFICATION SECTION 01 35 26 (SAFETY REQUIREMENTS) FOR ADDITIONAL INFORMATION.
- 2 ALL WORK MUST BE SCHEDULED AND COORDINATED JOINTLY WITH THE MUST. A DETAILED JOB TIMELINE MUST BE ESTABLISHED AND SUBMITTED FOR REVIEW AND APPROVAL.
- 3 REFER TO ARCHITECTURAL FOR ADDITIONAL REQUIREMENTS.
- 4 MAINTAIN 6-IN MINIMUM CLEARANCE FROM RATED WALLS AND HVAC EQUIPMENT.
- 5 ALL BRANCH PIPING IS 3/4-IN UNLESS OTHERWISE NOTED EXCLUDING REFRIGERANT PIPING. REFRIGERANT PIPING SIZES MUST BE COMPLETED BY CONTRACTOR BASED ON MANUFACTURER'S RECOMMENDATIONS.
- 6 PROVIDE EXPANSION LOOPS, JOINTS, Z BENDS AND PIPING OFFSETS TO ACCOMMODATE THERMAL AND OTHER PIPING MOVEMENT.
- 7 CONTRACTOR RESPONSIBLE TO REMOVE EXISTING CEILING, REUSE AND REINSTALL TO GREATEST EXTENT POSSIBLE FOR LAY IN CEILINGS. GYP CEILINGS TO BE CUT AND PATCHED TO MATCH EXISTING. ALL SYSTEMS IN EXISTING CEILING TO REMAIN IN WORKING ORDER. ALL SPRINKLERS AND FIRE ALARMS IN AREA OF WORK TO REMAIN ACTIVE AT ALL TIMES.

KEYNOTES

- 1 CONNECT HUMIDIFIER/DEHUMIDIFIER DRAIN TO CONDENSATE DRAIN PIPING. CONFIRM THAT DRAIN PIPING BEING CONNECTED INTO IS MINIMUM 3/4\"/>
- 2 CONNECT HUMIDIFIER WATER SUPPLY TO EXISTING DOMESTIC COLD WATER PIPING IN WALL BEHIND DRINKING FOUNTAIN.
- 3 CONNECT HUMIDIFIER WATER SUPPLY TO EXISTING DOMESTIC COLD WATER PIPING IN WALL.
- 4 3/4\"/>
- 5 3/4\"/>
- 6 3/4\"/>
- 7 EXISTING PERIMETER HEATING CONVECTORS (WHERE APPLICABLE) - FIELD-VERIFY WHETHER SYSTEM IS STEAM OR HOT WATER. REPLACE EXISTING CONVECTOR VALVE WITH NEW CONTROL VALVE. WIRED TO AND CONTROLLED BY SAME THERMOSTAT AS THE COOLING-ONLY FCU.

A


B

C


D



E

F




		Consultant	Architect/Engineer of Record	Stamp	OFFICE OF CONSTRUCTION AND FACILITIES MANAGEMENT VA U.S. Department of Veterans Affairs	Drawing Title BUILDING 1 - BASEMENT FLOOR PIPING PLAN Approved:	Phase BID DOCUMENTS Sprinkler Status FULLY SPRINKLERED	Project Title STERILE STORAGE IMPROVEMENTS Location 1700 S LINCOLN AVE, LEBANON, PA 17042 Issue Date 11.17.25	Project Number VLEB-016 Building Number 1 Drawing Number 001-MP-100
#	Revisions							Checked TS	Drawn AC

[illegible]




- 1 3/4" CONDENSATE DRAIN CONNECT TO EXISTING CONDENSATE DRAIN PIPING.
- 2 CHWS/R PIPING CONNECT TO EXISTING PIPING.
- 3 3/4" HUMIDIFIER DRAIN CONNECT TO EXISTING CONDENSATE DRAIN PIPING.
- 4 1/2" CW PIPING CONNECT TO EXISTING PIPING.
- 5 EXISTING PERIMETER HEATING CONNECTORS (WHERE APPLICABLE) -
FIELD-VERIFY WHETHER SYSTEM IS STEAM OR HOT WATER. REPLACE EXISTING
CONNECTOR VALVE WITH NEW CONTROL VALVE. WIRED TO AND CONTROLLED BY
SAS THERMOSTAT AS THE COOLING-ONLY FCU.



(2)

3



4

1