

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE		PAGE 1 of 2 PAGES		
2. AMENDMENT/MODIFICATION NO. 0002		3. EFFECTIVE DATE March 12, 2026		4. REQUISITION/PURCHASE REQ. NO. PR15798237		5. PROJECT NO. (If applicable)	
6. ISSUED BY AMERICAN CONSULATE GENERAL JEDDAH Al Safa STREET, ATTN: GSO/PROCUREMENT JEDDAH SAUDI ARABIA		CODE 19SA40		7. ADMINISTERED BY (If other than Item 6) AMERICAN CONSULATE GENERAL JEDDAH Al Safa STREET, ATTN: GSO/PROCUREMENT JEDDAH SAUDI ARABIA		CODE 19SA40	
8. NAME AND ADDRESS OF CONTRACTOR (NO., street, city, county, State, and ZIP Code)				9a. AMENDMENT OF SOLICITATION NO. 19SA4026R0008			
				X 9b. DATED (SEE ITEM 11) January 27, 2026			
				10a. MODIFICATION OF CONTRACT/ORDER NO.			
				10b. DATED (SEE ITEM 13)			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
☐ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers X is extended, ☐ is not extended Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram, which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram Or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying Office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b)							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER							
E. IMPORTANT: Contractor ☐ is not, ☒ is required to sign this document and return 1 original copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this Amendment: - To Incorporate Questions and Answers - To extend the proposal submission due date from March 10, 2026, to March 30, 2026 by 5PM. No proposals shall be accepted after this time and date. Except as provided herein, all terms and conditions remain unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME OF CONTRACTING OFFICER Robert Blakeslee			
15B. NAME OF CONTRACTOR/OFFEROR SIGNED BY _____ (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA BY  (Signature of Contracting Officer)		16C. DATE SIGNED 03/12/2026	

Question and Answers RFP 19SA4026R0008 – PM services Switchgear

Q#	Question(s)	Government Response
1	Please confirm whether all circuit breakers will be tested during a single planned outage and mobilization, or if multiple mobilizations and phased outages are anticipated	Yes all breakers will be tested in single visit.
2	The scope specifies infrared (IR) scanning and functional/trip testing. Kindly confirm whether contact resistance testing is also required, and advise if any additional specialized testing is expected	All testing required in the scope of work are required in addition to manufacturer recommended testing.
3	If available, please share the latest Single Line Diagrams (SLD) and circuit breaker nameplate data for all listed equipment	Not possible at this time, SLD will be shared with the successful contractor.
4	Please provide the nameplate photos for all breakers	Not possible at this time, nameplate photo will be shared with the successful contractor.
5	Please confirm the suitable working hours for each switchgear to perform the annual site maintenance	Most of the work will happen during off hours such as weekend, however residential side circuit breakers will be maintained during normal weekdays.
6	Please confirm whether spare parts are included in the scope, or if the scope of work covers only the annual site maintenance	Contractor is responsible such as batteries and filters, refer to SOW.

END OF AMENDMENT