

AUTOMATIC AIR DAMPER SCHEDULE						
DESIGNATION	MANUFACTURER	MODEL	SIZE	MAX. CFM	VELOCITY	ACTUATOR
AAD-1	GREENHECK	VCD-20	24X18	2,000	600 FPM	24V
AAD-2	GREENHECK	VCD-20	24X18	2,000	600 FPM	24V
AAD-3	GREENHECK	VCD-20	24X18	2,000	600 FPM	24V
AAD-4	GREENHECK	VCD-20	24X18	2,000	600 FPM	24V
AAD-5	GREENHECK	VCD-20	24X18	2,000	600 FPM	24V
AAD-6	GREENHECK	VCD-20	24X18	2,000	600 FPM	24V
NOTES: DAMPERS SHALL BE NORMALLY CLOSED COORDINATE ACTUATOR MOUNTING WITH CONTROLS CONTRACTOR PROVIDE ACTUATORS WITH POSITIVE FEEDBACK						

UNIT HEATER SCHEDULE (ELECTRIC)								
DESIGNATION	MANUFACTURER	MODEL	DISCHARGE	MOUNTING HEIGHT	KW	VOLTAGE/ PHASE	TOTAL AMPS	NOTES
42-T-UH-001	INDEECO	UHIR	HORIZONTAL	9 FT	10.0	480/3	12.4	REFER TO BELOW
42-T-UH-002	INDEECO	UHIR	HORIZONTAL	9 FT	10.0	480/3	12.4	REFER TO BELOW
42-T-UH-003	INDEECO	UHIR	HORIZONTAL	9 FT	10.0	480/3	12.4	REFER TO BELOW
NOTES PROVIDE POWER DISCONNECT SWITCH PROVIDE CANTILEVER ARM UNIT CONTROLLED BY BUILDING JCI CONTROL SYSTEM PROVIDE 2 STAGE CONTROL								

DIRECT FIRED GAS FIRED MAKE UP AIR UNIT SCHEDULE																		
DESIGNATION	MANUF.	MODEL	SUPPLY FAN DATA						GAS DIRECT HEATING DATA						FILTER DATA		OPER. WEIGHT (LBS.)	VOLTAGE/ PHASE
			CFM TOTAL @ 5280'	CFM OA @ 5280'	ESP	DRIVE TYPE	APPROX. RPM	MIN. FAN HP	EAT	LAT	% EFF.	MBH INPUT	MBH OUTPUT @ 5280'	GAS PRESSURE	TYPE	PLENUM CURB HEIGHT.		
									°F DB	°F DB								
42-MAU-001	GREENHECK	DGX	12,000	12,000	0.25	DIRECT	1,272	5	0.7	104.0	92	1,200.0	1,104.0	5 PSIG	MERV-8	24	1,450	480/3

REVISION	DESCRIPTION	BY	SUPV.	DATE

DESIGN COOK	DRAFTING COOK	APPROVAL	DATE 3/10/2026	SHEET NUMBER M-4 of
PROJECT NAME ADDITIONAL TUNNEL HEAT				