

STATEMENT OF WORK

FOR

**ELECTRICAL
INDEFINITE DELIVERY/
INDEFINITE QUANTITY (ID/IQ)
CONTRACT**

AT

AIR FORCE TEST CENTER
EDWARDS AIR FORCE BASE, CALIFORNIA
22 APR 2025

FA9301-XX-X-XXXX

412 CES/COER

TABLE OF CONTENTS

1.0 SCOPE OF WORK	3
2.0 PROJECT REQUIREMENTS	3
3.0 CONTRACTOR PERSONNEL	4
4.0 OFFICE SITE	6
5.0 PERFORMANCE TIMES	6
6.0 SUBMITTALS	7
7.0 STANDARD PRODUCTS	7
8.0 BASE REQUIREMENTS	8
9.0 GOVERNMENT FURNISHED ITEMS	13
10.0 CONTRACTOR FURNISHED ITEMS AND SERVICES	13
11.0 CONDITIONS OF WORK	13
12.0 CONSTRUCTION SITE MAINTENANCE	14
13.0 INSPECTIONS, QUALITY CONTROL, WORKMANSHIP, AND TESTING	15
14.0 WARRANTY	16
15.0 ORDERING PROCEDURES	16
16.0 TASK ORDER PRICING	18
17.0 COMMENCEMENT, PROSECUTION, COMPLETION, AND PAYMENT FOR WORK	19
ATTACHMENT 1 - QUALITY CONTROL PLAN	23
APPENDIX A - TYPES OF WORK	26
APPENDIX B - MAPS	27
APPENDIX C – SECURITY REQUIREMENTS	31
APPENDIX D – LIST OF ACRONYMS	35

1.0 SCOPE OF WORK:

- 1.1** This is an indefinite delivery/indefinite quantity (ID/IQ) contract for Electrical requirements at Edwards Air Force Base (AFB), California including the Air Force Research Laboratory (AFRL), Air Force Plant 42 (in Palmdale, CA), and other tenant organizations. The Contractor shall furnish all management, personnel, vehicles, supplies, equipment, etc. required to perform work such as, but not limited to: pulling wire, repairing panel boards, rough electrical, finish electrical, replacing inspecting electrical systems and components, providing blueprints, electrical studies, electrical equipment, bending conduit, removing and replacing worn out relays, lifting heavy objects, repairing sophisticated objects, transformers, switches, design studies and support, disconnects, switchgears, generators, automatic transfer switches, uninterrupted power supply (UPS's), communication wires, fire protections system, cathodic protection systems, Electrical coordination studies including load studies; Lightning protection systems and other electrical projects. All electrical work must comply with industry standards, Unified Facility Criteria (UFC) UFC 3-501-01 (Electrical Engineering), UFC 3-550-01 (Exterior Power Distribution), UFC 3-560-01 (Operation and Maintenance), IEEE Std. 979-2012 (Guide for Substation Protection), NEC, NFPA, NESC and other applicable UFCs and provide 1-year No Dollar Limit warranties for work. Additionally, work may include but is not limited to lead and asbestos abatement, equipment, disconnect/movement, repair, and installation. Military Family Housing at Edwards AFB is privatized and excluded from the scope of this contract.
- 1.2** Electrical IDIQ contract shall also include the repair, alteration, maintenance, and new installation of electrical systems (up to 34.5 kV), grounding systems, Airfield lighting, fire alarm, Energy Management and Control System (EMCS), Supervisory Control and Data Acquisition (SCADA) systems, generators, lightning protection, cathodic protection, and associated works at Edwards AFB, California. The primary discipline will be electrical to include ancillary work in other fields such as civil engineering. Projects will be awarded by individual task orders on an as-needed basis in support of real property repair, alteration, maintenance, and new installation. This contract may be used for non-appropriated fund (NAF) projects (for the aforementioned systems) on Edwards AFB which do not become an obligation of the United States Government.
- 1.3** Task Orders (TOs) will be issued against the basic contract and will be executed in accordance with (IAW) the basic contract's terms, conditions, and this Statement of Work (SOW), as well as each individual TO's SOW, required submittals, and any other items identified in each TO. The Contractor shall submit an Air Force Form 813 or work order for environmental review for each individual task order. Contractor shall comply with all measures listed on the most current Minimization Measures list for the life-cycle of this contract and as identified in each individual AF Form 813 or work order. The Minimization Measures and signed AF Form 813 will be provided by the Government with each SOW and/or task order.
- 1.4** The following intent is provided within this document to assist the Contractor with understanding the purpose of this SOW. The below sections are not intended to provide a minimum or maximum amount of work required. Specific scopes of work will be provided in individual TOs. The Contractor's proposed materials, means, and methods for individual TOs can and are expected to exceed the minimum requirements but are subject to Government review and approval.
- 1.5** For detailed description of work to be performed the contractor should refer to Appendix A denoted as Types of Work

2.0 PROJECT REQUIREMENTS:

- 2.1** Location and Site Plan: Edwards AFB is comprised of main base and the Air Force Research Laboratory (AFRL). The work under this contract includes these areas as well as all other areas within the Base and Air Force Plant 42 in Palmdale, CA. The location and site plan for each project will be provided with each TO's Request for Proposal (RFP).
- 2.2** All Contractor work shall meet quality standards listed in manufacturers' instructions and shall follow the manufacturers' recommended application methods. It is the Contractor's

responsibility to ensure that all work performed is in accordance with (IAW) all Air Force, Federal, state, county, and local statutes, laws, codes, regulations, safety requirements, instructions, manuals, handbooks, guidance and policy letters. The specifications and standards set forth in the terms and conditions of this contract, and subsequent TOs which include, but are not limited to, the National Emission Standards for Hazardous Air Pollutants (NESHAP), Environmental Protection Agency (EPA) Regulations and Codes, Unified Facilities Guide Specification (UFGS) Codes, American Society for Testing and Materials (ASTM), National Fire Protection Association (NFPA), National Electrical Code (NEC), International Building Code (IBC), International Mechanical Code (IMC), EAFB Design Standards, and Asbestos and Lead Management Plans. It is the Contractor's responsibility to ensure that all subcontractors have proper permits, notifications, manufacturer certifications/agreements, and appropriate general and state licenses required to fulfill the requirements described in this SOW.

- 2.3** The scope of work requires the Prime Contractor to hold a California Contractors State License Board issued class B contracting license. The Prime Contractor shall have the capability to accomplish electrical services with electrical subcontractors if the subcontractors hold a class C10 contracting license. Additionally, the Prime Contractor has the capability to subcontract in any specialty area, as long as subcontractors have the right licenses for specialty areas.

- 2.3.1** The Prime contractor shall submit proof of California Contractors State License Board issued class B and class C10 (for any subcontractors) contracting licenses, to the Contracting Officer (CO) within 45 calendar days after date of contract award.

3.0 CONTRACTOR PERSONNEL:

- 3.1** The Contractor shall perform adequate background checks on all employees to validate U.S. citizenship, or to validate that employees are legally allowed to work in the U.S. Employees shall not have prior felonies or outstanding warrants of any kind. Naturalized citizens are required to bring their naturalization certificate to be eligible to apply for a Base access pass IAW DFARS 252.203-7001, Prohibition on Persons Convicted of Fraud or Other Defense Contract-Related Felonies.

- 3.2** The Contractor shall ensure that all employees and subcontractor employees have current, valid licenses and certifications necessary to perform their functions. Any cost or time associated with obtaining licenses or certifications shall be at the Contractor's expense.

- 3.2.1** All work shall be performed in a professional manner by journeyman craftsmen certified in the trade in which they are employed.

- 3.2.2** The Contractor shall ensure that all employees are trained and qualified to operate specialized equipment such as a scissor lift, "hi-lo", welder, or any other specialized equipment as required by industry standards. The Contractor shall provide proof of qualifications and/or certifications to the CO when requested.

- 3.2.3** The Contractor shall immediately replace any individual not acceptable to the Government as directed by the CO.

- 3.2.4** The Contractor shall not employ any person who is currently or formerly an employee of the U.S. Government, if the employment of that person would create a conflict of interest.

3.3 Contract Manager.

- 3.3.1** The Contractor's Contract Manager (CM) shall be responsible for the overall performance of this contract and shall possess the necessary experience to provide direct oversight of all project design and planning activities. The CM shall have full authority to act for the Contractor. The CM shall provide overall contract management, including full authority to develop TO proposals, negotiate and sign TOs, and provide subcontract purchasing and administration. The CM and alternates, who shall act for the Contractor when the CM is absent, shall be designated prior to commencement of work in writing to the CO. Subcontractors may not perform duties of the CM.

The CM shall be able to speak, understand, and read the English language. The CO must be able to contact the CM at any anytime by phone or e-mail to discuss any project.

3.4 Superintendent.

3.4.1.1 The Contractor's Superintendent shall provide on-site supervision and visit each active project site daily; submit periodic detailed progress reports (AF Form 3065) for each TO; review material submittals; schedule and coordinate subcontractor and material suppliers, site visits, and inspections; and attend all status meetings, site visits, and pre-final/final inspections as required. Subcontractors may not perform duties of the Superintendent. The Superintendent shall be on-site during normal work hours and for contingencies requiring work beyond normal work hours. The Superintendent shall be able to speak, understand, and read the English language. The Superintendent shall ensure that a complete, current set of the contract documents and approved submittals are available at the jobsite at any given time.

3.4.1.2 Throughout the life of this contract, whenever there are active TOs, the Superintendent shall be available to meet within 120 minutes of notification by the CO or Government Program Manager (GPM) regarding any active project, and the CO must be able to the superintendent at any given time by phone or e-mail. If there are multiple projects taking place at once, the Superintendent shall be present at the project that is most complex and/or has the highest visibility per the GPM.

3.5 The Contractor shall provide and maintain the following capabilities, at a local or remote office, to support this contract:

3.5.1 Cost Estimating/Negotiating. The Contractor shall provide estimating/negotiating support capable of producing accurate quantity reductions and cost proposals, within the time constraints specified.

3.5.2 The contractor shall be able to provide a cost estimate with broken-down itemized list of services and products provided utilizing RSMeans software.

3.5.3 Copying and Reproduction Capabilities. The Contractor shall be able to copy or reproduce all necessary drawings and contract documents required to support TOs.

3.6 Subcontractors.

3.6.1 All subcontractors shall be licensed in the State of California in all the applicable disciplines as per required.

3.6.2 The Contractor shall coordinate the work of subcontractors and shall ensure coordination of work between various trades. The Contractor is responsible for any subcontractor's work performed. The Contractor shall study, examine, and evaluate the contract drawings to establish the work, coordination, or materials required and necessary to provide a product complete in the usual and customary manner, and shall provide for all such requirements as though expressly detailed herein or on the drawings.

3.7 Labor Requirements. The Contractor shall abide by the labor requirements/statutes required IAW with Federal Acquisition Regulation (FAR) 22.403 and FAR 22.10. A total of four wage determinations (to cover Kern County if work takes place at Edwards AFB and Los Angeles County if work takes place at Air Force Plant 42, which will be specified on individual TOs) apply to this contract and will be attached to the basic contract, to be used on all TOs issued against the basic contract.

3.7.1 The Construction Wage Rate Requirements Statute (formerly known as the Davis-Bacon Act) will apply to all construction work, e.g. repair or replacement.

3.7.2 The Service Contract Labor Standards (formerly known as the Service Contract Act) will apply to service work, e.g. maintenance.

3.7.2.1 The total value of maintenance services in this contract, as defined at FAR 37.101, shall be less than the Simplified Acquisition threshold (SAT, \$250,000) is subject to AFI 63-138,

Acquisition of Services (see AFI 63-138 para 1.2.2.2), and would require a Performance Based Work Statement.

4.0 OFFICE SITE:

- 4.1** Contractor's Row. A designated lot on Contractor Hill Road (also known as Contractor's Row) will be provided as the official area for the Contractor and is required for the performance of this contract. A specific space assignment will be designated after the award. This designated lot on Contractor Hill Road will be used for the Contractor's office trailer, vehicle parking, and supply storage. The Contractor shall provide a field office for their use. The Contractor shall be responsible for the connection of all utilities. Costs incurred in connection with the facility shall be paid by the Contractor. The field office shall comply with all applicable codes, regulations, and Base standards. The location, type, proposed maintenance, and other considerations shall be approved by the GPM prior to moving onto the site. At the completion of the contract, the facility shall be removed from Edwards AFB and the area restored to the condition existing prior to the start of the contract. The Government will only provide fire prevention and protection services.
- 4.2** The Contractor shall contact Environmental Management at (661) 277-9223 or 277-1401 at least 7 days prior to occupying the space to schedule a move-in visual site inspection (VSI). The Contractor shall contact Environmental Management at least 30 days prior to vacating the premises to schedule a close-out VSI and obtain environmental clearance. The VSI is used to assess any environmental damage caused by the contractor's occupancy. The Contractor shall be responsible for mitigating environmental impacts caused by their occupancy. The Contractor must ensure to always maintain environmental compliance at any given time in accordance with federal, state and local requirements and will be subject to announced and unannounced inspections by The Civil Engineering Group (412 CEG/CEVC), local, state and federal authorities.
- 4.3** The site office shall be manned as necessary as stated in Section 17.0 and shall have the Site Superintendent or CM on-site whenever there are active TOs.
- 4.4** Following contract expiration and/or written direction from the CO, whichever comes first, the Contractor shall vacate their office on Contractor's Row and have a fully operational temporary field office with all required facilities, staff, and capabilities to facilitate the completion of any outstanding TOs.
- 4.5** Once the performance period of the contract has ended and before the final payment is paid on the last TO, the Contractor shall contact the Civil Engineering (CE) Community Planner to schedule a move out inspection prior to them leaving the site. Under no circumstances shall any trailers, portable buildings, conex type facilities, or any other structures be left on-site once the contract has been completed. In addition, no waste or excess materials of any kind, non-hazardous or hazardous, will be left on site. The site will be reverted to its original condition prior to its current use. Before departure, the Contractor shall contact the CO, GPM, and the CE Community Planner for the final move out inspection before leaving the Base. Any deficiencies noted shall be corrected by the departing Contractor before vacating the space. Any uncorrected deficiencies could delay final payment on the final TO.
- 4.6** The Contractor shall notify the Environmental Management Division (412 CEG/CEV) at (661) 277-1401 (option 1) prior to installing any storage tanks on the installation. Contractors owning, operating, or procuring any storage tanks for use on the installation will comply with all federal, state, and local requirements. Contractors shall comply with the *Edwards AF Base Spill Prevention, Control, and Countermeasure Plan* for all petroleum storage tanks used on the installation. Upon installation of a tank, the Contractor shall send an email notification (including tank specification information) to 412CEG.CEVC.WastewaterPOLTanks@us.af.mil to facilitate California Environmental Reporting System (CERS), Storage Tank Accounting and Reporting (STAR), and the Spill Prevention Control and Countermeasure (SPCC) Plan update requirements. The Contractor shall appoint a tank custodian, provide required training, gain access to STAR, and capture monthly inspections in STAR. 412 CEG/CEV can assist the appointed tank custodian with training and obtaining STAR access.

5.0 PERFORMANCE TIMES:

- 5.1** The Government's preferred total period of performance (PoP) will depend on the individual TO and will be specified in the RFP. The Contractor may propose a shorter or longer PoP in their proposal. Should the Contractor propose a longer PoP, the proposal must include justification for the longer PoP. The final PoP duration will be discussed during negotiations with the Contracting Office. The Contractor shall proceed with the project as stated in the TO's SOW after the Notice to Proceed (NTP) is provided by the Government. The Contractor shall not postpone or interrupt their work performance unless official notice, to that effect, is provided to them by the CO.
- 5.1.1** The Contractor shall be able to handle anywhere from 10 to 20 projects concurrently and in multiple locations (main base, north base, south base, AFRL, AF Plant 42, etc.).
- 5.1.2** Performance periods shall not be extended due to insufficient resources.
- 5.2** TO projects shall start no later than 10 days following the issuance of the NTP. Construction shall not be permitted to commence until submittals specified at the TO level have been reviewed by the Government and clearance issued to start construction.
- 5.3** The first 30 calendar-days following basic contract award shall be designated as a start-up period, after which the Contractor shall have all equipment and personnel in place to fully execute the requirements of this contract. The Government will conduct an indoctrination (Pre-Construction Conference) with the Contractor to cover ordering procedures, security requirements, environmental requirements, etc. following the award of the basic contract.

6.0 SUBMITTALS:

- 6.1** The AF Form 66, Schedule of Material Submittals, will be issued with each TO's RFP and will be incorporated as an attachment to each TO. The AF Form 66 will include all desired material submittals along with respective due dates for a specific TO. If a copy of the AF Form 66 is not provided with the awarded TO, the Contractor shall request a copy from the Contracting Office.
- 6.1.1** Once an individual TO is awarded, the Contractor shall submit all required material/shop drawing submittals to the CO within 10 calendar days for approval. No materials shall be used prior to approval.
- 6.1.2** All material submittals indicated on the AF Form 66 shall be attached to an AF Form 3000, Material Approval Submittal, with the TO project title, project number, and TO number clearly indicated. Three copies of each submittal shall be submitted to the CO for approval; one copy will be returned to the Contractor and shall be posted by the Contractor at the jobsite. The Contractor may submit a catalog of standard material data sheets for selected items that are used repetitively for TOs. The catalog number for these items can be referenced on the AF Form 3000 without attaching copies of the data sheets. Submittals shall be legible and shall include all technical data needed to verify that the item meets the requirement including but not limited to estimated quantities of paints/coatings to be used, data sheets showing the specific gravity, mix ratio, volatile organic compound (VOC) content, vapor pressure, and hazardous air pollutant (HAP) content of all coatings and solvents.
- 6.1.3** The Contractor shall submit as-builts upon completion of TOs when specified.
- 6.2** The contractor shall comply with Unified Facility Criteria (UFC)-Criteria for Transfer and Acceptance of DoD Real property-UFC 1-300-08. The Contractor is responsible for all such materials that are provided from Contractor-furnished supplies and materials brought to the job site by the Contractor, and for any such materials identified herein or by the drawings for individual TOs, during the performance of this contract. Any clarifying question should go via project manager to base real property office.
- 6.3** Payrolls. In accordance with FAR Clause 52.222-8, Payrolls and Basic Records, the Contractor must submit to the CO copies of payrolls applicable to each TO for each week in which any contract work is performed as well as weekly payroll statements of compliance for the Contractor and each

Subcontractor. The Contractor may use the U.S. Department of Labor form WH-347, Payroll, or a similar form that provides the same data and identical representation. The WH-347 form can be found at <http://www.dol.gov/whd/forms/wh347.pdf>. If the WH-347 form is used, a DD Form 879, Statement of Compliance, does not need to be provided; the DD Form 879 is only required if the WH-347 form is not used. The Prime Contractor is responsible for making sure the submittals are correct before submitting them to the CO. Failure to submit payrolls may cause delays in payment. The final payroll must be marked "FINAL". This information and a sample of the DD Form 879 will be included in each TO's Pre-Construction Letter, issued with the NTP.

7.0 STANDARD PRODUCTS:

- 7.1** Materials and equipment shall be standard products of a manufacturer regularly engaged in the manufacture of such products, which are of a similar material, design, and workmanship. The Contractor shall furnish a Safety Data Sheet (SDS), Occupational Safety and Health (OSHA) Form 20 or an accepted equivalent, for each hazardous or potentially hazardous material or chemical utilized by the Contractor. This includes solvents and treated materials, such as preservative treated wood (SDS for the preservative) or fungicide treated rubber goods (SDS for fungicide). The CO and GPM must approve all materials prior to installation.
- 7.1.1** Green Procurement. The Green Procurement Program (GPP) is a mandatory federal acquisition program that focuses on the purchase and use of environmentally preferable products and services. Many different items are covered by the GPP. Recycled-content products are designated by the Environmental Protection Agency (EPA). "Bio-based" products made from renewable plant materials are designated by the United States Department of Agriculture (USDA). Energy and water efficient products are designated by the Department of Energy (DOE). GPP also requires the Government to avoid purchasing Ozone Depleting Substances (ODS) and EPA-designated Priority Chemicals. Environmentally preferable purchasing (EPP) is a voluntary program, and it encourages the purchase of goods and services that have decreased effects on human health and the environment (compared to the competing goods and services that serve the same purpose) but are not already required by one of the mandatory GPP elements.
- 7.1.1.1** The EPA promulgates this product information via the Federal Register at <http://www.epa.gov/cpg/products/html>. Green Procurement is mandated except when the Contractor can show that the product with recycled content does not meet intended specifications, has excessive cost, or cannot be delivered in time to support the schedule of the contract. If the Contractor is unable to locate a specified product meeting the GPP requirement, identify the issue to the CO or GPM for guidance. GPP is based on legal requirements and the Department of Defense facilities are subject to enforcement action if these requirements are ignored.
- 7.1.1.2** The Contractor shall make maximum use of products containing recovered materials that are EPA-designated items IAW FAR Clause 52.223-17, Affirmative Procurement of EPA-Designated Items in Service and Construction Contracts. The list of EPA-designated items is available at <http://www.epa.gov/epawaste/conservation/cpg/index.htm>.
- 7.2** Technical instructions pertaining to the use or installation of products, materials, or equipment used or installed in the execution of work under this contract are furnished in response to a requirement stipulated herein and form a part of these specifications as though specifically set forth herein. In the event of conflict between the specifications or drawings and technical instructions, the Contractor shall bring such conflict to the attention of the CO for resolution before proceeding with the work involved.
- 7.3** Non-Restrictive Specifications. References in the design specifications of this SOW and each TO's SOW to equipment, material, articles, or patented processes by trade name, make, or catalog number shall be regarded as establishing a standard of quality and shall not be construed as limiting competition. The Contractor may, at its option, use any equipment, material, article, or process that, in the judgment of the CO, is equal or exceeds the requirement

of these specifications, unless otherwise specifically provided in this SOW or individual TO SOW.

- 7.4 Prohibited Materials.** The Contractor shall certify that products do not contain mercury, hexavalent chromium, toluene, chlorinated solvents, hydrolysable chlorine derivatives, ethylene based glycol ethers and their acetates, nor any carcinogen. When tested, the lead content shall not exceed 0.06% by weight of the dry film and the test for chromium content shall be negative. Additionally, prohibited are any devices determined by Security Forces. All products shall be American made.
- 7.5** Products specified in Air Force Instruction AF 32-1001, AFI 32-9005, AFI 32-9001, UFC 3-550, UFC 3-540 are to be acceptable manufacturers and are the only acceptable products that can be used in performance of this contract.

8.0 BASE REQUIREMENTS:

- 8.1 Base Access.** The Contracting Office shall control base access and issue an AFMC Form 496, Application for AFMC Identification Card, for the Contractor and any subcontractors. Upon award of the contract, the Contractor shall submit an AFMC Form 496 for each individual who requires base access to the CO. Base access for Contractors performing on long-term contracts is authorized for up to one year, so the AFMC Form 496 will need to be accomplished on an annual basis through coordination with the Contracting Office. Visitors must report to the Visitor Control Center, located prior to the West Gate checkpoint, for initial access.
- 8.1.1** The Contractor shall comply with all security requirements imposed by the Installation. Specific security considerations will be handled on an individual task order basis as required. Air Force Federal Acquisition Regulation Supplement (AFFARS) Clause 5352.242-9000, Contractor Access to Air Force Installations, will be incorporated in full text, in order to implement the specific security requirements for this contract.
- 8.1.2** Restricted Area and Special Access Programs. The number of restricted area badges will be limited as determined by the Civil Engineering Security Manager.
- 8.1.3** All Contractor employee's identification badges shall be returned to the CO prior to leaving the Base upon completion of the contract. Failure to return ALL identification badges may result in withholding of funds due until such identification badges are returned.
- 8.2 Waste.** The Contractor shall be responsible for the collection and disposal of all debris, rubble, residue, and waste material generated in the performance of work under this contract. The Contractor shall remove and dispose of legally and properly all such materials from the installation. The Contractor is not permitted to deposit any such materials in base trash collection containers or at any on-base location without prior approval of the CO.
- 8.3 Hazardous Materials.**
- 8.3.1** Materials classified as hazardous by U.S. and California environmental rules, regulations, or laws shall be handled for disposal IAW those rules, regulations, or laws. Any cost provisions to meet these requirements shall be the sole responsibility of the Contractor. Any project delay to meet these requirements shall also be the sole responsibility of the Contractor.
- 8.3.2** The Contractor shall ensure all hazardous materials (HM) are authorized and managed in compliance with FAR Clause 52.223-3, Hazardous Material Identification and Material Safety Data, FAR Clause 52.223-5, Pollution Prevention and Right-to-Know Information and applicable sections of Air Force Manual 32-7002, Environmental Compliance and Pollution Prevention, and Edwards AFB HM policy, to ensure compliance with Emergency Planning and Community Right-to-Know Act of 1986 (42 U.S.C. 11001-11050), and Pollution Prevention Act of 1990 (42 U.S.C. 13101-13109).
- 8.3.3** For all chemicals/materials (paints, adhesives, solvents, lubricants, cleaners, etc.) procured for this project by any means other than installation HAZMART, the Contractor shall provide the following to the Contracting Officer Representative (COR), at least 45 days prior to the

start of the project:

- Completed Contractor Hazardous Materials Usage Tracking Form
- Current Safety Data Sheets

8.3.4 The Contractor shall continue to provide material usage updates to the COR by the 5th of each month until the term of Contract. The COR will forward all contractor provided information to the 412CEG/CEVC HM Program Manager. For guidance regarding tracking of HM, usage and regulatory requirements, or questions regarding completing this form, contact the Edwards AFB Environmental Management Office at (661) 277-1401 or email 412CEG.CEVC.HMWorkflow@us.af.mil. For questions concerning projects at AFRL, call (661) 277-5135.

8.3.5 The Contractor is responsible for all such materials that are residue from Contractor-furnished supplies and materials brought to the job site by the Contractor, and for any such materials identified herein or by the drawings for individual TOs.

8.4 Security, Vehicles, and Parking.

8.4.1 The Contractor shall follow existing security and parking procedures and instructions applicable to Edwards AFB and AF Plant 42.

8.4.2 The Contractor shall be responsible for the physical security of all materials, supplies, and equipment, including property that is being utilized.

8.4.3 The Government shall not be held liable for any delays prior to the Contractor reaching the gate and notification that he is ready to proceed through the gate.

8.4.4 The Contractor's employees, suppliers', and subcontractor's vehicles shall not be parked on grass/landscaped surfaces at any time. In addition, vehicles may not be driven over grass/landscaped surfaces, unless indicated and approved by the GPM during the site visit or pre-construction conference.

8.4.5 Contractor vehicles shall be in top repair and be able to be shut off and restarted without outside aid. Vehicles in need of repair shall be replaced not later than the following morning. Downed and unrepairable vehicles must be removed from the Base. If necessary, the Contractor shall provide a flatbed trailer and rig or a tow truck at their cost to remove the vehicle from the Base. Vehicles will always be in safe operating conditions, have seatbelts, or will be denied access to the Base. At no time will Contractors perform routine maintenance on vehicles, which would result in the dumping of any fluid onto the ground. Contractor shall not transport rollers, paving equipment, or other slow moving construction equipment on and throughout Edwards AFB or AF Plant 42 unless it is loaded on a flatbed or lowboy.

8.5 Vehicular Traffic.

8.5.1 Traffic Control Devices. The Contractor shall comply with the local laws and regulations, to include Air Force regulations, regarding the safe operation of equipment in and around roadways associated with the construction site. Contractor owned and/or operated vehicles violating speeding, parking, or traffic regulations on Federal Government grounds property may be removed from the installation at the Contractor's expense. Should this be the case, the Government will not be held liable for the time delay to the Contractor nor such costs that might occur based on the vehicle removal.

8.5.1.1 The Contractor shall coordinate to ensure proper warnings to motorists are posted and adequate traffic control is used when vehicles are present. This will be coordinated with the Contracting Office and approved by the GPM.

8.5.1.2 The Contractor shall address known traffic impedances within the site/location drawing and the safety plan. Coordinate submittal dates per the AF Form 66.

8.5.1.3 Signs, warning lights, barricades, and other traffic control devices shall be provided by the Contractor. Warning lights will be operational at all times during non-daylight hours. Barricades shall be highly luminescent and clearly visible at night. Signs shall also be highly luminescent, blaze orange in color with black lettering, and be clearly visible from at least 50ft (15m) away.

8.5.1.4 Temporary traffic control signs (warning and hazard signs) shall be furnished and installed, at the discretion of the GPM, by the Contractor while projects are underway. These warning signs shall be placed near the beginning of the work site and well ahead of the work site for alerting approaching traffic from both directions. Slow-moving equipment shall be marked with large warning signs indicating slow-moving equipment in operation.

8.5.1.5 Road Diversions/Closures. The Contractor shall notify the GPM at least 15 business-days prior to work if construction will impact traffic on the roadways. The Contractor shall state in writing the exact dates of the road closure, duration of closure, and provide a traffic diversion map showing the location of the diversion (if available), closure, posting of signage, phasing plan (if applicable), and other pertinent information for the impedance.

8.5.1.6 All costs including, but not limited to, design, procurement, equipment, installation, maintenance and removal, associated with the temporary traffic control signs, barriers, barricades, warning lights, diversions, etc. are the sole responsibility of the Contractor.

8.6 Sanitary Provisions. The Contractor shall provide temporary toilets that satisfy Edwards AFB requirements for the use of project personnel. Location, type, proposed maintenance, etc. shall be approved by the GPM prior to placing toilets. Temporary toilets shall be removed at the completion of the project. All costs incurred in connection with the temporary toilets shall be paid by the Contractor.

8.7 Pollution Abatement. The Contractor shall perform work IAW Air Force, Federal, state, and local environmental regulations so as to minimize pollution, degradation, and exploitation of the environment. The Contractor shall also demonstrate leadership in preventing, controlling, and abating environmental pollution by supporting regional pollution abatement programs and by accelerating corrective measures to meet established standards and criteria.

8.8 Fire Prevention.

8.8.1 The prevention of fire is imperative during construction projects. The Contractor is responsible for enforcing fire safety in the work area.

8.8.2 The Contractor must report all fires to the Edwards AFB Fire Department. The Contractor must attempt to extinguish the fire only if it is safe to do so; go to the nearest phone and notify the Fire Department at 911 and have someone meet the Fire Department upon arrival to provide additional information.

8.8.3 The Contractor shall have serviceable fire extinguishers readily available at all times.

8.8.4 Burning trash and rubbish at the construction site is strictly prohibited.

8.8.5 The Contractor may not use gasoline or diesel fuel for cleaning parts or surfaces.

8.8.6 Electrical extension cords may be used on a temporary basis to power tools and equipment. Do not overload extension cords. Frayed, cut, or spliced extension cords are prohibited.

8.9 Site Safety.

8.9.1 Fire, Environmental, and Public Health Inspections. At any time, the construction site and laydown yard (if applicable) can be inspected by the CO or designated representative for fire, safety, environmental, or public health discrepancies. Any discrepancies noted shall be fixed immediately. If discrepancies cannot be fixed immediately, the Contractor shall remove the items from the installation. Any costs or time delays associated with correcting discrepancies are the sole responsibility of the Contractor.

- 8.9.2** The Contractor shall assume full responsibility and liability for compliance with federal, state and local laws, and Air Force Instructions for the protection of their employees while working on an Air Force Installation or property during the execution of work and shall hold the Government harmless for any action on his part or that of his employees or subcontractors, which results in illness, injury, or death.
- 8.9.3** The Contractor will be required to follow current Health Protection Condition (HPCON) restrictions and sanitization procedures to include social distancing and wearing of Center for Disease Control (CDC) - Approved face masks must be worn while conducting business on the base or test locations to maintain personal and public health and safety, unit public health and HPCON restrictions advise otherwise.
- 8.9.4** The Contractor shall comply with all pertinent provisions of the latest version of U.S. Army Corps of Engineers Safety and Health Requirements Manual, EM 385-1-1, IAW FAR Clause 52.236-13, Accident Prevention. Where there is a conflict between applicable regulations, the most stringent shall apply. The Contractor or any of his subcontractors who are responsible for handling hazardous and toxic materials shall have the necessary certification before doing so and shall provide evidence of certification to the CO and GPM upon request.
- 8.9.5** The Contractor shall conduct initial and periodic safety training for their employees and ensure that all subcontractor employees have had proper safety awareness training. When a contractor will perform work that involves a permit-required confined space entry, the CO or GPM will ensure compliance with the criteria in AFMAN 91-203, 23.8 and the Master Entry Plan of the unit controlling the space. While contractors are responsible for the rescue of their personnel, they must be advised that 911 calls will be routed back to Edwards AFB Fire Department Emergency Operations Center. To prevent potential delays, notify the Fire Department at (661) 277-4540/4541 prior to and after entry.
- 8.9.6** The Contractor shall establish and maintain a safety plan to ensure the safety requirements of the contract are provided as specified. The safety plan shall be provided as specified and submitted to the CO within 30 calendar days after the contract award. The Safety and Health Plan must include site-specific mishap reporting procedures for incidents which result in damage to Government property or injury to Air Force personnel.
- 8.9.7** The safety plan shall be subject to Government approval by the CO. The contractor is responsible for establishing these requirements for all subcontractors who qualify as subcontractors under the resulting contract. Contractor compliance with the safety plan will be monitored by the Government.
- 8.9.8** The Contractor shall record and report to the CO and GPM within one hour of occurrence all available facts relating to each instance of injury to either the Contractor, subcontractor, or Government personnel, or damage to Government property. In the event of an accident or mishap, the Contractor shall take prudent and reasonable action to establish control of the accident or mishap scene until relieved by the CO and GPM. If the Government elects to conduct an investigation of the accident or mishap, the Contractor and/or subcontractor shall cooperate fully and assist Government personnel in the investigation until such is complete
- 8.9.9** Explosive Operated Hand Tools. Explosive operated hand tools shall not be used without previous approval of the GPM. The Contractor shall comply with all OSHA standards when utilizing explosive operated hand tools. Storage of explosive cartridges on Edwards AFB will be in metal containers and limited to one day's supply. The Contractor shall provide adequate controls to prevent theft/loss of cartridges used and stored on the installation.
- 8.9.10** Use of Electromagnetic Emission Devices. Electromagnetic emission devices include radio/RADAR transmitters, navigational aids, instrumentations, signaling, intrusion detection and identification devices, mobile and fixed business radio communication equipment, Military Affiliate Radio Systems, Citizen's Bands (CBs), and amateur radio stations. Use of these devices must be coordinated with 412 TW Weapons Safety if used within the vicinity of any

explosive sites or facilities. Provide a list of equipment for review. Contact 412 TW Weapons Safety at 661-810-7585, or email 412TW.SEW@us.af.mil prior to beginning work.

- 8.10** Drinking Water. The Contractor is responsible for providing potable drinking water for their workers. Water shall be brought to the work site cold, in sufficient quantity, at the beginning of each day as to ensure the safety and health of workers. The Contractor shall be responsible to ensure that workers drink sufficient water to ensure that they remain productive and healthy throughout the course of their labor and the project.
- 8.11** Escorts (when applicable based on specific TOs). When work is to take place in a secure area such as the flight line, which will be indicated on applicable TOs, the Contractor shall provide to the GPM a Contractor's weekly worker plan at least seven 7 working days prior to work commencing so the Government can schedule escorts.
- 8.11.1** The weekly worker plan format and extent of details will be discussed at the pre-construction conference. The Contractor can expect to provide a weekly plan that shows the project location(s) and number of anticipated workers at the location and any scheduled deliveries (time, date). If workers will be transiting between sites and/or a laydown yard, the Contractor shall identify them in the plan since additional mobile escorts may need to be allocated.
- 8.11.2** Changes to the Worker Plan. The Contractor shall notify the GPM 72 hours in advance when total Contractor workers increase or decrease by different multiples of 5 or if an unscheduled delivery needs to be made. It is the Contractor's responsibility to notify GPM at least 24 hours in advance of the time and location that the escorts shall meet the Contractor. The Contractor shall make all attempts to promptly meet this appointment. If the Contractor is more than one hour late, the Contractor shall not be allowed access to the area(s) requiring escorts that working day. The Contractor shall not be able to resume work until a new escort arrangement can be made. The Government will not be held liable for any claim attributable to the Contractor's failure to follow these guidelines for arranging and meeting escorts.
- 8.12** Requests/Permits.
- 8.12.1** Base Civil Engineer (BCE) Work Clearance Request. The Contractor shall obtain a BCE Work Clearance Request (AF Form 103) from the GPM for any utility that must be shut off. The request will be made for a minimum of 15 business days prior to the shutdown of utilities. The coordination for the shutdown of utilities is the responsibility of the GPM.
- 8.12.2** Dig Permit. The Contractor shall apply for and maintain active dig permits during excavation activities. The Contractor shall be responsible for routing and coordinating the request for approval. To initiate a dig permit, the Contractor will go to the 412 CE/CENME section located in Bldg. 3500. The Contractor shall provide a map of the area where the work will commence, scope of work to be completed, and digging route including depth. 412 CE/CENME will direct the Contractor how to route (who needs to sign/approve) the dig permit based on the scope of work to be completed. Once the dig permit has been fully signed/approved and returned to 412 CE/CENME, the Contractor shall furnish a copy to the GPM. The Contractor shall have a copy of the dig permit present on-site during all excavation activities. If the Contractor damages any utility, the Contractor shall stop work and contact the CO or GPM immediately. If the Contractor damages a marked, known utility, the Contractor shall repair said utility to the previous condition at the Contractor's own expense. If a Contractor damages an unmarked utility, the Government shall repair said utility.
- 8.12.3** Hot Work Permit. The Contractor shall obtain a Welding, Cutting, and Brazing Permit (AF Form 592) prior to commencement of any hot work. Hot work includes, but is not limited to, welding, cutting, brazing operations, and the use of tar kettles. The Contractor must submit their completed AF Form 592 to the Base Fire Department for coordination and approval. The Contractor shall have a copy of the hot work permit present on-site during welding, cutting, and brazing activities, and shall make the copy available when requested by the CO, GPM, or Fire Department personnel.

- 8.12.4** Confined Space Permit. The Contractor is responsible for and shall submit a MEP for base review and approval to the GPM. The MEP will comply with UFCs, AFIs, CalOSHA, and OSHA regulations and the Contractor shall adhere to the most stringent regulations. The MEP will be for specific TOs as applicable.
- 8.12.5** Airfield Requirements. The Contractor shall coordinate through the GPM for restrictions involving access to the flight line, taxiway, and runway areas. The Contractor shall comply with Air Force Traffic Control Instruction (AFTCI) 13-213, Airfield Management, and the instruction of the Airfield Manager at all times.
- 8.12.6** Work in Specialty Areas. All work in secure areas shall be under escort by Government personnel. Security Forces may require a local agency check of all personnel involved in the accomplishment of the work prior to commencement of work.
- 8.13** Protection of Land Resources. It is intended that land resources within the project boundaries of work performed under this contract be preserved in their present condition or be restored to a condition after completion that will appear to be natural and not detract from the appearance of the project. Insofar as possible, the Contractor shall confine his activities to areas defined by the plans and specifications. Any landscape feature damaged or scarred by the Contractor's equipment or operations shall be restored to its original condition at the Contractor's expense. The CO will decide what method of restoration shall be used. The Contractor shall remove all signs of temporary construction facilities such as haul materials or any vestiges of construction resulting from the contract as directed by the CO.

9.0 GOVERNMENT FURNISHED ITEMS:

- 9.1** Government Provided Design. Any design drawings provided by the Government are at the schematic design level. They are provided to clearly communicate the project's program, scope, and minimum requirements. The Government provided design drawings are not final. The facilities and site design shall be the responsibility of the Contractor.

10.0 CONTRACTOR FURNISHED ITEMS AND SERVICES:

- 10.1** The Contractor shall furnish labor, supervision, tools, materials, equipment, transportation, fuels, lubricants, fluids, solvents, and all other supplies and services necessary to perform operations required to complete work as indicated within these specifications and individual TO's specifications. The Contractor shall be responsible for installing and maintaining temporary cords, lines, or other equipment in a safe condition. Prior to final acceptance, all temporary cords, lines, supplies, solvents, paint, fuel, lubricants, parts, material, tools, or other equipment shall be removed.
- 10.2** The Contractor-furnished materials and equipment shall be currently manufactured and supported by the manufacturer. Obsolete and/or unsupported materials and equipment will not be accepted by the Government to fulfill the terms of this contract or specific TOs.
- 10.3** Any equipment/material the Contractor removes, and which requires reinstallation as part of the job requirements shall be the responsibility of the Contractor. All damaged material shall be replaced with equipment/material of equal quality and function at the Contractor's own expense.
- 10.3.1** Any equipment/material the Contractor removes, and which is **NOT** required for reinstallation becomes the property of the Contractor, unless otherwise instructed by the GPM.

11.0 CONDITIONS OF WORK:

- 11.1** Base Regulations. The Contractor shall comply with all applicable Edwards AFB and Air Force regulations and directives pertaining to security, safety, traffic, fire prevention, personnel clearances, and environmental protection, which will be provided at the pre-construction conference.
- 11.2** Weather. When notified by the Government that a severe weather warning alert has been issued, the Contractor shall immediately take necessary action to tie down and secure all

materials on the job site that could become airborne projectiles as a result of strong surface winds, thunderstorms, etc. This requirement also includes all non-regular working periods. The CO will negotiate any Contractor compensation and or claims due to extensive weather delays.

11.2.1 The procedures for determination of time extensions for unusually severe weather shall be IAW FAR Clause 52.249-10, Default (Fixed-Price Construction). For the CO to award a time extension under this clause, the following conditions must be satisfied:

11.2.1.1 The weather experienced at the project site during the contract period must be found to be unusually severe, that is, more severe than the adverse weather anticipated for the project location during any given month.

11.2.1.2 The unusual severe weather must be an actual cause of a delay in the project's completion. The delay must be beyond the control and without the fault or negligence of the Contractor.

11.3 Changes to Work. Only the CO is authorized to make changes to the contract or any TO issued hereunder. No other Government or non-Government official may alter this contract or any TO issued IAW the basic contract terms and conditions, including the GPM. The Contractor shall report any attempts to alter this contract or any TO to the CO. In the event the Contractor effects any such changes at the direction of any person other than the CO, the change will be considered to have been made without authority and no adjustment will be made to the contract or TO price to cover any increase in costs incurred as a result thereof. If the Contractor needs clarification(s) regarding the contract or a TO, the Contractor shall submit any Request for Information (RFI) questions to the CO.

11.4 Work in connection with this contract which requires utility outages (electrical, water, gas, etc.) that will close down or limit (as determined by the GPM) normal activities in the building, construction area, or other affected areas, shall be performed by the Contractor at a time other than regular work periods of the organization occupying the facility. Requests for utility outages shall be submitted in writing to the GPM for approval 15 business days in advance. Utilities shall not be turned on and off by the Contractor; Civil Engineering (CE) personnel will be scheduled for this purpose.

11.5 Recording and Preserving Historical and Archeological Finds. All items having any apparent historical or archeological interest that are discovered during any construction activities shall be carefully preserved. The Contractor shall leave the archeological find undisturbed and shall immediately report the find to the GPM so that the proper authorities may be notified.

12.0 CONSTRUCTION SITE MAINTENANCE:

12.1 The Contractor shall store all supplies and equipment on the project site as much as is practicable so as to prevent theft or mechanical/climatic damage. The GPM and Facility Manager will determine storage area location. The site shall be maintained in a neat and orderly manner.

12.2 The Contractor shall dispose of all trash and debris generated during the contract. Disposal shall be by the sanitary landfill located off of Edwards AFB or AF Plant 42 or other approved methods and shall conform to all local, state, and federal guidelines and regulations.

12.2.1 The Contractor shall store all refuse in appropriate trash containers on the jobsite. Location of a dumpster at the site shall be as directed by the GPM.

12.2.2 The Edwards AFB refuse contract supplies dumpsters are for Government-produced refuse only. The Contractor shall not dump refuse from any project in the Government dumpsters. If the GPM or CO discovers refuse in Government dumpsters, he/she may instruct the Contractor to immediately remove the refuse or have Government resources remove it at the Contractor's expense.

- 12.2.3** The Contractor's dumpster shall be removed prior to the contract's final inspection. The Contractor shall repair any damage the dumpster causes to paving or lawns at the Contractor's expense.
- 12.2.4** All mud, dirt, debris, foreign objects, or spills of any kind from the Contractor's operations (including subcontractors and suppliers) on streets and parking lots used as access to the work or staging areas, shall be cleaned off the same day. Taxiways, runways, parking aprons, and hard surfaces used as access to the work or staging areas, shall be kept clean at all times.
- 12.2.5** Spill Response. The Contractor is responsible to report and promptly clean up all spills in a manner consistent with current environmental regulations. If it is necessary to utilize Government material, equipment, or personnel to clean up a Contractor caused spill, the Contractor shall be required to reimburse the Government for all associated costs.
- 12.2.6** Recycling, Trash and Litter Control. The Contractor shall strive to recycle as much cardboard, paper, plastic, wood, and metal as possible through the installation's Qualified Recycling Program (QRP), and shall develop a strict recycling, trash, and litter control program. The recycling and litter control program shall consist of supplying an adequate number of covered recycling, trash, and litter receptacles in all appropriate locations. The QRP may be able to provide limited additional recycling containers and bins as required (call 661-277-1167 for coordination). The contractor shall take precautions to prevent Foreign Object Debris (FOD) while working on or around the flight line. The contractor will be responsible to remove all debris because of the contract activity.
- 12.2.7** The Contractor shall have all refuse removal trucks covered and secured prior to leaving the jobsite. If any materials are observed falling off the trucks, the truck shall be stopped and reloaded to prevent damage to any other vehicles caused directly/indirectly by falling debris. The Contractor shall bear the monetary responsibility to repair all damage associated with falling debris.
- 12.2.8** There are no approved concrete truck cleanout sites on Base. The Contractor may instruct the truck to wash out into the Contractor's dumpster only. If the concrete truck cleans out anywhere else on base, the clean-up charges will be billed back to the Contractor against the individual TO.
- 12.3** Each project site must be cleaned up at the end of each day. All debris (whether blown in or Contractor-generated) on the jobsite shall be picked up and disposed of properly. All materials shall be neatly stacked and secured to prevent wind-gusts from blowing materials around the Base. If the GPM determines the site is unsightly, the Contractor may be instructed to halt construction and clean up the site. Contractor shall prevent windblown dust from disturbed areas including frequent watering while performing earth moving and stopping earth disturbing work during high winds exceeding 25 mph. Cleanup project-related dirt tracks out or bulk material spills on publicly maintained paved surfaces within 24 hours. Worksites of 5 or more acres must take measures to prevent dirt track out such as paving, installing grizzlies or pads, street sweeping, washing, or other approved methods. Any project disturbing more than 10 acres or 2 acres in Antelope Valley Air Quality Management District (AVAQMD) may need a Dust Plan from the District, the contractor will provide a copy of the Dust Plan to Environmental prior to conducting earthmoving activity.
- 12.4** Trees, Shrubs, Grass, and Irrigation Systems. The Contractor shall take appropriate measures to prevent injury to plants and subsurface irrigation systems on the project site unless designated to be removed. The Contractor shall not remove or prune any plants without approval from the GPM. Plants that are damaged during construction shall be replaced at the Contractor's own expense with a one-year warranty. Plantation replacement shall be accomplished during the appropriate planting season. Damaged shrubs or hedges shall be replaced with plants of equal size, type, and value. Any subsurface irrigation system damaged by the Contractor shall be repaired at the Contractor's own expense.

- 12.5** The Contractor shall confine their operations, including material storage, to the area of work shown indicated in the TO. The Contractor shall be furnished adequate storage areas for their equipment and materials, but shall be responsible for the receipt, unloading, security, and handling of his equipment and materials. The Contractor shall coordinate proposed storage areas with the CO or GPM. The Contractor shall stock and place materials and equipment only in areas specifically approved by the CO.
- 12.6** The Contractor shall be responsible for the covering of open-bodied vehicles transporting any materials likely to create air pollution or become debris while on base.
- 12.7** Equipment and tools used in the performance of the work shall be always maintained in satisfactory working conditions. The equipment shall be adequate and shall have the capability of producing the requirements as set forth herein. Owners and/or operators of in-use off-road diesel, gasoline, liquefied petroleum gas (LPG), and other alternate fuels vehicles rated 25 horsepower (hp) or greater (i.e. loaders, crawlers tractors, skid steers, backhoes, forklifts, etc.) and portable equipment (backup generators, saws, abrasive blasting, etc.) must meet current emission standards and fleet requirements pursuant to California Air Resources Board (CARB) regulations. The equipment must be registered under the Diesel Off-road Online Reporting System (DOORS), Portable Equipment Registration Program (PERP), or maintain a local permit. New equipment must be certified to an appropriate EPA Tier rating and CARB Executive Order emission standards. For any portable engine or off-road vehicle used by the Contractor, rental agency, or other party registered with CARB, the proponent/contractor shall be responsible for maintaining PERP/DOORS registration and notifying the Air Pollution Control District of any generators (Eastern Kern Air Pollution Control District (EKAPCD), Mojave Desert Air Quality Management District (MDAQMD), or AVAQMD) brought on base.
- 12.8** Use of Tobacco. There shall be no tobacco use inside Government facilities. This rule applies to all facilities, whether occupied or not and under construction/renovation or not. Cigarettes butts shall not be left on the ground at any construction site. The Contractor shall strictly inform/enforce these rules regarding his employees, suppliers, and subcontractors.
- 12.9** Inappropriate Worker Behavior. The Contractor assumes responsibility for the actions of all his/her employees, subcontractors, and suppliers when on Edwards AFB or AF Plant 42.
- 12.10** Noise Control. The Contractor shall comply with all applicable state and local laws, ordinances, and regulations relative to noise control. The Government may require that operations that generate excessive noise be scheduled at other than standard work hours.

13.0 INSPECTIONS, QUALITY CONTROL, WORKMANSHIP, AND TESTING:

- 13.1** The Contractor shall comply with all applicable current standards, codes, and regulations.
- 13.2** Preparatory Inspection. This inspection shall be performed by the Contractor prior to beginning work on any definable phase of construction. It shall include a review of contract requirements; a check to ensure that all materials and/or equipment have been tested, submitted, and approved; a check to ensure that provisions have been made to provide required testing; examination of work area to ascertain that all preliminary work has been completed; and a physical examination of materials and equipment to ensure that they conform to approved shop drawings or submittal data and that all materials and/or equipment are on hand. The GPM shall be notified at least 72 hours in advance of the preparatory inspections and such inspection shall be made a matter of record and sent to the CO.
- 13.3** Preliminary and Final Inspections. The Contractor shall coordinate with the CO no later than 7 days prior to the scheduled TO completion date to allow scheduling of preliminary and final inspections. Attendance at the preliminary and final inspections is mandatory for the Contractor or designated representative. At the preliminary and final inspections, the Contractor shall demonstrate that all systems and subsystems installed under the TO are fully functional, operational and usable.

13.4 Quality Control Plan. The Contractor is responsible for quality control and shall establish and maintain an effective quality control system in compliance with Attachment 1 of this SOW entitled "Quality Control Plan." The quality control system shall consist of plans, procedures, and organization necessary to manage all TOs to produce end-products, which comply with the contract requirements. The system shall cover all construction operations, both on-site and off-site. The Government will hold the Site Superintendent responsible for the quality of work on the job and is subject to removal by the CO for non-compliance with quality requirements specified in the contract. The Contractor's quality control plan shall be provided to the CO for approval within 30 calendar days of contract award.

13.5 Workmanship. All work shall comply with the specifications and drawings provided for each TO. All work shall be performed by craftsmen skilled in the applicable trade and shall be supervised by a qualified Superintendent with experience in the related construction trades.

13.5.1 No careless work will be tolerated. While the CO or GPM may identify workmanship problems to the Contractor, Quality Control is the Contractor's responsibility. Inspection or non-inspection by the Government of work does not relieve the Contractor from ensuring the work complies with the contract documents. It is the responsibility of the Contractor to identify and correct all workmanship problems. Any workmanship problems identified are to be corrected in a timely manner, to the satisfaction of the CO, at no additional cost to the Government.

13.5.2 The Contractor is responsible for coordination and sequence of events with relation to the performance of this project. The Contractor shall verify all dimensions and advise the CO of any discrepancies prior to proceeding with that phase of work. If exact locations for positioning of equipment are not provided by the GPM or Facility Manager, the Contractor must coordinate the locations through the CO. All equipment must be positioned to allow easy access for maintenance and replacement of component parts.

13.6 Existing Work and Restoration of Damage Caused by the Contractor. The disassembling, disconnecting, cutting, removal, or altering in any way of existing work shall be carried on in such a manner as to prevent injury or damage to any portions of existing work, whether they are to remain in place, be re-used in the new work or be salvaged and stored. All existing portions which have been cut, damaged, or altered in any way during performance of work shall be repaired or replaced in kind, in an approved manner to match existing adjoining work. Work of this nature shall be performed by the Contractor at their expense and left in a condition similar to that which existed prior to the start of the work.

14.0 WARRANTY:

14.1 IAW FAR 52.246-21, Warranty of Construction, all work performed under this contract shall conform to the contract requirements and be free of any defect in equipment, material, or design furnished, or workmanship performed by the Contractor or any subcontractor or supplier at any tier. The Contractor shall submit a written warranty and any manufacturers' warranties for items installed to the CO for approval. After being notified of the problem, the CM shall investigate the issue and respond within 24 hours, to include weekends. If the CM believes the issue is not warranty related, he may request a fact-finding visit with the CO and GPM. If the fact-finding meeting determines the issue is warranty related, the Contractor shall repair the item within 48 hours, or as determined by the CO.

14.2 The Contractor is responsible for ensuring their subcontractors fulfill warranty requirements on their work. All manufacturer warranties under an individual TO shall be submitted to the CO with an AF Form 3000 prior to TO closeout and final payment.

15.0 ORDERING PROCEDURES:

15.1 General. TOs will be issued against the basic contract and will be executed IAW the basic contract's terms, conditions, SOW, and each individual TO's SOW, required submittals, and any other items identified. The CO will issue an RFP to the Contractor describing the requirements

for each TO to include a SOW, preliminary list of required shop drawings/material submittals, and possibly concept design drawings. In response to the RFP, the Contractor shall submit a proposal to include all applicable documentation for review by the CO. If necessary, the CO will schedule negotiations with the Contractor and at the conclusion of successful negotiations, award an individual firm-fixed-price (FFP) TO.

- 15.1.1** The response time for a proposal shall be 10 business days after the site visit. Due to mission requirements, it may be necessary to request the Contractor's TO proposal in less than 10 business-days after the site visit. For more complex projects, additional time may be granted by the CO.
- 15.2** Site Visit. The RFP will include the proposed date/time for a site visit (or it will be scheduled shortly after issuance of the RFP). The CM and subcontractors (if applicable) shall attend the site visit and obtain whatever measurements and information necessary to develop the design and produce a complete and accurate TO proposal. The scope validation/site visit discussions will include:
 - 15.2.1.1** Site access
 - 15.2.1.2** Methods and alternatives for accomplishing the work
 - 15.2.1.3** Definition and refinement of requirements
 - 15.2.1.4** Requirements for proposal (in addition to those enumerated in this SOW)
 - 15.2.1.5** Detailed scope of work
 - 15.2.1.6** Special time requirements for completion and phasing requirements as well as justification.
- 15.2.2** The Contracting Office will complete a Memorandum for Record of the site visit. Questions or clarifications should be directed to the CO concerning the discussions above.
- 15.3** Contractor's Proposal. A TO proposal shall consist of a detailed TO cost proposal, drawings (if applicable), period of performance, and confirmation of the project scope.
 - 15.3.1.1** Drawings. If applicable, one set of blue-line/bond paper drawings shall be provided that clearly locate, define, and quantify each item in the Contractor's detailed cost proposal. The Contractor's drawings shall clearly indicate compliance with the requirements of the Government's concept design and building codes. The Contractor shall provide drawings in enough detail to allow the Government to evaluate the Contractor's detailed cost proposal for completeness and accuracy.
- 15.4** Negotiations.
 - 15.4.1** The CO will notify the CM and schedule negotiations (as needed). The CM shall be available to negotiate within two business days of notification.
 - 15.4.2** All TOs will be FFP and negotiated by line-item basis. Unit prices will not be discussed, except for non-priced items (NPIs). Negotiations will establish the appropriate line items for the TO and quantities for each line item. The Contractor must be prepared to provide quantity calculations justifying the material quantities contained in the proposal.
 - 15.4.3** At the conclusion of line-item cost negotiations, the CO will negotiate a reasonable and expeditious performance period based upon input from the GPM.
 - 15.4.4** Liquidated Damages. Liquidated Damages will be assessed on TOs over \$750K (and may be required on TOs under \$750K) as required by FAR Clause 52.211-12, Liquidated Damages - Construction.
 - 15.4.5** Within 5 business days after the TO line items/quantities and performance time have been negotiated, the Contractor shall provide revised drawings (if applicable), corrected for any deficiencies and negotiated changes. Three revised sets (blue-line/bond) shall be provided to the

CO for signature. Incomplete drawings may be annotated and returned to the CM for revision. Approved drawings will be signed by the CO and returned to the CM for use as construction documents. Two sets of construction drawings must be on the jobsite at all times.

15.4.6 After the issuance of the NTP for any TO, the Government may elect to host a pre-construction conference. The Contractor and subcontractors shall be represented at the scheduled conference and be prepared to discuss all efforts related to the TO. A pre-construction letter may be issued in lieu of a conference at the CO's discretion; the Contractor shall follow all instructions in the pre-construction letter and pass on its contents to all subcontractors working on that TO.

15.5 Estimation of Project in Advance of Funding.

15.5.1 During the course of the contract, the Contractor may be required to estimate and negotiate projects in advance of funding. These projects may not have funding available and there is no guarantee that funds will become available for the award of the project. No separate compensation for any pre-order costs including proposal preparation and attendance during negotiations or site visits will be due to the Contractor for projects that are negotiated, and funding is not provided.

15.5.2 Fiscal Year-end Procedures. The Contractor may be given a list of projects for which the Base reasonably expects to receive funding. The list may be revised for both additions and deletions based on the Government's requirements. These projects will be estimated and negotiations completed. The Government will incur no obligation until such time as funding becomes available and a TO is executed for the project. The negotiated total quantities shall remain binding until funding becomes available. Agreed upon total prices that contain NPIs shall be verified with the Contractor prior to execution of the TO. In the event the NPIs have undergone a substantial change in the market, the items shall be re-negotiated and an agreement reached prior to executing a TO.

16.0 TASK ORDER PRICING:

16.1 Contractor TO pricing shall be accomplished as described below and based on the most economical standard construction practices. Value engineering and design review shall be used in project design and scope development.

16.2 Terms Explained:

16.2.1 Line-Item Cost: The cost of a line item shall be item's total bare cost based on a national average as defined by the applicable latest RS Means software version including RS Means Price Book. The RS Means Labor costs are included as line items of work.

16.2.2 RS Means Unit Price Books (UPB's): Consist of RS Means Electrical Cost Data, RS Means Facilities Construction Cost Data, RS Means Electrical Change Order Cost Data, RS Means Heavy Construction Cost Data, RS Means Interior Cost Data, and RS Means Facilities and Maintenance Cost Data Books. **The current year UPBs in effect at the time of contract award shall be used through December 31st. Beginning January 1st, the next newly published editions will be used again through December 31st. This methodology shall apply for the entire term of the contract. Partial year price updates published by RS Means are not allowed.** RS Means UPBs are published by Reed Construction Data; more information may be obtained by visiting www.rsmeans.com. Contract line-item unit prices are to be used as the basis on TO pricing. Estimates composed of the RS Means UPB line items bare costs per unit based on a national average are used. These are non-negotiable.

- 16.2.2.1** The RS Means RS Means Cost Data Books are incorporated into the contract by reference. The Government will not provide the RS Means Cost Data Books specified above for Contractor use. The Contractor must purchase their own copies of the required RS Means Cost Data Books for this contract. The cost books contain pricing information for the description of work to be accomplished and for the unit of measure specified.
- 16.2.2.2** Currently the RS Means Cost Data Books are updated and republished by the RS Means company annually. For the purposes of pricing work under this contract, the new editions will become effective upon issuance, but not later than 31 January of each year. Cost proposals are to be prepared using the provided spreadsheet titled "Electrical IDIQ Proposal Template"
- 16.2.2.3** As each new RS Means Cost Data Book is released, it will be used for all pricing within that year, including quarterly updates. For example, if the contract is awarded in 2023, the 2023 edition shall be used with the most up to date quarterly update; upon release of the 2024 edition, all subsequent work shall be priced using the 2024. In short the latest edition for the year from RS Means shall be used.
- 16.2.2.4** For purposes of TO negotiations, the RS Means Cost Data Books and current quarterly update in effect at the time the TO Request for Proposal (RFP) is issued will be used for negotiating purposes. Similarly, any modifications made to a TO will incorporate the RS Means edition and quarterly update in effect at the time the modification RFP is issued. The Contractor is responsible for purchasing and maintaining their own current edition of the RS Means Cost Data Books for this purpose and incorporating quarterly updates as they become available.
- 16.2.2.5** The Government does not allow use of Division 1 - General Requirements from the RS Means Price Books as a direct charge, EXCEPT for the line items listed below. The line items listed below are permitted as a direct cost to the TO when required by the TO SOW using the 2025 RS Means Price Book as a baseline (*Note: Coefficient and Cost City Index are applicable to these cost)

UPB DIVISION 1 LINE ITEM	UPB LINE ITEM NO.
Engineering Fees	01 11 31.30
Testing & Inspecting Services	01 45 23.50
Scaffolding	01 54 23.70
Earth Work Equipment Rental	01 54 33.20
Equipment Rental	01 54 33.40.0150 through 01 54 33.40.0190
Equipment Rental	01 54 33.40.6950
Lifting and Hoisting Equipment Rental	01 54.33.60

- 16.2.2.6** Contingency such as changes to labor wages and inflation shall be adjusted annually by the annual economic price adjustment to the RS Means Price Books. Any change in the applicable minimum hourly rates of wages during the contract period shall not affect the unit prices to be paid by the Government reformed under the contract.
- 16.2.3** Custom Price Book (CPB): A pre-priced line-item book that will allow for the addition of recurring line items not included in the RS Means Price Books. This book will be a spreadsheet created and maintained by the Government. Recurring non pre-priced items may be added to the CPB after negotiation and after they are used on a TO at the discretion of the CO.
- 16.2.4** Non Pre-priced Items (NPI): Items of work not included in the RS Means Price Books required for execution of a TO and within the scope and general intent of the contract. These items must be submitted, approved, and/or negotiated with the Government.

- 16.2.4.1** Non-RS Means NPI prices taken from local area sources shall be the lowest price offered from at least two acceptable vendors. Labor costs shall be derived using the RS Means productivity and crew cost rates.
- 16.2.4.2** The Contractor shall submit a worksheet for each NPI item, which shows all the costs and calculations used to develop the NPI item's price. The Contractor shall retain all materials used in performing take-offs (calculations, sketches, field measurements, etc.) and obtaining cost information (catalog cut sheets, vendor quotes, etc.) for the NPIs, and shall provide these materials in the TO proposal.
- 16.2.4.3** In case a minimum of two vendor quotes cannot be obtained, a sole source justification may be submitted. Sole source is justified when there is only one supplier, potential suppliers/subcontractors are unresponsive or respond with "no bid", etc. The Contractor shall document the sole source justification and submit it to the Government as part of the TO proposal.
- 16.2.4.4** NPI prices include only direct costs.
- 16.2.4.5** Negotiating prices for NPIs and incorporating them into a TO does not incorporate the NPIs into the contract for subsequent use as a priced item. To permit subsequent use, the CO must incorporate prices for NPIs by supplemental agreement into this contract itself via modification to the basic contract, in which case they become pre-priced items under the contract. This may occur with an annual update to the CPB or separately at another time during the year at the discretion of the CO
- 16.2.5** City Cost Index (CCI): A multiplier used to adjust construction costs to a particular geographic location, as bare costs in the RS Means Price Books represent the U.S. national average. The CCI category to be utilized for this contract is "Electrical, Communications & Utilities". To adjust costs to a particular geographic location, the Weighted Average CCI is applied to the bare cost. The CCI for Bakersfield, CA shall apply to all work under this contract that takes place at Edwards AFB, and the CCI for Los Angeles, CA shall apply to all work under this contract that takes place at Plant 42 in Palmdale, CA. Individual TOs will specify where the work will take place, and the Contractor shall utilize this information in preparing their proposal. CCI rates are found in the Reference Section of the RS Means Cost Data Books
- 16.2.6** Coefficient: A numerical factor that allows the Contractor to account for any cost not included in the RS Means Price Books unit pricing or not allowed (such as Division 1 – General Requirements). The coefficient shall include all costs other than direct labor, material, and equipment incurred in the performance of work that cannot be charged to any specific work elements within the RS Means Price Books.
- 16.3** How to Calculate a TO Price.
- 16.3.1** The TO amount is derived by identifying the appropriate bare cost line items in the RS Means Unit Price Book (or applicable NPIs) necessary to satisfy the technical specification and requirements of the project. The CCI for Electrical, Communications & Utilities (for either Bakersfield, CA or Los Angeles, CA) and negotiated Coefficient will be applied to arrive at the total TO amount. The Contractor shall utilize the TO proposal spreadsheet provided by the Government during the solicitation phase for all TOs issued against the contract. Construction projects are issued as FFP TOs.
- 16.3.2** Keeping Prices Current. The Contractor shall obtain and utilize the current year versions of the following RS Means Cost Books in preparation of TO proposals under this contract: RS Means Electrical Cost Data, RS Means Facilities Construction Cost Data, RS Means Electrical Change Order Cost Data, RS Means Heavy Construction Cost Data, RS Means Interior Cost Data, and RS Means Facilities and Maintenance Cost Data.

16.3.3 Subcontractors. If a subcontractor is used, an additional .05 will be added for subcontractor overhead and profit to the subcontractor portion of the TO. The subcontractor TO amount is derived by identifying the appropriate bare cost line items in the unit price book necessary to satisfy the technical specification and requirements of the subcontractor's portion. The CCI, Coefficient, and subcontractor's overhead and profit are then applied to arrive at the subcontractor's portion of the TO amount. This will be added to the total of the rest of the TO amount.

17.0 COMMENCEMENT, PROSECUTION, COMPLETION, AND PAYMENT FOR WORK:

17.1 IAW FAR Clause 52.211-10, Commencement, Prosecution, and Completion of Work, the Contractor shall be required to: (a) commence work under this contract within (to be determined per TO) calendar-days after the date the Contractor receives the NTP; (b) execute the work diligently; and (c) complete the entire work ready for use not later than (to be determined per TO) calendar-days after receipt of the NTP. The time stated for completion shall include final cleanup of the premises.

17.2 This contract includes work in multiple use type facilities that may be occupied when work is in progress. All work must be coordinated by the Contractor to minimize inconvenience to occupants. It shall be the Contractor's responsibility to take whatever measures are necessary to assure the protection of occupant's assets, furnishings, equipment, etc. and to perform the work to cause minimal disruption of ongoing activities in occupied areas.

17.2.1 The Contractor shall adhere to the requirements of each individual user organization. Any infringement on the normal working conditions (i.e. closing a hallway) shall be coordinated at least 24 hours in advance.

17.2.2 If it becomes necessary to interrupt the use of the agency's work activities in buildings and/or areas for construction purposes, permission to do so must be requested in writing to the GPM five business days in advance. Written requests for street closings shall be submitted to the GPM for approval 15 business days prior to closing of the street.

17.2.2.1 Progress Schedules. Progress Schedules are required on all TOs over \$150K that have a PoP greater than 60 days IAW FAR Clause 52.236-15, Schedules for Construction Contracts. For TOs under \$150K and/or with a PoP less than 60 days that are deemed urgent/high-visibility by the Government and/or for which the Contractor plans to request progress payments (in lieu of one final payment), the Contractor might be required to submit a Progress Schedule that will be used to measure the Contractor's progress on the submitted Progress Reports (see below), if requested by the CO. The Contractor must submit 3 copies (when submitting hard copies; however electronic copies are allowable at the CO's discretion) of a Progress Schedule on an AF IMT 3064, Contract Progress Schedule (attached), or a comparable form to the Contracting Office within five business days of work starting. The schedule should show the order of accomplishment in which the Contractor proposes to perform work. The Contractor shall perform the work IAW the schedule or give timely notice to the CO and identify the need to deviate from the schedule. If assistance in preparing the schedule is required, the Contractor can contact either the GPM or the Contract Administrator. In addition, the Contractor is advised that the CO has determined that bonds and mobilization are not measurable elements of work and should not be listed on the progress schedule. Work elements shall be limited to those tasks which indicate the progress of the work, and which may be readily identified and measured by personnel monitoring the Contractor's progress on the project itself.

17.2.2.2 Three annotated copies of the Progress Schedule showing current progress shall be provided by the Contractor with each request for a progress payment IAW FAR 52.236-15(b).

17.2.2.3 Each TO shall be diligently worked according to the progress schedule and without extending performance periods due to insufficient resources.

- 17.2.2.4** Before any work is initiated under an individual TO, the CM shall coordinate with the GPM and agree on a sequence of procedures; means of access to premises and building; space for storage of materials and equipment; delivery of materials; and use of approaches, corridors, stairways, and elevators. The Progress Schedule must be coordinated with the GPM and approved by the CO prior to work commencing.
- 17.2.2.5** When specifically requested by the Government, the work shall, so far as practicable, be done in definite sections or areas and confined to limited areas that shall be completed before work begins in other areas.
- 17.2.3** Progress Reports. Progress Reports are required on all TOs regardless of dollar value or PoP. These reports are required for tracking the Contractor's completion and for scheduling progress payments. Progress should coincide with the approved Progress Schedule and the Contractor's invoices submitted in Wide Area Workflow (WAWF). The Contractor must submit Progress Reports on an AF IMT 3065, Contract Progress Report, or a comparable form. For actions over \$150,000 that have a PoP greater than 60 days, a Progress Report shall be submitted on a weekly basis. For actions under \$150,000 and/or when the PoP is less than 60 days, a Progress Report shall be submitted with each request for a progress payment (invoice). Certain urgent projects that are under \$150,000 and/or have a PoP of less than 60 days may require weekly Progress Reports to ensure the project stays on track; the Contracting Office will indicate at the time of the award if a project falls in this category. When a Progress Schedule is used, the Progress Report's percentage of work completed for a given period should match (or be ahead of) the schedule identified in the Progress Schedule. These reports shall cover one-week periods starting on Sunday and concluding on Saturday. Reports are not needed if no work is performed during a given week, as long as progress is being completed as identified in the Progress Schedule (when no Progress Schedule is used, progress shall be completed as agreed to by the TO's PoP and as approved by the GPM). The report will be turned into the Contracting Office (send to both individuals identified in the Pre-Construction Letter), and the Contracting Office will then submit it to the GPM who will annotate his/her independent rate of progress and promptly return it back to the CO for approval. In the event there is a variance of 5% or more between the Contractor's and the GPM's percentages, a meeting will be held with the CO to resolve the differences. If there is a variance of less than 5%, the GPM's percentage shall govern. A Progress Report is required for each request for a progress payment (even if only one final payment is requested). The final Progress Report shall be labeled "Final". This information and a sample of the AF IMT 3065 will be included in each TO's Pre-Construction Letter.
- 17.2.4** Inspection by the Government. The GPM will monitor the Contractor's progress on each active TO and identify any non-compliance items while performing technical surveillance of workmanship. The GPM must always have access to the jobsite. Worker certifications, construction drawings, etc. must be on the jobsite and available for review at any given time.
- 17.2.5** The Contractor shall perform planning, scheduling, and reporting functions utilizing Gantt Charts, Critical Path Analysis, Resource Histograms, and Look Ahead Schedules. Items within the project schedule shall have predecessor and successor activities to support a GPM overview. Items in the schedule shall be resource loaded with the manpower required.
- 17.2.6** Due to Force Protection at Edwards AFB, the Contractor can experience delays while gaining access to the base, and the Contractor shall account for possible delays. Any documented, unforeseen Government delays in excess of two hours, shall be reviewed by the CO for possible time extensions.
- 17.2.7** Normal daytime working hours shall be adhered to by the Contractor and its employees to include subcontractor employees. Normal hours are from 0700-1600 hours Monday through Friday. If the Contractor wishes to work at night or during other unscheduled times, permission must be requested and received from the CO. The Contractor shall provide written request to the CO at least 72 hours in advance.
- 17.2.7.1** The following Federal holidays are observed by Edwards AFB:

New Year's Day	01 January
Martin Luther King's Birthday	Third Monday in January
President's Day	Third Monday in February
Memorial Day	Last Monday in May
Juneteenth Day	19 June
Independence Day	04 July
Labor Day	First Monday in September
Columbus Day	Second Monday in October
Veterans Day	11 November
Thanksgiving Day	Fourth Thursday in November
Christmas Day	25 December

17.2.7.2 Holidays falling on a Saturday are observed on the preceding Friday. Holidays falling on a Sunday are observed on the succeeding Monday.

17.2.8 Specific TOs may require outages outside of normal working hours. The Contractor shall be able to work outside of normal working hours to accommodate base mission requirements. The Contractor shall work with the CO on specific TOs that require scheduling outside of normal working hours.

17.3 Meetings. The CM or Superintendent shall attend meetings as scheduled by the GPM and CO to discuss active TOs. The Contracting Office shall prepare minutes of the meeting and provide a copy to all parties in attendance. Should any party not concur with the minutes, they shall state the areas of non-concurrence in writing to the Contractor within one calendar day of receipt of the minutes.

17.4 Distribution of Correspondence. A Contractor representative shall visit the Contracting Office at Bldg. 2800 to pick up and deliver correspondence at least weekly, unless correspondence is handled electronically per agreement with the CO.

17.5 Payment. IAW FAR Clause 52.232-5, Payments Under Fixed-Price Construction Contracts, progress payments can be withheld if satisfactory progress is not achieved. Final payment will not be made until all discrepancies are corrected and all submittals are received.

Attachment 1: Contractor's Quality Control Plan

1. GENERAL REQUIREMENTS:

Establish and maintain an effective quality control (QC) system. QC consists of plans, procedures, and organization necessary to produce a final product which complies with the contract requirements. Cover all design and construction operations, both onsite and offsite, and be keyed to the proposed construction design and construction sequence. The project superintendent will be responsible for the overall performance of this contract and will be held responsible for the quality of work and is subject to removal by the Contracting Officer for non-compliance with the quality requirements specified in the contract. In this context the highest-level manager responsible for the overall construction activities at the site, including quality and production, is the project superintendent. The project superintendent must always have physical presence at the site and is responsible for all construction and related activities at the site, except as otherwise acceptable to the Contracting Officer.

2. QUALITY CONTROL PLAN:

Submit no later than 14 days after the award of the basic contract the Contractor Quality Control (CQC) Plan proposed to implement the requirements of this contract. The Government will consider an interim plan for the first 30 days of operation after the notice to proceed. Design and construction will be permitted to begin only after acceptance of the CQC Plan or acceptance of an interim plan applicable to the particular feature of work to be started. Work outside of the accepted interim plan will not be permitted to begin until acceptance of a CQC Plan or another interim plan containing the additional work.

2.1 Content of the CQC Plan. Include, as a minimum, the following to cover all design and construction operations, both onsite and offsite, including work by subcontractors, fabricators, suppliers, and purchasing agents, subcontractors, designers of record, consultants, architect/engineers (AE), fabricators, suppliers, and purchasing agents:

- a. A description of the quality control organization, including a chart showing lines of authority and acknowledgment that the CQC staff will implement the three-phase control system (refer to para. 3.3) for all aspects of the work specified. Include a CQC System Manager who reports to the project superintendent.
- b. The name, qualifications (in resume format), duties, responsibilities, and authorities of each person assigned a CQC function.
- c. A copy of the letter to the CQC System Manager signed by an authorized official of the firm which describes the responsibilities and delegates sufficient authority to adequately perform the functions of the CQC System Manager, including authority to stop work which is not in compliance with the contract. Letters of direction to all other various quality control representatives outlining duties, authorities, and responsibilities will be issued by the CQC System Manager. Copies of these letters must be furnished to the Government.
- d. Procedures for scheduling, reviewing, certifying, and managing submittals, including those of subcontractors, offsite fabricators, suppliers, and purchasing agents, subcontractors, designers of record, consultants, architect engineers (AE), offsite fabricators, suppliers, and purchasing agents.
- e. Control, verification, and acceptance testing procedures for each specific test to include the test name, specification paragraph requiring test, feature of work to be tested, and person responsible for each test.
- f. Procedures for tracking preparatory, initial, and follow-up control phases and control, verification, and acceptance tests including documentation.

- g. Procedures for tracking design and construction deficiencies from identification through acceptable corrective action. Establish verification procedures that identified deficiencies have been corrected.

2.2 Acceptance of Plan. Acceptance of the Contractor's plan is required prior to the start of design and construction. Acceptance is conditional and will be predicated on satisfactory performance during the construction design and construction. The Government reserves the right to require the Contractor to make changes in his CQC Plan and operations including removal of personnel, as necessary, to obtain the quality specified.

2.3 Notification of Changes. After acceptance of the CQC Plan, notify the Contracting Officer in writing of any proposed change. The proposed changes are subject to acceptance by the Contracting Officer.

3. CONTROL: Contractor Quality Control is the means by which the Contractor ensures that the construction, to include that of subcontractors and suppliers, complies with the requirements of the contract. At least three phases of control must be conducted by the CQC System Manager for each definable feature of the construction work as follows:

3.1 Preparatory Phase. This phase is performed prior to beginning work on each definable feature of work, after all required plans/documents/materials are approved/accepted, and after copies are at the work site. This phase includes:

- a. A review of each paragraph of applicable specifications, reference codes, and standards. Maintain and make available in the field for use by Government personnel until final acceptance of the work.
- b. Review of the contract drawings.
- c. Check to assure that all materials and/or equipment have been tested, submitted, and approved.
- d. Review of provisions that have been made to provide required control inspection and testing.
- e. Examination of the work area to assure that all required preliminary work has been completed and is in compliance with the contract.
- f. Examination of required materials, equipment, and sample work to assure that they are on hand, conform to approved shop drawings or submitted data, and are properly stored.
- g. Review of the appropriate activity hazard analysis to ensure safety requirements are met.
- h. Discussion of procedures for controlling quality of the work including repetitive deficiencies. Document construction tolerances and workmanship standards for that feature of work.
- i. Check to ensure that the portion of the plan for the work to be performed has been accepted by the Contracting Officer.

3.2 Initial Phase. This phase is accomplished at the beginning of a definable feature of work. Accomplish the following:

- a. Check work to ensure that it is in full compliance with contract requirements.

- b. Verify adequacy of controls to ensure full contract compliance. Verify required control inspection and testing.
- c. Establish a level of workmanship and verify that it meets minimum acceptable workmanship standards. Compare with required sample panels as appropriate.
- d. Resolve all differences.
- e. Check safety to include compliance with and upgrading of the safety plan and activity hazard analysis. Review the activity analysis with each worker.
- f. The initial phase should be repeated for each new crew to work onsite, or at any time acceptable specified quality standards are not being met.

3.3 Follow-up Phase. Perform daily checks to assure control activities, including control testing, are providing continued compliance with contract requirements, until completion of the particular feature of work. Record the checks in the CQC documentation. Conduct final follow-up checks and correct all deficiencies prior to the start of additional features of work which may be affected by the deficient work. Do not build upon nor conceal non-conforming work.

3.4 Additional Preparatory and Initial Phases. Conduct additional preparatory and initial phases on the same definable features of work if: the quality of on-going work is unacceptable; if there are changes in the applicable CQC staff, onsite production supervision or work crew; if work on a definable feature is resumed after a substantial period of inactivity; or if other problems develop.

APPENDIX A TYPES OF WORK

The work under this contract at Edwards Air Force Base, CA, including the Air Force Research Laboratory, Air Force Plant 42, and other tenant organizations may include but is not limited to:

- Low and medium voltage within interior and exterior of facilities.
- Switch Stations and Substation facilities.
- Perform an electrical power system analysis of the existing primary distribution systems including the following:
 - Power flow calculations.
 - Short circuit analysis.
 - Arch flash analysis.
 - Electrical protection for current electrical infrastructure.
 - Load study for buildings.
 - Coordination studies.

NOTE: The proper documentation such as reports or data among others shall be submitted to the government for verification as well as the recommendations provided by the contractor.


- Conduct a detailed engineering evaluation of the primary electrical system to establish the following:
 - Future modification, expansions, and upgrades to support future electrical requirements.
 - Future improvement for system efficiency, reliability, and maintainability.
- EasyPower electrical modeling includes the following: file for the primary distribution system shall be submitted by the contractor while required.
- Transformer installation including all sizes.
- Pole Schedule.
- Switch Schedule.
- Transformer overload summary.
- Line overload summary-cables and overhead lines.
- Underground distribution, manholes and duct banks
- Cathodic Protection Systems on tanks including underground water lines.
- Lightning Protection System design for not only buildings but among other required structures.
- Surge Protection Systems for existing and newly installed systems.
- Power generation including Generators sizing for up 2MW including all its components such as Automatic Transfer Switch, SCADA communication with Building B3500.
- Radio Communication equipment installation between building B3500 and local Switch Stations and Substations.
- Add all Switch/Substation meters to Advanced Meter Reading System (AMRS) COINv2 network. This work will include an Upgrade meters provide communication where applicable.
- Provide adequate software licenses when required. (i.e. INSITE, AcSelerator)

The above list of types of work is for the purpose of general information only and is NOT intended to cover and describe every feature or item of work or to define every scope of work required under this contract. Scope of work will be defined and described in detail in the SOW provided to the Contractor for each TO.

Note: All costs arising from the requirements of this SOW must be included in the contract's pricing bid schedule, required by any applicable Construction Wage Rate Requirements Statute.

APPENDIX B

MAPS





South Base Map




Dining Facility

- 1 Food Court / Bldg 145

Areas of Special Interest

- A Aero Club, Bldg 320
- B Branch Park

Lancaster Blvd



Current as of 30 July 2012

Produced by: 412 TWIPA Graphic Arts 130050A

APPENDIX C SECURITY REQUIREMENTS

All Contractor employees will be subject to a criminal history background check IAW DoDM 5200.08V3_AFMAN 31-101V3, Installation Perimeter Access Control, and 412th Test Wing Integrated Defense Plan (IDP) 31, Volume I (the AFMAN and IDP are both limited access documents but more details on the requirements/process in terms of background checks can be provided by the Contracting Office upon request). Vehicle registration, proof of insurance, and a valid driver's license must be presented for vehicles. Installation Commanders may deny access and credentials based on information obtained during identity vetting that indicates the individual may present a threat to the good order, discipline, and morale of the installation.

Base Access. For Contractor personnel requiring frequent base access to perform work at Edwards AFB will be granted access via an Air Force Materiel Command (AFMC) Form 496, Application for AFMC Identification Card. Air Force Federal Acquisition Regulation Supplement (AFFARS) Clause 5352.242-9000, Contractor Access to Air Force Installations, the Prime Contractor shall submit a written request on company letterhead to the CO with the following information (prior to submitting a request for Base access via an AFMC Form 496): 1) contract number, 2) location of work, 3) contract start and stop date (must be on or before contract's expiration date), and 4) names of employees/ subcontractor employees needing access to the base, to include each employee's company name.

It is recommended that the Prime Contractor provide a copy of the request letter to each employee for verification purposes when the employee comes to the Contracting Office at Building 2800 to get their AFMC Form 496 signed. Employees for which no request letter can be found or provided will result in the employee being asked to return on another date/time so verification can be made.

Base passes will be limited to the length of the contract not to exceed 3 years from the date the AFMC Form 496 is submitted to the Contracting Office for signature.

The AFMC Form 496 will be reviewed/approved by the CO, then taken by the Contractor employee to the Edwards AFB Pass & Registration Office in Building 3000, or the Visitor Control Center in Building 1004, for the security portion and issuance of the Base pass.

The contractor shall comply with all base security regulations. Additionally, the contractor shall comply with actions dictated by force protection condition (FPCON) changes/measures and/or health protection condition (HPCON) changes/measures. For real-world situations/exercises, changes to force/health protection conditions could impact contractor performance of work and can include denial of access to the installation to perform work

Only employees who will be working on the contract consistently/frequently should be submitted for a long term Base pass.

The Contractor shall comply with all security requirements imposed by the Installation. Specific security considerations will be handled on an individual Task Order/contract basis as required.

The contractor shall report suspicious activity (refer to Edwards AFB Contractor Antiterrorism Awareness pamphlet) to Security Forces at 661-277-3340 in a timely manner.

The Contractor and its employees shall comply with all base traffic regulations.

No States are subject to Real ID Act enforcement at this time. The Department of Defense will accept standard State-issued driver's licenses and identification cards from all U.S. States and territories as proof of identity. Please visit the Department of Homeland Security's (DHS) website to get the latest information, <https://www.dhs.gov/current-status-states-territories>. Once Real ID Act is enforced, the Contractor shall comply fully.

Contractor shall maintain and make available to the COR, within 30 days after award, records of Antiterrorism Awareness Level I required training of contractor employees and subcontractor employees who require routine physical access to the installation via 30 day pass, DBIDS Access card or Common Access Card (CAC), both initially and annually thereafter. AT Level I training provides contractor employees with the requisite knowledge necessary to remain vigilant for possible terrorist threats. Level I AT Awareness Training may be taken at <https://jkodirect.jten.mil/Atlas2/page/login/Login.jsf> for non-CAC holders. CAC holders may complete AT Level I training (Force Protection course ZZ133079) via myLearning at <https://lms-jets.cce.af.mil/moodle/>. Tracking for each contractor or subcontractor employee is the responsibility of the COR or unit Antiterrorism Representative.

The Contractor shall be responsible for safeguarding all government property, equipment and materials provided for Contractor use. At the end of each work period, all government facilities, equipment, and materials shall be secured.

During performance of the contract, the Contractor shall be responsible for obtaining required identification for newly assigned personnel.

The Contractor shall be responsible for prompt return of credentials and vehicle passes for: 1) any employee who no longer requires access to the work site; 2) upon request by a CO; and 3) upon completion or termination of the contract. The Prime Contractor shall ensure that all Base identification passes issued to employees and subcontractor employees are returned to the issuing office. Failure to comply with these requirements may result in withholding of payment.


Contractor employees are prohibited from possessing weapons, firearms or ammunition, on themselves or within Contractor-owned or privately owned vehicle while on Edwards AFB.

OPSEC - The Contractor shall comply with DOD, USAF, and locally established Operations Security (OPSEC) policies and procedures to protect sensitive and unclassified information and/or equipment, which is furnished to and operated by the Contractor, and prevent compromise of classified information and equipment.

Contractor shall maintain Operations Security (OPSEC) in accordance with DOD Directive & Manual 5205.02, DOD Operations Security (OPSEC) Program, AFI 10-701, Operations Security (OPSEC), and Edwards AFB OPSEC policies and procedures.

Completion of OPSEC Training of contractor employees offered by the Government IAW AFI 10-701, para. 4.1 and 4.2.3 shall be required of all Contractor employees within 90 days of initiating work. Access to mission critical information will not be allowed until OPSEC education has been completed and documented. This training provides Contractor employees with the requisite knowledge necessary to remain vigilant for possible threats, understand basic security procedures, understand the obligation to report security violations and the continued obligation to safeguard information. The requiring unit Security Manager/OPSEC Coordinator will coordinate and track completed training with the Contractor.

Contact the unit Security Manager/OPSEC Coordinator or Wing OPSEC Signature Manager at (661) 277-2066 for questions or reporting.



**No One Starts A New Day Believing
They Will Be A Terrorist Target
Instead You May Find Yourself a:**

- Victim By Association – The wrong friends, in the wrong place, at the wrong time
- Victim By Location – The wrong place at the wrong time
- Victim By Opportunity – The completely random circumstance, primarily occurs at a soft target

BE ALERT TO YOUR SURROUNDINGS!

- What's Different – What Doesn't Fit?
- Know The People That Belong In Your Area
- Be Able To Recognize Names and Insignias Of Official Organizations

WHAT TO LOOK FOR:

- Surveillance (outside and inside the fence) and unfamiliar people or vehicles
- Vehicles without current license plates
- Occupied/Illegally parked vehicles remaining in the same place for extended periods of time
- Same vehicle(s) repeatedly passing your location



Terrorism is Defined As The Unlawful Use Of Violence Or The Threat Of Violence Often Motivated By Religious, Political, Or Other Ideological Beliefs To Instill Fear And Coerce Governments Or Societies In The Pursuit Of Goals That Are Usually Political (DOD Definition)

This pamphlet was developed to provide you a broad overview of your role in the global war on terrorism while you are on Edwards Air Force Base. You are one of our force multipliers... providing additional sets of eyes to help maintain security vigilance. If you see something...say something.

EAFB Contractor Antiterrorism Awareness




Antiterrorism Office (412 SFS/SSX)

Commercial Phone:
(661) 277-4009 or 277-4004
DSN Phone: 527-4009
Email: 412.TW.ATO@us.af.mil

**Contact Edwards
Base Defense Operations Center
661-277-3341**

To report suspicious activity

FORCE PROTECTION CONDITIONS – FPCON'S



FPCON NORMAL

Basic Security Posture When There Is No Known Threat

- A Terrorist Attack Is Always Possible
- Best Information Available Offers No Indication of Probable Attack



Expect To See A Routine Security Posture

FPCON ALPHA

Increased Security Readiness Against Nonspecific Threats

- General Conditions Suggest Possible Violence
- Nothing Indicates That The Base or The Local Area Is Targeted



Expect Random Vehicle Checks And Increased Crime Prevention Efforts

FPCON BRAVO

Increased And More Predictable Threat Exists

- Specific Information Suggests Probable Violence
- Nothing Indicates That This Installation Is Targeted
- Extra Precaution Is Appropriate To Deter Terrorist Planning



Expect To See Closer Inspection Of Vehicles And Deliveries, ID Checks, And A Greater Presence Of Guards

FPCON CHARLIE

Incident Occurs Or Information Indicates Targeting Driving Greatly Enhanced Security Measures

- Evidence Of Terrorist Attack Planning, Such As Terrorist Surveillance Or Reports From Local Sources
- Strong Protective Measures Are Required



Expect Rigorous Efforts To Inspect Vehicles And Facilities; You May Be Required To Evacuate The Base, Or You Will Not Be Allowed On-Base Without Escort

FPCON DELTA

Full Alert Status Used When An Attack Has Occurred Or Is Imminent

- The Base Will Move To A High State Of Alert And Will Implement Required Security Measures



If On-Base, Follow Security Forces Instructions; You May Be Directed To Evacuate Or Seek Shelter. If Off-Base, You May Be Denied Access Until The Incident Has Been Taken Care Of. Additional Security Measures Will Delay And Interrupt Normal Routines

Contact Base Defense Operations Center at
661-277-3341 or 911
To Report Suspicious Activity



U.S. AIR FORCE
EagleEyes
WATCH, REPORT, PROTECT

WHAT TO REPORT

Surveillance – Using cameras (either still or video), notetaking, drawing diagrams, writing on maps, or using binoculars or other vision-enhancing devices to record or monitor base activity.

Elicitation – Attempts to gain information from you by mail, in person, or by telephone about military operations, capabilities, or people.

Tests Of Security – Attempts to measure reaction times or penetrate physical security barriers or procedures in order to access strengths and weaknesses.

Acquiring Supplies – Purchase, theft, or unauthorized acquisition of explosives, weapons, ammunition, military, uniforms, decals, flight manuals, passes or badges, or any other controlled items.

Suspicious Persons Out Of Place – People who don't seem to belong in the workplace, neighborhood, business establishment, or anywhere else.

Dry Run – People getting into position and moving around according to their plan without actually committing a terrorist act. This could also include mapping out routes and determining the timing of traffic lights and flow.

Deploying Assets – People and supplies getting into position to commit the act. This is a person's last chance to alert authorities before the terrorist act occurs.

IF YOU DETECT A SUSPICIOUS ACT BE PREPARED TO:

- Give your Name
- Give your location (as clearly and accurately as you can – give a building name and or number or street)
- Give a "Call Back" phone number
- Remain at your location until contacted by Security Forces
- Move to a location of safety when directed to do so

APPENDIX D LIST OF ACRONYMS

AFB – Air Force Base
AFFARS – Air Force Federal Acquisition Regulation Supplement
AFRL – Air Force Research Laboratory
AFTCI - Air Force Traffic Control Instruction
ASTM - American Society for Testing and Materials
AVAQMD - Antelope Valley Air Quality Management District
BCE - Base Civil Engineer
CARB - California Air Resources Board
CE – Civil Engineering
CM – Contract Manager
CO – Contracting Officer
COR - Contracting Officer Representative
DOE – Department of Energy
DOORS - Diesel Off-road Online Reporting System
EKAPCD - Eastern Kern Air Pollution Control District
EMCS - Energy Management and Control System
EPA – Environmental Protection Agency
EPP – Environmentally preferable purchasing
FAR – Federal Acquisition Regulation
FFP - firm-fixed-price
GPM – Government Program Manager
GPP – Green Procurement Program
HAP – hazardous air pollutant
HM – hazardous materials
hp - horsepower
HPCON - Health Protection Condition
IAW – In accordance with
IBC - International Building Code
ID/IQ – Indefinite Delivery/Indefinite Quantity
IMC - International Mechanical Code
LPG - liquefied petroleum gas
MDAQMD - Mojave Desert Air Quality Management District
MEP - Master Entry Plan
NAF – non-appropriated fund
NEC - National Electrical Code
NESHAP - National Emission Standards for Hazardous Air Pollutants
NFPA - National Fire Protection Association
NPIs - non-priced items
NTP – Notice to Proceed
ODS – Ozone Depleting Substances
OSHA – Occupational Safety and Health Administration
PERP - Portable Equipment Registration Program
POP – Period of Performance
RFP – Request for Proposal
SCADA - Supervisory Control and Data Acquisition
SDS – Safety Data Sheet
SOW – Statement of Work
TOs – Task Orders
UFC - Unified Facility Criteria
UFGS - Unified Facilities Guide Specification
USDA – United States Department of Agriculture
VOC – volatile organic compound
VSI – visual site inspection
WAWF - Wide Area Workflow