

STATEMENT OF NEED
460 CES
1 Megawatt (MW) Generator Rental
Current as of 5 March 2026

1. SCOPE:

460 CES requires an additional backup power source for infrastructure support. The contractor shall provide a 1000 kW (1MW) mobile diesel generator rental for 30 days and all necessary additional equipment for operation. The generator rental shall include an option to extend for an additional 30-days based on the needs for the government.

2. REQUIREMENT:

Product	Quantity
1000 kW (1MW) Mobile Generator	1
300ft 20-0000 AWG cables with Camlock Connection	1

3. SPECIFICATIONS:

1000 kW (1MW) Mobile Generator

- Shall be a diesel fueled power generator system.
- Shall be 480-volt (V) 3-phase power at 60 hertz (Hz) with telemetry.
- Shall be 1600 amperes (A).
- Shall not include WiFi, Bluetooth or GPS capabilities.
- Shall include necessary Cable Tail, Female, Single Conductors.
- Shall include necessary Cable Tail, Male, Single Conductors.

300ft 20-0000 AWG cables with Camlock Connection

- Shall be seven (7) per phase, plus three (3) grounds.
- Shall be rated to 600V.

4. DELIVERY:

Generator and components shall be delivered to Buckley Space Force Base. The Contractor's technician must place, install and service the unit. The Contractor must decommission and retrieve the generator at contract completion. The Contractor

must be able to enter all areas of the installation by adhering to all 460th Security Forces Squadron (SFS) protocols and standards.

Items, when delivered, will be accepted and inspected by the government officials responsible for receiving the products and performing any required inspections.