

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE		PAGE 1 OF 2 PAGES	
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0002		3. EFFECTIVE DATE 3/23/26		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO. (If applicable) 25-0441	
6. ISSUED BY NAVFAC Mid-Atlantic Resident Officer in Charge of Construction 1107A Birch Street Camp Lejeune, NC 28547-2521		7. ADMINISTERED BY (If other than Item 6) See Item 6		CODE			
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-26-R-9014		
				X	9B. DATED (SEE ITEM 11) 2/20/26		
					10A. MODIFICATION OF CONTRACT/ORDER NO.		
					10B. DATED (SEE ITEM 11)		
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☒ is extended, ☐ is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.						
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).						
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:						
	D. OTHER (Specify type of modification and authority)						
E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) 25-0441, BEQ Chiller Repairs FC66, HP476, BB137, etc Amendment 0002, Answer Requests for information The time and date for receipt of proposals has been extended to 1 April 2026 at 3:00PM. This amendment should be acknowledged when your proposal is submitted. Failure to acknowledge the amendment may constitute grounds for rejection of a proposal. See Continuation Page(s) Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
(Signature of person authorized to sign)				(Signature of Contracting Officer)			
NSN 7540-01-152-8070 Previous edition unusable				STANDARD FORM 30 (REV. 10-83) Prescribed by GSA FAR (48 CFR) 53.243			

CONTINUATION SHEET

1. QUESTION: SOW for HP121 says 90 ton chiller but the schedule shows a 70 ton. What should we be pricing?

ANSWER: The Chiller to be replaced is a **90 Ton**. The existing chiller is a 90-Ton York. See attached.

2. QUESTION: I also noticed that the plan pages for BB274 & BB275 are identical. Nots sure if worth addressing but wanted to point out.

ANSWER: These buildings have identical equipment and were built on the same contract.

3. QUESTION: The scheduled leaving water temperature on HP476 is 40 degrees. Providing leaving water at that temperature creates a very low suction temperature. Can you confirm if there is glycol in they system at HP476. If there is not glycol can you confirm if the existing chiller is actually running at 40 degrees LWT. Typically we see Camp Lejeune with a 44F or 42F LWT.

ANSWER: The system will be operating at 44F leaving water set point .

4. All other terms and conditions remain unchanged.