

NEW EQUIPMENT SCHEDULE

LABEL	EQUIPMENT	FLUID	FLOW RATE GPM	PRESSURE DROP(HEAD)	HEAT TRANSFER	EAT	EWT	MAXIMUM RPM	MINIMUM EFFICIENCY	ELECTRICAL	NOTES
FC1	AIR COOLED FLUID COOLER	35% PROPYLENE GLYCOL	320	19' MAXIMUM	1,500,000 BTU/HR	72°F	95°F			208/3/60 (12) FANS 1-1/2 HP EA 84 FLA 85.8 MCA 90 MOCp	-VERTICAL AIR FLOW -DIRECT DRIVE COOLING FANS. FANS SHALL BE TWO SPEED AND MAY BE ECM TYPE. VARIABLE FREQUENCY DRIVE IS NOT PERMITTED. -IN HIGH SPEED UNIT SHALL MEET HEAT REJECTION RATING CONDITION AS SCHEDULED AND NOT EXCEED 72dB SOUND PRESSURE AT 10' -IN LOW SPEED UNIT SHALL MEET AT LEAST 66% OF THE HEAT REJECTION RATING AND NOT EXCEED 60dBa SOUND PRESSURE AT 10' -NUMBER AND SIZE OF FANS IS GIVEN FOR SIZING OF ELECTRICAL SERVICE. OTHER COMBINATIONS ARE ACCEPTABLE. CONTRACTOR RESPONSIBLE FOR UPGRADING ELECTRICAL BRANCH CIRCUIT AT NO ADDITIONAL COST TO GOVERNMENT -COIL SHALL HAVE COATING THAT PASSES THE 6000 SALT SPRAY TEST AS INSTALLED. -MAXIMUM LENGTH NOT INCLUDING PIPE CONNECTIONS IS 28'6". -MAXIMUM OF 12 FINS PER INCH. -PROVIDE CONTROL CABINET FOR RELAYS (POWER OR CONTROL AS NEEDED) FOR SWITCHING FROM LOW TO HIGH SPEED. -CONTROL SEQUENCE TO RUN/OFF AND HIGH/LOW FAN SPEED SHALL BE INITIATED BY THE EXISTING BAS THROUGH CONTACT CLOSURE OR BACnet MS/TP BUS.
ACC1	AIR COOLED CHILLER	WATER	210	10'	88.1 TONS @ 55°F EWT & 95°F AMBIENT	95°F	55°F			208/3/60 404 MCA 500 MOCp	-GOVERNMENT FURNISHED, CONTRACTOR INSTALLED -YORK 091HE17XCASXTXATXBKCXX44SX
P12A	CLOSE COUPLED PUMP	WATER	210	42'			55°F	1800	67%	480/3/60 5 HP	-MOUNT ON STEEL STAND 12" TO 24" TALL. STAND MAY BE COMMON TO BOTH PUMPS. INSTALL WITH 18" BETWEEN PUMPS. -PROVIDE WITH SUCTION DIFFUSER AND FLEXIBLE CONNECTIONS ON SUCTION AND DISCHARGE.
P12B	CLOSE COUPLED PUMP	WATER	210	42'			55°F	1800	67%	480/3/60 5 HP	-PROVIDE CHECK VALVE AND CIRCUIT SETTER ON DISCHARGE.
P13	CLOSE COUPLED PUMP	WATER	300	20'			100°F	1800	67%	480/3/60 3 HP	-MOUNT ON STEEL STAND 12" TO 24" TALL. -PROVIDE WITH SUCTION DIFFUSER AND FLEXIBLE CONNECTIONS ON SUCTION AND DISCHARGE. -PROVIDE CHECK VALVE ON DISCHARGE. -DO NOT PROVIDE CIRCUIT SETTER.
P14	CLOSE COUPLED PUMP	35% PROPYLENE GLYCOL	320	48'			85°F	1800	72%	480/3/60 7.5 HP	-MOUNT ON STEEL STAND 12" TO 24" TALL. -PROVIDE WITH SUCTION DIFFUSER AND FLEXIBLE CONNECTIONS ON SUCTION AND DISCHARGE. -DO NOT PROVIDE CIRCUIT SETTER OR CHECK VALVE.
HEX1	PLATE & FRAME HEAT EXCHANGER	COOL SIDE 35% PROPYLENE GLYCOL	320	12' MAXIMUM	1,450,000 BTU/HR		85°F				.005 FOULING FACTOR ON WATER SIDE
		WARM SIDE WATER	300	10' MAXIMUM	1,450,000 BTU/HR		100°F				
EXP TANK	DIAPHRAM TYPE EXPANSION TANK	35% PROPYLENE GLYCOL									33 GALLON MINIMUM TANK VOLUME 10 GALLON MINIMUM ACCEPTANCE VOLUME. 12 PSIG PRECHARGE FILL THE SYSTEM WITH 35% PROPYLENE GLYCOL.*
AS	VORTEX OR COALESCING TYPE AIR SEPARATOR	35% PROPYLENE GLYCOL	320	3' MAXIMUM							