

ASBESTOS INSPECTION REPORT of:

Building # 8

MCB CAMP LEJEUNE



Print Date

Tuesday, July 23, 2024

INSPECTION SUMMARY

BLDG #: 8

YEAR BUILT: 1942

OCCUPANT: ADMIN/ ACS COMPTROLLER

ASBESTOS MANAGER: 910-451-5837

BUILDING COMMENTS:

HAZ RANK 3/GREEN [AH AUG2015]
FRIABLE DEBRIS APPEARS ABATED, ROOFING SEALANT DEBRIS BELIEVED UNDER WATER; OTHER ACM REMAINS, LOW HAZARD

FEB2016
CHECK FOR FIBROUS DEBRIS, CANNOT FIND TO SAMPLE, BELIEVED REMOVED

AUG2015
PVS. ACM REMAINS, UNSURE ABOUT FIBROUS DEBRIS

OCT2013
PVS. ACM REMAINS

JUL2010
UNDER RENO; TRANSITE GROUND DEBRIS REMOVED BY INSPECTOR, OTHER ACM REMAINS, ADDL SAMPLING, ACM INCLUDES:
FIBROUS DEBRIS

AUG08
PVS ACM ADDL SAMPLING NOT CONCLUSIVE, ADDL ACM IDENTIFIED:
TRANSITE PANEL MATERIAL, DEBRIS
CLOTH EXPANSION JOINT MATERIAL, THICK
TAR SEALANT DEBRIS

FEB04
PVS. ACM REMAINS

JUL01
ACM INCLUDES:
EXTERIOR CAULKING, WINDOWS

NOTIFICATION OF ACM IN BUILDING

NOTICE: The following asbestos-containing materials have been identified in this structure. Refer to survey findings for additional information or contact the Asbestos Program Manager. Please note ACM that is intact and undisturbed is not considered a significant health hazard to building occupants.

Friable ACM(s) identified

DESCRIPTION	LOCATION	Date	Quantity
-------------	----------	------	----------

No friable ACM records found in database

Non-friable ACM(s) identified

DESCRIPTION	LOCATION	Date	Quantity
-------------	----------	------	----------

TRANSITE PANEL MATERIAL	ROOF/ ATTIC VENTS/ DORMERS	8/6/2008	2 SF
EXTERIOR CAULKING,	EXTERIOR BRICK JOINTS, EAST CENTER WING CONNECTION TO MAIN ORIGINAL BUILDING	8/6/2008	54 LF
CAULKING MATERIAL	INTERIOR (-) AND EXTERIOR (+) WINDOW PERIMETERS	7/30/2001	2,196 LF

TAR SEALANT	EXTERIOR GROUND DEBRIS; WEST CENTER SOUTHEAST, SOUTHSIDE EAST	8/6/2008	1	SF
CAULKING MATERIAL	INTERIOR (-) AND EXTERIOR (+) WINDOW PERIMETERS	8/12/2015	2,196	LF
TRANSITE PANEL MATERIAL	ROOF/ ATTIC DORMER VENT CENTER EAST	8/12/2015	2	SF
TAR SEALANT	EXTERIOR GROUND DEBRIS; WEST CENTER SOUTHEAST	8/12/2015	1	SF
EXTERIOR CAULKING,	EXTERIOR BRICK JOINTS, EAST CENTER WING CONNECTION TO MAIN ORIGINAL BUILDING	8/12/2015	54	LF
CAULKING MATERIAL	INTERIOR (-) AND EXTERIOR (+) WINDOW PERIMETERS	10/15/2013	2,196	LF
EXTERIOR CAULKING,	EXTERIOR BRICK JOINTS, EAST CENTER WING CONNECTION TO MAIN ORIGINAL BUILDING	7/27/2010	54	LF
TRANSITE PANEL MATERIAL	ROOF/ ATTIC VENTS/ DORMERS	10/15/2013	2	SF
TAR SEALANT	EXTERIOR GROUND DEBRIS; WEST CENTER SOUTHEAST, SOUTHSIDE EAST	10/15/2013	1	SF
EXTERIOR CAULKING,	EXTERIOR BRICK JOINTS, EAST CENTER WING CONNECTION TO MAIN ORIGINAL BUILDING	10/15/2013	54	LF
TAR SEALANT	EXTERIOR GROUND DEBRIS; WEST CENTER SOUTHEAST, SOUTHSIDE EAST	7/27/2010	1	SF
CAULKING MATERIAL	INTERIOR (-) AND EXTERIOR (+) WINDOW AND DOOR PERIMETERS	7/27/2010	3,400	LF
TRANSITE PANEL MATERIAL	ROOF/ ATTIC VENTS/ DORMERS	7/27/2010	2	SF

Tested Non ACM or REMOVED Materials

<i>DESCRIPTION</i>	<i>LOCATION</i>	<i>Date</i>
DUCT SEALANT, TAN	ATTIC, OLD VENT BOX (CAPPED)	8/6/2008
FIREWALL MATERIAL, SOFT PLASTER	ATTIC, CENTER NORTH, SOUTH, AND EAST FIREWALLS	8/6/2008
TAR PAPER, BLACK	ATTIC DEBRIS, PREVIOUS ROOFING MATERIALS	8/6/2008
EXTERIOR CAULKING,	RESIDUAL MATERIALS IN ATTIC AT DORMER VENTS	8/6/2008
TRANSITE PANEL MATERIAL	EXTERIOR GROUND, NORTH AND SOUTH WINGS WEST ENDS (SEE ALSO HM43)	8/6/2008
FLOOR TILE ADHESIVE	OFFICE AREA	8/6/2008
JOINT MATERIAL	PARTITION AND NEW INSTALLED WALLS THROUGHOUT (SEE ALSO HM09)	8/6/2008

SINK UNDERCOATING,	FIRST AND SECOND FLOOR WEST CENTER BREAK AREAS	8/6/2008
TAR SEALANT	EAST CENTER WING CONNECTION TO ORIGINAL BUILDING, OVERHEAD w/CORK	8/6/2008
CARPET ADHESIVE	OFFICE AREAS THROUGHOUT BUILDING (SEE ALSO HM20)	7/30/2001
12" WHITE FLOOR TILE AND ADHESIVE	WEST CENTER EXTERIOR GROUND DEBRIS	8/6/2008
EXTERIOR CAULKING,	EXTERIOR GROUND DEBRIS, WEST CENTER (PREVIOUS ROOFING MATERIALS)	8/6/2008
GASKET MATERIAL	EXTERIOR GROUND DEBRIS, WEST CENTER, NORTHEAST	8/6/2008
GRAY VINYL BASE AND ADHESIVE, 4"	ASSOCIATED WITH HM01 THROUGHOUT	7/30/2001
12" GRAY FLOOR TILE AND ADHESIVE	STAIRWELL LANDINGS, LIMITED OFFICES AND CLOSETS	7/30/2001
DRYWALL AND JOINT MATERIAL	ABOVE DROPDOWN CEILING (SEE ALSO HM09, 24)	8/6/2008
TAR PAPER, BLACK	ROOFING SYSTEM UNDERLAYMENT	8/6/2008
FLOOR LEVELING COMPOUND	LIMITED AREAS AT DOORWAY THRESHOLDS MATERIAL NOT VISIBLE, UNDER FLOOR COVERINGS (SEE ALSO HM22)	7/30/2001
VAPOR BARRIER	BEHIND BRICK/ PLASTER-DRYWALL WALLS THROUGHOUT	8/6/2008
TAR PAPER, BLACK	EXTERIOR GROUND DEBRIS, WEST CENTER, SOUTH	8/6/2008
TRANSITE PANEL MATERIAL	EXTERIOR GROUND DEBRIS (SEE ALSO HM36)	8/6/2008
CLOTH EXPANSION JOINT MATERIAL, THICK	ATTIC, CENTER HEAD EXHAUST DUCTS AT ROOF LEVEL (SEE ALSO HM10)	8/6/2008
12" WHITE FLOOR TILE AND ADHESIVE	FIRST FLOOR WEST CENTER OFFICE; SECOND FLOOR WEST CENTER OFFICES	8/6/2008
PLASTER MATERIAL	THROUGHOUT BUILDING	7/30/2001
2'x2' CEILING TILE,	LIMITED OFFICE AREAS	7/30/2001
FLOOR LEVELING COMPOUND	OFFICE AREAS	8/6/2008
EXTERIOR CAULKING,	EXTERIOR GROUND DEBRIS, WEST CENTER	8/6/2008
INTERIOR CAULKING,	METAL WINDOWS THROUGHOUT (SEE ALSO HM04)	7/27/2010
FIBROUS DEBRIS	INTERIOR OVERHEAD FIRST FLOOR CENTER AT ABANDONED PIPING SYSTEMS AND HANGARS	7/27/2010
RESIDUAL MASTIC	PATCHES THROUGHOUT (SEE ALSO HM01, 20)	7/27/2010
2'x2' CEILING TILE,	LIMITED OFFICE AREAS	2/10/2004

FIBROUS DEBRIS	INTERIOR OVERHEAD FIRST FLOOR CENTER AT ABANDONED PIPING SYSTEMS AND HANGARS	8/12/2015
CARPET ADHESIVE	OFFICE AREAS THROUGHOUT BUILDING (SEE ALSO HM20)	2/10/2004
DUCT SEALANT, GRAY	DUCT SYSTEM THROUGHOUT	2/10/2004
DRYWALL AND JOINT MATERIAL	PARTITION AND NEW INSTALLED WALLS THROUGHOUT	2/10/2004
GRAY VINYL BASE AND ADHESIVE, 4"	THROUGHOUT BUILDING	2/10/2004
12" GRAY FLOOR TILE AND ADHESIVE	STAIRWELL LANDINGS, LIMITED OFFICES AND CLOSETS	2/10/2004
CAULKING/PUTTIES	INTERIOR (-) AND EXTERIOR (+) WINDOW PERIMETERS	2/10/2004
PLASTER MATERIAL	THROUGHOUT BUILDING	2/10/2004
CLOTH EXPANSION JOINT MATERIAL, THICK	ATTIC, CENTER HEAD EXHAUST DUCTS AT ROOF LEVEL (SEE ALSO HM10)	7/27/2010
FIBROUS DEBRIS	INTERIOR OVERHEAD FIRST FLOOR CENTER AT ABANDONED PIPING SYSTEMS AND HANGARS	10/15/2013

HEALTH ASPECTS:	ACM only presents a health hazard when asbestos fibers are airborne and inhaled. Avoid disturbance which will release fibers. The presence of asbestos does not constitute a health hazard.
CONDITIONS TO AVOID:	Do not disturb or cause damage to ACM. Do not sand, grind or abrade materials or cause damage with any type of equipment.
REPORTS OF DAMAGE:	Report any damage, dust or debris that may come from ACM or suspect ACM, or any change in the condition of materials, or accidental disturbance to the Asbestos Program Manager.
RESPONSE ACTION:	Corrective action initiated to minimize fiber release and protect personnel.
INSPECTION:	ACM will be inspected periodically to evaluate any changes in condition.
RECORDKEEPING:	The Camp Lejeune Asbestos Program Manager maintains a copy of the survey for the building.

CAMP LEJEUNE Asbestos Program Manager:

Phone: (910) 451-5837

SAMPLES COLLECTED

Sample	HA	Description		Sample Date	Sample Location	Chr (%)	Amo (%)	Oth (%)
8-01-01	01	CARPET ADHESIVE	YELLOW	2/10/2004	1ST FL CORRIDOR, SOUTH	0	0	0
8-01-02	01	CARPET ADHESIVE	YELLOW	2/10/2004	1ST FL CORRIDOR, SOUTH	0	0	0
8-01-03	01	CARPET ADHESIVE	YELLOW	2/10/2004	1ST FL, NORTH STAIRWELL	0	0	0
8-01-04	01	CARPET ADHESIVE	YELLOW	2/10/2004	2ND FL, NORTH WING, CENTER	0	0	0
8-01-05	01	CARPET ADHESIVE	YELLOW	2/10/2004	2ND FL, CORRIDOR, SOUTH	0	0	0
8-1-01	01	CARPET ADHESIVE	YELLOW	7/30/2001	2ND FL NORTH WING, WEST END	0	0	0
8-1-02	01	CARPET ADHESIVE	YELLOW	7/30/2001	2ND FL SOUTH WING, WEST	0	0	0
8-1-03	01	CARPET ADHESIVE	YELLOW	7/30/2001	2ND FL EAST CNTR WING, WEST	0	0	0
8-02-01	02	GRAY VINYL BASE AND ADHESIVE, 4"		2/10/2004	1ST FL CORRIDOR	0	0	0
8-02-02	02	GRAY VINYL BASE AND ADHESIVE, 4"		2/10/2004	1ST FL, EAST WING	0	0	0
8-02-03	02	GRAY VINYL BASE AND ADHESIVE, 4"		2/10/2004	2ND FL, NORTH WING	0	0	0
8-2-01	02	GRAY VINYL BASE AND ADHESIVE, 4"		7/30/2001	1ST FL HALL, NORTH FOYER	0	0	0
8-2-02	02	GRAY VINYL BASE AND ADHESIVE, 4"		7/30/2001	1ST FL EAST CNTR WING	0	0	0
8-03-01	03	12" GRAY FLOOR TILE AND ADHESIVE		2/10/2004	1ST FL, CORRIDOR SOUTH	0	0	0
8-03-02	03	12" GRAY FLOOR TILE AND ADHESIVE		2/10/2004	1ST FL, SOUTH STAIRWELL	0	0	0
8-03-03	03	12" GRAY FLOOR TILE AND ADHESIVE		2/10/2004	1ST FL, NORTH STAIRWELL	0	0	0
8-03-04	03	12" GRAY FLOOR TILE AND ADHESIVE		2/10/2004	2ND FL, CORRIDOR SOUTH	0	0	0
8-03-05	03	12" GRAY FLOOR TILE AND ADHESIVE		2/10/2004	2ND FL, NORTH STAIRWELL	0	0	0
8-3-01	03	12" GRAY FLOOR TILE AND ADHESIVE		7/30/2001	SOUTH FOYER COMM CLOSET	0	0	0

Sample	HA	Description		Sample Date	Sample Location	Chr (%)	Amo (%)	Oth (%)
8-04-00ri13	04	CAULKING MATERIAL	WHITE/ GRAY	10/15/2013	N/A	9	9	9
8-04-00ri15	04	CAULKING MATERIAL	WHITE/ GRAY	8/12/2015	N/A	9	9	9
8-04-01	04	CAULKING MATERIAL	WHITE/ GRAY	2/10/2004	1ST FL CENTER, INTERIOR	0	0	0
8-04-02	04	CAULKING MATERIAL	WHITE/ GRAY	2/10/2004	1ST FL CENTER WING, INTERIOR	0	0	0
8-04-03	04	CAULKING MATERIAL	WHITE/ GRAY	2/10/2004	CENTER MAIN, EXTERIOR	0	0	0
8-04-04	04	CAULKING MATERIAL	WHITE/ GRAY	2/10/2004	CENTER WING, EXTERIOR	0	0	0
8-04-05	04	CAULKING MATERIAL	WHITE/ GRAY	2/10/2004	SOUTH WING, EXTERIOR	0	0	0
8-04-40	04	CAULKING MATERIAL	WHITE/ GRAY	7/27/2010	CNTR EAST WING, WEST END DOOR	0	0	0
8-04-41	04	CAULKING MATERIAL	WHITE/ GRAY	7/27/2010	NORTH WING, SE WINDOW	0	0	0
8-04-42	04	CAULKING MATERIAL	WHITE/ GRAY	7/27/2010	CNTR HALL, NW ENTRY DOOR	0	0	0
8-04-43	04	CAULKING MATERIAL	WHITE/ GRAY	7/27/2010	SOUTH WING, NW WINDOW	3	0	0
8-4-01	04	CAULKING MATERIAL	WHITE/ GRAY	7/30/2001	EXT., CNTR SE HEAD	2	0	0
8-4-02	04	CAULKING MATERIAL	WHITE/ GRAY	7/30/2001	INT., CNTR NW OFFICE	0	0	0
8-05-01	05	PLASTER MATERIAL		2/10/2004	1ST FL CENTER, NORTH OFFICE	0	0	0
8-05-02	05	PLASTER MATERIAL		2/10/2004	1ST FL NORTH WING	0	0	0
8-05-03	05	PLASTER MATERIAL		2/10/2004	2ND FL NORTH CORRIDOR	0	0	0
8-05-04	05	PLASTER MATERIAL		2/10/2004	1ST FL CENTER, NORTH OFFICE	0	0	0
8-05-05	05	PLASTER MATERIAL		2/10/2004	2ND FL NORTH CORRIDOR	0	0	0
8-5-01	05	PLASTER MATERIAL		7/30/2001	CNTR NORTH FOYER	0	0	0
8-06-01	06	2'x2' CEILING TILE,		2/10/2004	1ST FL, CENTER WING OFFICE	0	0	0
8-06-02	06	2'x2' CEILING TILE,		2/10/2004	1ST FL, CENTER CORRIDOR SOUTH	0	0	0
8-06-03	06	2'x2' CEILING TILE,		2/10/2004	2ND FL, CENTER CORRIDOR NORTH	0	0	0
8-6-01	06	2'x2' CEILING TILE,		7/30/2001	EAST CNTR WING	0	0	0

Sample	HA	Description		Sample Date	Sample Location	Chr (%)	Amo (%)	Oth (%)
8-7-01	07	FLOOR LEVELING COMPOUND	GRAY	7/30/2001	SOUTH WING, EAST END	0	0	0
8-21-30	21	12" WHITE FLOOR TILE AND ADHESIVE		8/6/2008	1ST FL WEST CNTR OFFICE	0	0	0
8-22-30	22	FLOOR LEVELING COMPOUND	YELLOW	8/6/2008	1ST FL WEST CNTR OFFICE	0	0	0
8-23-20	23	FLOOR TILE ADHESIVE	YELLOW	8/6/2008	1ST FL WEST CNTR	0	0	0
8-24-30	24	JOINT MATERIAL		8/6/2008	1ST FL CNTR HALL, SW CLOSET	0	0	0
8-25-30	25	SINK UNDERCOATING,	WHITE	8/6/2008	1ST FL WEST CNTR	0	0	0
8-25-31	25	SINK UNDERCOATING,	WHITE	8/6/2008	2ND FL WEST CNTR	0	0	0
8-26-30	26	VAPOR BARRIER	BLACK	8/6/2008	1ST FL EAST CNTR WING, WEST	0	0	0
8-27-30	27	TAR SEALANT	BLACK	8/6/2008	1ST FL EAST CNTR WING, WEST	0	0	0
8-28-30	28	DRYWALL AND JOINT MATERIAL		8/6/2008	2ND FL NORTH WING, NE	0	0	0
8-28-31	28	DRYWALL AND JOINT MATERIAL		8/6/2008	2ND FL SOUTH WING, SOUTH CNTR	0	0	0
8-29-30	29	TAR PAPER, BLACK		8/6/2008	ROOF/ATTIC, SOUTH WING CNTR	0	0	0
8-29-31	29	TAR PAPER, BLACK		8/6/2008	ROOF/ ATTIC, EAST CNTR WING, EAST	0	0	0
8-29-32	29	TAR PAPER, BLACK		8/6/2008	ROOF/ ATTIC, CNTR WEST	0	0	0
8-30-00ri10	30	TRANSITE PANEL MATERIAL	DEBRIS	7/27/2010	N/A	9	9	9
8-30-00ri13	30	TRANSITE PANEL MATERIAL	DEBRIS	10/15/2013	N/A	9	9	9
8-30-00ri15	30	TRANSITE PANEL MATERIAL	DEBRIS	8/12/2015	N/A	9	9	9
8-30-30	30	TRANSITE PANEL MATERIAL	DEBRIS	8/6/2008	ATTIC, CNTR EAST WING, EAST END	20	0	0
8-31-30	31	DUCT SEALANT, TAN		8/6/2008	ATTIC, CNTR EAST WING, SE	0	0	0
8-32-30	32	FIREWALL MATERIAL, SOFT PLASTER	TAN	8/6/2008	ATTIC, EAST CNTR FIREWALL	0	0	0

Sample	HA	Description		Sample Date	Sample Location	Chr (%)	Amo (%)	Oth (%)
8-33-00ri10	33	CLOTH EXPANSION JOINT MATERIAL, THICK		7/27/2010	N/A	9	9	9
8-33-30	33	CLOTH EXPANSION JOINT MATERIAL, THICK		8/6/2008	ATTIC, CNTR EAST	70	0	0
8-34-30	34	TAR PAPER, BLACK		8/6/2008	ATTIC, CNTR EAST	0	0	0
8-35-30	35	EXTERIOR CAULKING,	WHITE	8/6/2008	ATTIC, NORTH WING, NORTH CNTR VENT	0	0	0
8-36-30	36	TRANSITE PANEL MATERIAL	GRAY	8/6/2008	EXT. NORTH WING, SW GROUND	15	0	0
8-37-30	37	12" WHITE FLOOR TILE AND ADHESIVE		8/6/2008	WEST CNTR EXT. GROUND	0	0	0
8-38-30	38	EXTERIOR CAULKING,	BLACK	8/6/2008	WEST CNTR EXT. GROUND, NE	0	0	0
8-38-31	38	EXTERIOR CAULKING,	BLACK	8/6/2008	WEST CNTR EXT. GROUND, SW	0	0	0
8-39-30	39	GASKET MATERIAL	BLACK	8/6/2008	EXT. GROUND, WEST CNTR, NE	0	0	0
8-40-30	40	EXTERIOR CAULKING,	WHITE	8/6/2008	EXT. WEST CNTR GROUND, SE	0	0	0
8-41-00ri10	41	TAR SEALANT	BLACK/ GRAY	7/27/2010	N/A	9	9	9
8-41-00ri13	41	TAR SEALANT	BLACK/ GRAY	10/15/2013	N/A	9	9	9
8-41-00ri15	41	TAR SEALANT	BLACK/ GRAY	8/12/2015	N/A	9	9	9
8-41-30	41	TAR SEALANT	BLACK/ GRAY	8/6/2008	EXT. GROUND, WEST CNTR, SE	6	0	0
8-41-31	41	TAR SEALANT	BLACK/ GRAY	8/6/2008	EXT. GROUND, SOUTHSIDE EAST	0	0	0
8-42-30	42	TAR PAPER, BLACK		8/6/2008	EXT. GROUND DEBRIS, WEST CNTR SOUTH	0	0	0
8-43-30	43	TRANSITE PANEL MATERIAL	DEBRIS	8/6/2008	EXT. GROUND, SOUTHSIDE WEST	15	0	0
8-43-32	43	TRANSITE PANEL MATERIAL	DEBRIS	8/6/2008	EXT. GROUND, NORTHSIDE WEST	8	0	0
8-44-00ri10	44	EXTERIOR CAULKING,	WHITE	7/27/2010	N/A	9	9	9
8-44-00ri13	44	EXTERIOR CAULKING,	WHITE	10/15/2013	N/A	9	9	9
8-44-00ri15	44	EXTERIOR CAULKING,	WHITE	8/12/2015	N/A	9	9	9

Sample	HA	Description		Sample Date	Sample Location	Chr (%)	Amo (%)	Oth (%)
8-44-30	44	EXTERIOR CAULKING,	WHITE	8/6/2008	EAST CNTR, SOUTH JOINT	5	0	0
8-44-31	44	EXTERIOR CAULKING,	WHITE	8/6/2008	EAST CNTR, NORTH JOINT	2	0	0
8-50-40	50	INTERIOR CAULKING,	WHITE	7/27/2010	EAST CNTR WING, NW WINDOW	0	0	0
8-50-41	50	INTERIOR CAULKING,	WHITE	7/27/2010	SOUTH WING, NW WINDOW	0	0	0
8-50-42	50	INTERIOR CAULKING,	WHITE	7/27/2010	2ND FL SOUTH WING, NE WINDOW	0	0	0
8-50-43	50	INTERIOR CAULKING,	WHITE	7/27/2010	2ND FL NORTH WING, NE WINDOW	0	0	0
8-51-00ri13	51	FIBROUS DEBRIS	GRAY, WHITE	10/15/2013	N/A	9	9	9
8-51-00ri15	51	FIBROUS DEBRIS	GRAY, WHITE	8/12/2015	N/A	.1	.1	.1
8-51-40	51	FIBROUS DEBRIS	GRAY, WHITE	7/27/2010	CNTR NORTH MECH RM	0	0	0
8-51-41	51	FIBROUS DEBRIS	GRAY, WHITE	7/27/2010	CNTR HALL AT NORTH HEAD DOOR OVHD	10	20	0
8-51-42	51	FIBROUS DEBRIS	GRAY, WHITE	7/27/2010	CNTR HALL WEST SPRINKLER RM OVHD	20	0	0
8-51-43	51	FIBROUS DEBRIS	GRAY, WHITE	7/27/2010	CNTR HALL WEST SPRINKLER RM OVHD	45	0	0
8-52-40	52	RESIDUAL MASTIC	BLACK	7/27/2010	NORTH WING, SW CORNER	0	0	0
8-52-41	52	RESIDUAL MASTIC	BLACK	7/27/2010	2ND FL CNTR NORTH TELE CLOSET	0	0	0
8-52-42	52	RESIDUAL MASTIC	BLACK	7/27/2010	2ND FL NORTH WING, NE CORNER	0	0	0