

TECHNICAL CAPABILITY CERTIFICATIONS

Vendor shall self-certify that the equipment and services proposed either meets or does not meet the Government's minimum requirements specified in the associated Statement of Work (SOW) reference by initialing in the "YES" or "NO" area of the chart below.

In order to be considered technically acceptable for award, this form must be completed in its entirety and submitted with your quote.

**PURPOSE OF REQUEST:** JP-5 Tanker Trailer and Pump Rental

**LOCATION:** Norfolk Naval Shipyard

**PERIOD OF PERFORMANCE:** 6/15/26-5/15/27

**CONTRACTOR RESPONSIBILITY:** JP-5 Tanker Trailer

|                           |
|---------------------------|
| <b>Manufacturer Name:</b> |
| <b>Part #:</b>            |
| <b>Model#:</b>            |

| SOW REF | DESCRIPTION                                                                                                                                                                                                 | YES | NO |
|---------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----|----|
| 3.1.1   | Contractor to supply POC information (name and phone number) on the equipment.                                                                                                                              |     |    |
| 3.1.2   | Shall be cleaned and dry for JP-5 fuel service and be ready for immediate use upon delivery.                                                                                                                |     |    |
| 3.1.3   | Tanker trailer must comply with NFPA 385, Standard for tank vehicles for flammable and combustible liquids.                                                                                                 |     |    |
| 3.1.4   | Have pumping capability with by-pass 4" Camlock supply fitting (in the event NNSY provides local pumping capability).                                                                                       |     |    |
| 3.1.5   | Deliver and place tanker trailer at location of work job site on pier 5A.                                                                                                                                   |     |    |
| 3.1.6   | The total weight including all fluids must be stenciled on the tanker trailer with minimum 1" high letters.                                                                                                 |     |    |
| 3.1.7   | Tanker Trailer must be capable of continuous operation. Normal duty for tanker trailer will be to supply JP-5 fuel to ship tanks in an emergency.                                                           |     |    |
| 3.1.8   | Tanker shall have one hose connection of 4" (Camlok) that can pump the complete contents of the tank.                                                                                                       |     |    |
| 3.1.9   | Tanker Trailer must be free of leaks, cracks, and holes. Fittings shall be properly mounted and secure without cracks, leaks, bends, or breaks.                                                             |     |    |
| 3.1.10  | New or used equipment may be provided.                                                                                                                                                                      |     |    |
| 3.1.11  | NNSY Technical POC listed below shall inspect the equipment PRIOR to delivery to location of work. NNSY reserves the right to request a different tanker trailer if the condition is deemed unsatisfactory. |     |    |

\_\_\_\_\_(Insert Initial/Date) hereby certifies the equipment/services proposed meet or exceed all Government Minimum Specifications.

CONTRACTOR RESPONSIBILITY: JP-5 Pump Rental

|                    |
|--------------------|
| Manufacturer Name: |
| Part #:            |
| Model#:            |

| SOW REF | DESCRIPTION                                                                                                                                                                                                                                                                                                                                           | YES | NO |
|---------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----|----|
| 3.2.1   | Pump must be diesel powered.                                                                                                                                                                                                                                                                                                                          |     |    |
| 3.2.2   | Pump must provide 150 GPM (minimum) at 50 PSIG discharge pressure. Limit RPM of motor is 1500 RPM (maximum).                                                                                                                                                                                                                                          |     |    |
| 3.2.3   | Pump must be able to prime automatically and quickly for suction lifts of up to 28 feet without use of foot valves.                                                                                                                                                                                                                                   |     |    |
| 3.2.4   | Pump must have a 40-gallon (minimum) diesel fuel tank.                                                                                                                                                                                                                                                                                                |     |    |
| 3.2.5   | Pump must be a separate compact unit mounted on a trailer type chassis with integral fuel tank. The total weight including all fluids must be stenciled on the unit with minimum 1" high letters.                                                                                                                                                     |     |    |
| 3.2.6   | Pump must be capable of continuous operation. Normal duty for pump will be to supply JP-5 fuel to ship tanks in an emergency.                                                                                                                                                                                                                         |     |    |
| 3.2.7   | Maximum working pressure of pump unit shall be 50 PSIG.                                                                                                                                                                                                                                                                                               |     |    |
| 3.2.8   | Hose connections: 3" suction and 2" discharge (Camlok).                                                                                                                                                                                                                                                                                               |     |    |
| 3.2.9   | Pump unit shall have discharge pressure gage (0 – 100 PSIG minimum range).                                                                                                                                                                                                                                                                            |     |    |
| 3.2.10  | Pump unit shall have winterization features such as water jacket heaters and lube oil sump heaters to ensure rapid starting during freezing conditions.                                                                                                                                                                                               |     |    |
| 3.2.11  | Pump and associated equipment shall be free of leaks, cracks, etc.                                                                                                                                                                                                                                                                                    |     |    |
| 3.2.12  | Pump shall be operationally tested prior to delivering to location of work. Pump shall be cleaned and dry for JP-5 fuel service.                                                                                                                                                                                                                      |     |    |
| 3.2.13  | Provide one 3" suction hose x 20' length with male/female Camlok end fittings suitable for JP-5 fuel service. Hose assembly shall be free of leaks, cracks, chaffing, cuts, rips, tears, and any other damage. It shall be pressure tested and cleaned for JP-5 fuel service. Hose ends shall be blanked/capped to prevent debris from entering hose. |     |    |

\_\_\_\_\_ (Insert Initial/Date) hereby certifies the equipment/services proposed meet or exceed all Government Minimum Specifications.

Vendor shall certify that his/her product(s) meets or exceeds all specifications in this solicitation, in their entirety, with no exceptions. \_\_\_\_\_ (initials)

Company Name:

Cage Code:

Point of Contact: