J-1502000-09
Boiler and Related Equipment Inventory

Boiler #1 Babcock and Wilcox National Board # 20583 Built 1960 Capacity 76,500 pph Design Pressure 775 psi Steam Temp 500°F Heating Surface 7895 ft^2 Economizer heating surface 3030ft^2 Economizer pressure 825 psi	**Boiler #1S** Cleaver Brooks National Board #17317 Built 2011 Design Pressure 150 psi Rating 1200 BHP Type: Firetube Model # CBL-200X-1200-150ST
Boiler #2 Babcock and Wilcox National Board # 20582 Built 1960 Capacity 76,500 pph Design Pressure 775 psi Steam Temp 500°F Heating Surface 7895 ft^2 Economizer heating surface 3030ft^2 Economizer pressure 825 psi	**Boiler #3** Babcock and Wilcox National Board # 21838 Built 1965 Capacity 76,500 pph Design Pressure 775 psi Steam Temp SAT Heating Surface 6934 ft^2 Economizer heating surface 3030ft^2 Economizer pressure 825 psi
Boiler #4 Cleaver Brooks National Board #17454 Built 2011 Design Pressure 150 psi Rating 1200 BHP Type: Firetube Model # CBL-200X-1200-150ST	**Boiler #6** Energy Resources Inc. Heat recovery Steam Generator Model# S3-2616 National Board # 3225 Average AWP 200 psi Heating Surface 17,882 ft^2 Maximum Steam Capacity 50,000 pph
Deaerator #1 Chicago Heater CO. Built: 1990 Diameter: 7'5" Height 8' Capacity: 350,000 PPH 50 psig Steel Construction	**Deaerator #2** Chicago Heater CO. Built: 1993 Diameter: 7'8" Height 6'4" Capacity: 350,000 PPH 50 psig Steel Construction
Hot Water Production System Piping Sizes Vary From 2" TO 14"	**Steam Distribution** Approximately 8 linear miles of piping Piping sizes range from 1" to 8" Nominal steam piping pressures are 600 psig, 200 psig, 125 psig, and 5 psig.