

Specifications

1. Scope - This specification defines the minimum requirements for purchasing multiple new refrigerated air dryer & installation parts required.

2. Requirements - The dryer units shall consist of the following features and capabilities as a minimum:

Ingersoll Rand (or equal) Refrigerated Air Dryer (qty 2):

Model NVC1000 (1000 CFM) Cycling
Refrigerated Air Dryer, 460V / 3 PH / 60 HZ,
Heat Exchanger: Air Cooled Electric No Loss
Drain Valve

Ingersoll Rand (or equal) Condensate Drain (qty 1):

PNLD-28
PNLD II - 28 Condensate Drain, (LP) Low
Pressure Control air (40-130 PSI)

Ingersoll Rand (or equal) 2" Ball Valve (qty 1):

54634480
Ingersoll Rand Ball Valve With 2.00" Female
NPT

3. Documentation: The contractor shall provide a set of standard commercial manuals/instructions with the units. This documentation shall be provided at the same time as the delivery.