



2033 HERITAGE PARK DR, OKLAHOMA CITY, OK 73120 | 1.800.822.1650

Polarized Light Microscopy Asbestos Analysis Report

Quantem Lab No. 347428

Account Number: B731

Client: Tinker AFB - Civil Engineering

Laura Duck

Date Received: 06/14/2022

Received By: Baylie Longstreth

Date Analyzed: 06/15/2022

Analyzed By: Benjamin Hill

Methodology: EPA/600/R-93/116

Project: Mechanical Room Reno

Project Location: Bldg. 2280 West Mech Rm

Project Number: WWYK190068; WWYK200131

Quantem Sample ID	Client Sample ID	Composition	Color / Description	Asbestos (%)	Non-Asbestos Fiber (%)	Non Fibrous
001	GM220112	Homogeneous	White Ceiling Tile	Asbestos Not Present	Cellulose 50 Glass Fiber 30	Perlite Paint
002	GM220113	Layered	Tan/Brown Floor Tile	Asbestos Not Present	NA	CaCO3 Vinyl
002a		Layered	Yellow Adhesive	Asbestos Not Present	NA	Glue
002b		Layered	Gray Paint	Asbestos Not Present	NA	Paint
003	GM220114	Layered	Brown Fiberboard	Asbestos Not Present	Cellulose 90	Binder
003a		Layered	Brown/Tan Insulation	Asbestos Not Present	Cellulose 30 Glass Fiber 50	Perlite

Benjamin Hill

Benjamin Hill, Assistant Laboratory Manager

6/15/2022

Date of Report

Unless otherwise noted, upon receipt the condition of the sample was acceptable for analysis.

Quantem is a NVLAP accredited Testing PLM laboratory (Lab Code: 101959-0). This report relates only to the specific items tested.

NVLAP accreditation applies only to analysis performed utilizing EPA/600/M4-82-020 and EPA/600/R-93/116 methods.

This report may not be used to claim product endorsement by NVLAP or any agency of the US Government.

This report may not be reproduced except in full, without the written approval of the laboratory.



ASBESTOS CHAIN OF CUSTODY

2033 Heritage Park Drive, Oklahoma City, OK 73120-7502
(800) 822-1650 • (405) 755-7272 • Fax: (405) 755-2058

LEGAL DOCUMENT - PLEASE PRINT LEGIBLY

Contact Information		Project Information	
Company:	Tinker AFB, CE Environmental	Project Name:	Mechanical Room Reno
Contact:	Michael Green/Laura Duck	Project Location:	Bldg. 2280 West Mech Rm
Account #:		Project ID:	WWYK190068; WWYK200131
SAMPLED BY:	Name: Michael Green/Laura Duck	PO Number:	
	Date: 14 Jun 2022		

RELINQUISHED BY	VIA	RECEIVED BY	DATE & TIME
Michael Green	HAND	[Signature]	6/14/22 1:03

REQUESTED SERVICES (Please check the Appropriate Boxes)

	PLM		PLM		TEM		TEM		TURNAROUND TIME		
	Bulk Analysis (EPA 600/R-93/116)	400 Point Count	1000 Point Count	Gravimetric Preparation	Particle ID	Air- AHERA	Bulk- Presence / Absence EPA600/R-93/116	Bulk- Quantitative [weight%]- Chatfield	Dust- Presence / Absence	Dust- Quantitative [fibers/sq.cm]- ASTM D5755	Other
☒						☐	☐	☐	☐	☐	☐
☐						☐	☐	☐	☐	☐	☐
☐						☐	☐	☐	☐	☐	☐
☐						☐	☐	☐	☐	☐	☐
☐						☐	☐	☐	☐	☐	☐

No.	Sample ID (10 Characters Max)	To Be Analyzed	Color	Description	Volume / Area (as applicable)	Comments / Notes
1	GM220112	☒	White	Ceiling Tile		Friable remnant ceiling tile debris on floors in SW storage rm
2	GM220113	☒	White/Gray	Floor tile w/adhesive and paint		Old FT remaining in SW storage rm
3	GM220114	☒	Brown	Insulation		Insulation falling out walls in SW storage rm
4		☐				
5		☐				
6		☐				
7		☐				
8		☐				
9		☐				
10		☐				