

PERFORMANCE WORK STATEMENT

**FOR
THE INSPECTION, MAINTENANCE AND
SERVICING OF THE
MOBILE AIRCRAFT FIRE TRAINING FACILITY
AT
LAJES FIELD AFB**

18 December 2025

TABLE OF CONTENTS

SECTION	TITLE
Section 1	Description of Services
Section 2	Government Furnished Services
Section 3	Services Summary
Section 4	General Information

APPENDIX TITLE

Appendix 1 Inspection Data

Appendix 2 References

Section 1 – Description of Services

1. Description of Services. The Contractor shall provide all specialized tools and equipment and qualified labor to inspect, test, maintain and repair the Lajes Field Air Force Base Mobile Aircraft Fire Trainer (MAFT) in a manner that will ensure their serviceability and prevent deterioration in operational effectiveness. The Contractor shall comply with this Performance Work Statement (PWS), Air Force Technical Order (TO) 35E1-2-13-1 (latest version in effect at the time utilized) Operation and Maintenance Instructions for Aircraft Live Fire Training Facilities (AFTF), commercial standards, manufacturers' recommendations, procedures, and technical data, and local, state, and federal guidelines as applicable to the work involved. NOTE: Lajes Field MAFT is fueled by Butane gas, instead of Propane.

1.1. Additionally, all work being performed will ensure compliance with the applicable National Fire Protection Association national consensus standards listed below.

- NFPA 54, National Fuel Gas Code (2021 Edition)
- NFPA 58, Liquefied Petroleum Gas Code (2020 Edition)
- NFPA 70, National Electrical Code® (2020 Edition)
- NFPA 405, Standard for the Recurring Proficiency of Airport Fire Fighters (2020 Edition)
- NFPA 1003, Standard for Airport Fire Fighter Professional Qualifications (2019 Edition)
- NFPA 1402, Standard on Facilities for Fire Training and Associated Props (2019 Edition)
- NFPA 1403, Standard on Live Fire Training Evolutions (2018 Edition)

1.2. Inspection and Preventive Maintenance Services for Mobile Aircraft Fire Trainer (MAFT). The Contractor shall maintain one (1) MAFT and associated equipment and components - Butane Tank, Generator and Air compressor - currently located at Lajes Field AB. The Contractor shall perform all required inspections and preventive maintenance in accordance with commercial standards this PWS and Appendix 1A - USAF Live MAFT Inspection & Testing Requirements.

1.3. Minor Repair. The Contractor shall perform minor repairs as needed to keep the MAFT fully operational. Minor repairs are defined as preventive inspection and maintenance measures to restore the trainer to its full operating capability without requiring a major repair as described in Para 1.4. The Contractor shall utilize spare parts to accomplish such servicing, if replacement spare parts are available onsite. To facilitate prompt minor repairs, the Contractor shall maintain a readily accessible, secured box or container of essential equipment, basic supplies, and consumables at the MAFT location. If materials, supplies, and parts are needed and are not on site, the contractor shall determine what is required and submit a list to 765 ABS/CEF for approval. The Contractor is responsible for conducting market research to ensure the correct materials, supplies and parts are being procured. If any item exceeds a total value of \$3,500.00, including shipping/handling costs, the Contractor will need to provide three different quotes for that specific item. The Government will order and pay for those items and have them available for installation. Repairs with ordered parts may be completed upon subsequent visit in accordance with a semi-annual performance of the contract or an earlier visit.

1.4. Major Repair. Major repairs are not included in this contract. All major repairs that deem the trainer unserviceable shall be reported to the Field Representative and referred to the Using Organization. Major repairs are defined as unexpected parts replacement (part failure for unknown reason), repairs that require additional site visits or back-ordering of parts, and repairs that require over \$3,500.00 in parts to restore the trainer to its full operating capability.

Installation, testing and replacement of gas piping, gas utilization equipment or accessories, repair and servicing of equipment, shall be performed only by qualified personnel. Examples of major problems include: Any safety

related condition that could lead to an imminent hazard such as: LPG piping or tank corrosion that has reduced the wall thickness to less than that required for the maximum allowable operating pressure. Any crack or other material defect that impairs the structural integrity or reliability of an LPG tank or piping. Any abnormal movement by environmental causes, such as earthquakes, landslides or floods that may impair the serviceability of a pipeline, tank, or controls. Any malfunction or operating error that causes the pressure of an LPG pipeline or tank to rise above its maximum allowable working pressure or a leak in the LPG pipeline or tank that constitutes an emergency

1.5. Frequency. The MAFT shall be inspected and preventive maintenance performed on a semi-annual basis inspection (not to exceed 180 days). Any conflict between this PWS and the technical order, commercial standards or manuals will be resolved in favor of the PWS required frequency.

1.6. Scheduling. The Contractor shall submit an initial inspection and preventative maintenance schedule to the Contracting Officer within fifteen (15) days after contract award. The Contractor shall coordinate and schedule actual inspection and maintenance dates/times with the applicable Field Representative to prevent conflicts with on-going missions or exercises. The Government will provide the Contractor a list of names and contact information for the Field Representative(s) at Lajes Field AFB.

1.7. Operational Check. The Government, as part of the initial scheduling process, will conduct a complete “operational check” of the trainer and provide the results to the Contractor at least two weeks before the Contractor is scheduled to arrive at each base.

1.8. Reports. The Contractor shall submit a complete report of all inspections, maintenance and servicing accomplished. An example format is included under Appendix 1A MAFT trainers. The reports shall be submitted to the Field Representative and Contracting Officer within 10 calendar days after completion of the inspection, maintenance or servicing.

The reports shall include a record of conditions found, repairs, recharging, and all replacement parts used. All records, documents, and associated papers provided by the Contractor or generated during the period of this contract become Government property and will be returned to the Government upon contract termination or completion. During the contract period, all records, documents, and associated papers will be available for Government review.

1.9. Telephone and On-line Technical Support. The Contractor shall provide 24/7 Toll-free telephone and on-line support to facilitate simple troubleshooting and operator maintenance.

1.10. Equipment. The Contractor shall provide all specialized tools and testing equipment to accomplish maintenance and testing as required.

1.11. Travel. All costs for travel shall be included in the contract line items for maintenance and repair services.

1.12. Safety. Liquid propane used in the facility is potentially explosive. The fire department training ground is a non-smoking area. Personnel shall practice proper grounding procedures in accordance with the National Electric Code (NEC). Personnel shall wear appropriate protective clothing and be aware of emergency procedures to perform emergency shutdown and start-up.

1.13. Change in Place of Performance. It may be necessary to temporarily or permanently move aircraft LPG-fueled fire trainers (mobile and fixed facility) to a different site or location. The Government reserves the right to negotiate with the contractor any required change in place of performance.

Section 2 – Government Furnished Services

2. Government Furnished Utilities. The Government will provide the following utilities when available.

2.1 Utilities. The Government will provide water and electricity.

Section 3 – Services Summary

3. The following table summarizes the performance objectives and thresholds that will be used to assess contractor performance and compliance with the PWS.

SS Item	Performance Objective (PO)	PWS Section	Remedy	Performance Threshold	Method of Surveillance
1	Contractor performs required inspections and preventive maintenance ensuring compliance with NFPA standards.	1.1	Contractor performs 100% of required inspections and preventive maintenance – re-performance within one week.	Excellent: 0 defects Very Good: 1 defect Satisfactory: 2 defects Marginal: 3 defects Unsatisfactory: More than 3 defects	Customer Complaint; Periodic Validation
2	Contractor performs required inspections and preventive maintenance on Mobile Aircraft Fire Trainer.	1.2	Contractor performs 100% of required inspections and preventive maintenance to LPG MAFT – re-performance within one week.	Excellent: 0 defects Very Good: 1 defect Satisfactory: 2 defects Marginal: 3 defects Unsatisfactory: More than 3 defects	Customer Complaint; Periodic Validation Customer Complaint;
3	Contractor performs Minor Repairs.	1.3	Contractor performs 100% of required minor repairs – re-performance agreed upon scheduled.	Excellent: 0 defects Very Good: 1 defect Satisfactory: 2 defects Marginal: 3 defects Unsatisfactory: More than 3 defects	Customer Complaint; Periodic Validation

Section 4 – General Information

4. Environmental Protection. The Contractor shall comply with all applicable United States Air Force(USAF) environmental regulations and Host Nation environmental laws and regulations. The Contractorshall also comply with local safety regulations and fire requirements, including the Air Force Occupational Safety and Health (AFOSH) Standards. The Contractor shall ensure that the purchase, use,handling, storage, and disposal of all toxic, hazardous and special materials and wastes are in accordancewith all applicable USAF and Host Nation laws, regulations, policies and procedures that are establishedto protect the health and safety of employees and the community along with minimizing/eliminating therisk of environmental pollution.

4.1. Quality Control. Contractor shall develop and maintain a quality program to ensure maintenance andrepair services are performed in accordance with TO 35E1-2-13-1(latest version in effect at the time utilized), this PWS, commercial standards, manufacturers' recommendations, procedures, technical data, and applicable USAF and Host Nation regulations. The program shall consist of method(s) for identifyingand preventing defects, including preventing repetitive problems in the quality of service performed. The Contractor shall maintain a file of all inspection(s), repairs, and corrective actions made by the Contractor. This documentation shall be made available to the Government during the term of the contractand shall become the property of the Government at contract completion. It shall also contain the name andduty phone numbers for persons to be contacted.

4.2. Security Requirements. The installation access will be coordinated with the local Installation Fire Chief and Security Forces Squadron. Contract personnel will not enter restricted areas without escort from authorized personnel. The Contractor shall restrict personnel to only those areas required to performing work.

4.3. Disposition of Materials. The Contractor shall dispose of any and all expended and broken items properly in accordance with (IAW) host base disposal procedures.

4.4. Contractor Clean Up. The Contractor shall, at all times, keep all work areas free from accumulationsof waste material and rubbish. Upon completion of the job, the Contractor shall leave the work and premisesin a clean, neat, and orderly condition.

4.5. Employee Conduct. The Contractor is responsible for the conduct, professional credibility, and security compliance of contracted employee while working on USAF installations.

4.6. Uses and Safeguarding of Information. Information from the secure web site is considered to be proprietary in nature when the contract number and contractor identity are associated with the direct labor hours and direct labor dollars. At no time will any data be released to the public with the contractor nameand contract number associated with the data.

4.7. Compliance with Local Law. It is the Contractor's sole responsibility to ensure it is legally operating at each location in accordance with all host nation laws, to include labor laws.

Appendix 1 - Inspection Data

A1. Inspection Data. The following represents historical inspection data used for Mobile Aircraft Fire Trainers units. This data is provided for information only and represents the current minimum satisfactory level of service.

Appendix #	Title
1A	USAF Live MAFT Inspection & Testing Requirements

APPENDIX 1A

USAF Live MAFT Inspection & Testing Requirements

COMPONENT/S INSPECTED	TEST	INSPECTION CRITERIA	FREQ
MOCK UP			
Tail Engine Assembly	Visual: Manual:	Cracks, Corrosion, and oxidation. Lubricate shaft and bearing, raise and lower	S/A S/A
Floor Grates	Visual: Manual:	Cracks, corrosion, and oxidation. Lubricate shaft and bearings, raise and lower.	S/A S/A
Wing frames	Visual: Manual:	Cracks, corrosion, and oxidation Lubricate grease nipples, raise and lower	S/A S/A
Wing Engine Wheels	Visual: Manual:	Cracks, corrosion, and oxidation Lubricate, grease nipples, raise and lower	S/A S/A
Landing Gear	Visual: Manual	Cracks, corrosion, and oxidation nipples, raise and lower	S/A S/A
Winch	Visual: Manual: Validate:	Entire length for corrosion, fray/s. Lubricate. Operate	S/A S/A S/A
Surface Areas	Visual: Manual:	Loose paint, oxidation, and corrosion. Remove oxidation	S/A S/A
Control Cart	Visual:	Cracks, corrosion, and oxidation	S/A
Communications Devices	Visual: Validate:	Cracks, corrosion, and oxidation Operations check	S/A S/A
Program Logic Code (PLC)	Visual: Validate:	Cracks, corrosion, and oxidation Operations check	S/A S/A
Communication Cable	Visual: Manual:	Damage, cracks, abrasions. PIN connection formatting compatibility	A A

Hubbell	Plugs	Visual: Manual:	Damage, cracks, abrasions. PIN connection formatting compatibility	A A
Deadman Pendant (wireless and wired pendants)		Visual: Manual: Validate:	Damage. Activation buttons depress/reset. Operations check.	A AA
Pins, Clips, Lanyard		Visual: Manual:	Damage, corrosion. Lubricate.	A A
Spill Fire Pan		Visual: Manual:	Damage, corrosion,oxidation. Remove oxidation. Lubricate threads and seats	A A
Emergency Shutdown Valves		Visual: Manual: Validate:	Damage. Activation buttons depress/reset. Operations check.	A AA
SUPPORTING STRUCTURE				
Butane Tanks		Visual	Corrosion, cracks, damage, markings.	A
Tank Compartment		Visual: Manual:	Corrosion, cracks, damage, markings. Remove oxidation Lubricate hinges	A A
Butane Liquid Pump		Visual: Validate:	Corrosion, cracks, damage. Operate, IAW Ops Manual	A A
ACME Fittings		Visual: Manual: Validate	Cracks, leakage, Oxidation, and corrosion. Replace defective gaskets. Remove oxidation. Lubricate fittings and threads. Check pressure seal	A A A
Propane Cannon		Visual: Manual:	Corrosion, cracks, damage, markings. Remove oxidation. Lubricate	A A
Piping		Visual:	Cracks, leakage, free of debris, free- flowing	A
Hoses & Cables		Visual: Validate:	Corrosion, cracks,damage. Operate IAW Ops Manual	AA
Exhaust Fans		Visual: Validate:	Corrosion, cracks,damage. Operate IAW Ops Manual	S/A S/A
Gas Detection/Sensor Unit System		Visual: Manual: Validate	Damage, indicator lights illuminate. Calibrate IAW Ops Manual Operational check to ensure detection	A/S/AA
Main Gas Header Assembly		Visual: Manual: Validate:	Damage, oxidation, corrosion. Clean strainer Operational check of regulator, Inlet device/s.	A A A

Solenoid Valves	Visual: Manual:	Inspect operation. Clean	S/A S/A
Air Compressor	Visual: Manual:	Inspect air intake, clean filter or replace filter. Clean plastic parts. Blow out all airpassages.	S/A S/A
Generator	Visual: Manual:	Inspect air inlet and outlet for obstructions. Clean. Torque hold-down bolts	A A

A1.1. Trainer Specifics. The MAFT unit located a Lajes Field AFB, is composed by a Mobile Aircraft Fire Trained MA-500 and an O-100 Fuel Spill Fire Trainer, both manufactured by Kidde Fire Trainers, and both are fueled using Butane Gas. The O-100 Fuel Spill Fire Trainer uses both gas and liquid butane to operate.

The MA-500 is an instructor controlled, vapor butane-fueled, live fire training system mounted on a trailer that can be towed to a selected site and be quickly set up to provide safe and efficient fire training exercises for the types of fires normally associated with fixed wing aircraft. The MA-500 training fires include: Cockpit Fire; Passenger area fire; Left Engine fire; 3D fire; Wheel/Brakes fire; Tail engine fire. The MA-500 MAFT unit is complemented by an O-100 Fuel Spill Fire Trainer, a Propane Tank Trailer for fuel delivery a Generator trailer for power delivery, and an air compressor that provided air to the Tank safety valves.

Trainer Type	Trainer Location	Date Purchased	Current Condition	Date of Last Inspection
MAFT	Lajes	Oct 2014	Fair-Fully Operational	November 2025

Note: Semi-Operational means system operations are limited due to inoperable/defective components/infrastructure. Non-Operational means system is out of service awaiting repair by contractor/funding for repairs. These systems require major repair to become operational.

Appendix 2 – References

A2. References. All publication revisions will be provided through the corresponding weblink location.

Reference #	Publication #	Title	Weblink
2A	TO 35E1-2-13-1	Technical Manual, Operation and Maintenance Instruction Manual, Aircraft Fire Training Facility	http://www.robins.af.mil/library/technicalorders.asp