

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE		PAGE	OF	PAGES
2. AMENDMENT/MODIFICATION NO.		3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (if applicable)		1	2	
AMENDMENT NO. 0006		03/25/26		26-0400				
6. ISSUED BY		CODE	7. ADMINISTERED BY (if other than Item 6)		CODE			
NAVFAC Mid-Atlantic Resident Officer in Charge of Construction 1107A Birch Street Camp Lejeune, NC 28547-2521		N40085				See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			(X)	9A. AMENDMENT OF SOLICITATION NO.				
			X	N40085-26-R-9016				
				9B. DATED (SEE ITEM 11) 02/24/26				
				10A. MODIFICATION OF CONTRACT/ORDER NO.				
				10B. DATED (SEE ITEM 11)				
CODE			FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS								
☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended, ☒ is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.								
12. ACCOUNTING AND APPROPRIATION DATA (if required)								
13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.								
CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).							
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
	D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return _____ copies to the issuing office.								
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) 26-0400, Roof Repairs Buildings HP51, HP53, HP55, HP57, HP255, and HP265 Amendment 0006, Answer Request for Information.								
The time and date for receipt of proposals remains unchanged.								
This amendment should be acknowledged when your proposal is submitted. Failure to acknowledge the amendment may constitute grounds for rejection of a proposal.								
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.								
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)					
15B. CONTRACTOR/OFFEROR			15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
(Signature of person authorized to sign)					(Signature of Contracting Officer)			
NSN 7540-01-152-8070 Previous edition unusable			STANDARD FORM 30 (REV. 10-83) Prescribed by GSA FAR (48 CFR) 53.243					

CONTINUATION SHEET

QUESTION 1: RFI #5 includes the Asbestos reports for Buildings 255,51,53,55,57,265. The reports detail ACM material as “roofing material” “Black” But does not list a description for some of the buildings. Other roofing materials that were tested were described as “ sealants, tarpaper etc” with sample locations as “ Attic, or roof hatch”

ANSWER 1: Government acknowledges that the reports are published as described.

QUESTION 2: If we do not have to disturb ACM material for our scope should we price abating? Or can we leave as is?

ANSWER 2: Assume all roof penetrations with mastic is ACM material and price for abating these materials.

QUESTION 3: Should we assume all roof flashings are ACM material? Or can a more detailed description of the ACM material be obtained before bid submission?

ANSWER 3: No other information is available. Contact Ken Hensley, Base Environmental Compliance Officer, at 910-451-7018 if encounter suspected ACM material.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.