
Department of the Air Force: Justification for Other Than Full and Open Competition

Dollar Value of this Acquisition: [REDACTED]

CERTIFICATIONS: CO certification serves as J&A approval $\leq$ \$10M, *See [J&A Template Guidance](https://usaf.dps.mil/sites/AFCC/AQCP/KnowledgeCenter/SitePages/DAF-Contracting-Compass/Part-6---Competition-Requirements.aspx#exceptions-to-full-and-open-competition-mandatory) at <https://usaf.dps.mil/sites/AFCC/AQCP/KnowledgeCenter/SitePages/DAF-Contracting-Compass/Part-6---Competition-Requirements.aspx#exceptions-to-full-and-open-competition-mandatory>* J&A Template Guidance tab

Date	Contracting Officer (RFO 6.104-1(12))	Signature
26 March 2026	[REDACTED]	[REDACTED]
Date	Technical and Requirements Personnel (RFO 6.104(b))	Signature
25 March 2026	[REDACTED]	[REDACTED]

COORDINATION

APPROVALS (RFO 6.104-2(a) Table 6-1 & R-DFARS 206.104-72 Table 206.1)

See [J&A Template Guidance](https://usaf.dps.mil/sites/AFCC/AQCP/KnowledgeCenter/SitePages/DAF-Contracting-Compass/Part-6---Competition-Requirements.aspx#exceptions-to-full-and-open-competition-mandatory) (<https://usaf.dps.mil/sites/AFCC/AQCP/KnowledgeCenter/SitePages/DAF-Contracting-Compass/Part-6---Competition-Requirements.aspx#exceptions-to-full-and-open-competition-mandatory>) - Justification Approvals tab

NOTE 1: A signature block will appear here (replacing these notes) based on the "Dollar Value of this Acquisition" selected above. Since most digital signatures that include date/time-stamps are redacted before they are made publicly available, always insert the date in the "Date" cell when affixing a digital signature to this document.

Department of the Air Force: Justification for Other Than Full and Open Competition

I. Agency and Contracting Activity (RFO 6.104-1(a)(1)):

Air Force Materiel Command
AFTC/PZZG
5 South Wolfe Ave.
Edwards AFB, CA 93524.

II. Nature and/or description of the action being approved (RFO 6.104-1(a)(2)):

The [REDACTED] has a Sole Source requirement for the Siemens Building Management System (BMS) which is a centralized air-gapped alarm notification system. The requested equipment is specific to Siemens and as ancillary equipment to the current Siemens system, only the Siemens manufactured equipment can fulfill this requirement due to existing items being manufactured by Siemens and the equipment only being compatible with Siemens produced controllers.

III. Description of supplies/services required to meet agency needs (RFO 6.104-1(a)(3)):

The requirement is for one (1) centralized alarm notification cabinet located in the communications room adjacent to the Building Automation System (BAS) front end.

The system shall monitor up to twenty-four (48) discrete alarm inputs, representing up to eight (16) alarm points per building across three (3) buildings. Alarm notifications shall be transmitted using stacked auto-dialer devices capable of delivering prerecorded voice messages to designated phone numbers.

The system shall operate independently of the building network and shall not require INTERNET connectivity.

HARDWARE:

- One (1) Siemens PXC-series controller
- Relay expansion modules sufficient to support twenty-four (48) alarm inputs
- One (1) 24VDC power supply
- Six (6) auto-dialer devices (8 inputs per device)
- UPS battery backup system to maintain operation during power loss
- Internal wire management and labeling

All components shall be mounted, wired, and tested within the cabinet assembly.

IV. Statutory Authority Permitting Other Than Full and Open Competition (RFO 6.104-1(a)(4)):

10 U.S.C. 3204(a)(1), Only one responsible source and no other supplies or services will satisfy agency requirements.

V. Rationale for Use of Authority (RFO 6.104-1(a)(5)):

The requested equipment can only be obtained from Siemens as they have no re-sellers. Siemens is currently on contract FA930221D0007 for the Maintenance of Test Support Equipment Controls and Monitoring System (TSECMS). The requested

Department of the Air Force: Justification for Other Than Full and Open Competition

equipment is ancillary to the equipment covered by this contract and will provide Alarm Notifications via telephone when system failures are experienced.

Siemens, Inc is the sole source manufacturer of TSECMS and, as such, is the only vendor who can provide preventive maintenance and service for the system. The software is proprietary to Siemens, and no other company can be licensed to provide the services required. The requested hardware directly supports the on-call emergency system in place, the TSECMS, which provides aircraft and turntable utilities (hydraulics, 400Hz power, PAO and HVAC cooling) for systems under test in the Benefield Anechoic Facility (BAF), Joint Simulation Environment (JSE), and the Integrated Facility for Avionics System Test (IFAST) Edwards AFB, buildings 1020,1030 and 1040.

Previous awards referenced:

FA930221D0007 - Maintenance and Support for Test Support Equipment Controls and Monitoring System

FA930216D0005 - Maintenance and Support for Test Support Equipment Control and Monitoring System

VI. Integrated Market Analysis and Efforts to Solicit Competition (RFO 6.104-1(a)(6), (8), and (10)):

A notice of intent to sole source will be posted to the GFP IAW RFO 6.104-1(a)(6) to ensure that Siemens is the only capable vendor. Market research was conducted by researching the Internet for potential resellers of the hardware required, but no additional sources offered the required items. Siemens also provided a letter stating that only Siemens specialists have access to the service tools, technical service bulletins, and system software updates. If solicited through open market, there is a reasonable expectation that the potential awarded vendor would hire Siemens as a subcontractor and operate as a pass through, thus making the process inefficient and the government would incur additional costs for no additional benefit.

VII. Determination of Fair and Reasonable Cost (RFO 6.104-1(a)(7)):

The Contracting Officer is responsible for evaluating, determining, and documenting the anticipated contract cost/price is fair and reasonable in accordance with RFO Subpart 15.4, Contract Pricing.

VIII. Any Other Facts Supporting the Justification (RFO 6.104-1(a)(9)):

A system for cooling, polyalphaolefin, power, and hydraulics is in place for the turntables in the Benefield Anechoic Chamber. Changing the system in place would need a total restructure of an 80-foot, 175-ton turntable which would costs substantially higher and take significantly more time than just installing one centralized alarm cabinet for the system in place.

IX. Actions to Overcome Barriers to Competition (RFO 6.104-1(a)(11)):

The Government will continue to evaluate opportunities to increase competition for future requirements. However, the current procurement is constrained by the existing Siemens Desigo Building Automation System (BAS) architecture installed at the facility. The Siemens PXC-series controller and associated components are proprietary and can only be programmed, configured, and integrated using Siemens-specific software tools and licensed technicians. The only opening to remove barriers competition would be when the current platform is overhauled to a different system. The government will consider procuring non-proprietary architectures to allow multiple vendors to compete. However, this may be difficult since the

Department of the Air Force: Justification for Other Than Full and Open Competition

chamber is highly specialized and are built with specific designs.