


AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE		PAGE 1 OF 3 PAGES	
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0001		3. EFFECTIVE DATE 03/26/26		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO. (If applicable) 25-0448	
6. ISSUED BY NAVFAC Mid-Atlantic Resident Officer in Charge of Construction 1107A Birch Street Camp Lejeune, NC 28547-2521		7. ADMINISTERED BY (If other than Item 6) See Item 6		7. ADMINISTERED BY (If other than Item 6) See Item 6			
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)		9A. AMENDMENT OF SOLICITATION NO. N40085-26-R-9019	
				X		9B. DATED (SEE ITEM 11) 3/3/26	
						10A. MODIFICATION OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 11)	
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended, ☒ is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.						
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).						
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:						
	D. OTHER (Specify type of modification and authority)						
E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) 25-0448 B128 FREEZER DOOR REPLACEMENT Amendment 0001, Answer Requests for information The time and date for receipt of proposals remains unchanged. This amendment should be acknowledged when your proposal is submitted. Failure to acknowledge the amendment may constitute grounds for rejection of a proposal. See Continuation Page(s)							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
(Signature of person authorized to sign)				(Signature of Contracting Officer)			

CONTINUATION SHEET

1. QUESTION: Is there a data tag in the box. We will need a model and serial # for a quote.
Are you looking for the physical door itself with hinges and latch?

ANSWER: See attached for door details.

2. All other terms and conditions remain unchanged.



DATE _____

SIGNED _____

SIGNED APPROVAL _____


PLEASE READ

THIS DRAWING HAS BEEN CAREFULLY CHECKED BY OUR DRAWING
ENGINEER. HOWEVER, CHECKS OF INTERPRETATION CAN
ONLY BE SO GOOD AS THE SKILL OF THE DRAWING ENGINEER.
APPROVED: BE CERTAIN THAT YOU CHECK YOUR CAREFULLY
WITH RESPECT OF APPROVED DRAWINGS BY SKILL.

SECTION VIEW
THRU ENTRANCE DOOR

NOTE: THIS INCLUDES WALLS AND CEILING PANELS.

NOTE-A: SLAB URETHANE SHEETS (STAGGER ALL JOINTS):



501-10 1/2" +5/8" ASSEMBLY TENSILE

1000

- LOADING HEIGHT - AT LE
- INDOOR

50'-10 1/2" X 14'-5 1/2" X 9'-6"

EXTERIOR FINISH - STAINLESS STEEL

MAINTAINED BETWEEN TOP OF PRODUCT AND CEILING PANELS

INTERIOR FINISH

- FOAMED IN-PLACE Poured URETHANE
EXTERIOR FINISH

- CHANNEL TO SUPPOR
- SUPERDOOR- 3RD HIN
- WEST LIGHT MANNA

DOORS/ACCESSORIES

- BLOWER COILS WILL NOT BE SUSPENDED

- EXTERIOR CROSSOVER CURDS
- 14" x 24" OBSERVATION WINDOW
- POLISHED HARDWARE

②

GENERAL NOTES

⑧ - NOTE: BALLY TO F

(4) - NOTE: BALLY TO FURNISH VERTICAL AND CEILING CLOSURE TRIM PLEASE ADVISE SIZE AND QUANTITY, ALL FASTENERS AND

JUNCTION 1

FOR ALL JUNCTION BOXES FOAMED IN PLACE, BALLY TO FILL CONDUIT WITHIN VERTICAL PANEL EXTENDING FROM JUNCTION TO THE TOP EDGE OF THE VERTICAL PANEL. BALLY WILL

(8) - NOTE:



ITEM	QTY	MOUNT	USE	SIZE	MT C/L	ITEM
1	2	MT VERTICAL	THURS	4' X 4'	TBO	FREEZER

FURNISH A CONDUIT EXTENSION WITH NIPPLE AND JOINT TO
TO THE TOP EDGE OF THE VERTICAL PANEL. BALLY WILL ALSO
CONDUIT, AND SECURE THE CONDUIT TO THE PANEL WITH
ALL ADDITIONAL WIRE STRIPS, 1-ROCK, AND JOINT TO
J-BOX LOOSE

⑧ - NOTE: BALLY TO FURNISH (2) 4" X 4" X 48", 16 GA. S/S CORNER GUARDS.
 ⑦ - NOTE: BALLY TO FURNISH (2) RHODES TIMERS FOR VERTICAL MOUNT.

④ - NOTE: BALLY TO FURNISH VERTICAL AND CEILING CLOSURE TRIM. PLEASE ADVISE SIZE AND QUANTITY, ALL FASTENERS AND

② - NOTE: BALLY TO FINISH (10) FLUORESCENT LIGHTS. BULBS BY OTHERS. PANEL BASE ATTACHMENT.

CANNOT BE SUSPENDED DIRECTLY FROM BALLY CEILING PANELS.

- POLISHED HARDWARE
- RHODES TIMER (2 DOORS)

- PROVISIONS FOR CYLINDER LOCK AND PADLOCK
- ANTIMICROBIAL NON-PIVOTING S/S LATCH

- (2) 36" X 83 3/8" LEFT SWING HINGED WALK-IN DOOR
 - (2) 36" X 83 3/8" RIGHT SWING HINGED WALK-IN DOOR

INTERIOR FINISH - STAINLESS STEEL

EXTERIOR FINISH

- LOADING HEIGHT - AT LEAST 18" OF OPEN SPACE MUST BE MAINTAINED BETWEEN TOP OF PRODUCT AND CEILING PANELS

(1/FLOOR, EXTENDED HEIGHT)

.....