

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE		PAGE 1 OF 2 PAGES	
2. AMENDMENT/MODIFICATION NUMBER 0003		3. EFFECTIVE DATE 27 March 2026		4. REQUISITION/PURCHASE REQUISITION NUMBER		5. PROJECT NUMBER (If applicable)	
6. ISSUED BY NAVFACYSCOM MID-ATLANTIC PWD NORFOLK FACILITIES ENGINEERING & ACQ DIV 9324 VIRGINIA AVENUE NORFOLK, VA 23511-3095		CODE N40085		7. ADMINISTERED BY (If other than Item 6)		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code)				(X)		9A. AMENDMENT OF SOLICITATION NUMBER	
				(X)		N4008526R0098	
				(X)		9B. DATED (SEE ITEM 11) 05 March 2026	
				()		10A. MODIFICATION OF CONTRACT/ORDER NUMBER	
CODE				FACILITY CODE		10B. DATED (SEE ITEM 13)	
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended. ☒ is not extended.							
Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.							
CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.						
()							
()	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation data, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).						
()	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:						
()	D. OTHER (Specify type of modification and authority)						
E. IMPORTANT: Contractor ☐ is not ☐ is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)							
N4008526R0098; SP-312 Chiller Replacement, Naval Station Norfolk (NSN), Norfolk, Virginia.							
See continuation pages:							
Contact POC: Jordan Cashwell, (757) 341-0548, jordan.r.cashwell.civ@us.navy.mil							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
(Signature of person authorized to sign)				(Signature of Contracting Officer)			

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES**AMENDMENT 0003**

The purpose of this amendment is to provide the following:

1. Provide responses to Pre-Proposal Inquiries (PPI).

PRE-PROPOSAL INQUIRY (PPI) RESPONSES:

PPI #	QUESTION	RESPONSE
1	Can all chiller replacement activities take place over the weekend (Demo to start on Friday PM and New Chiller Start up by Sunday PM) that would eliminate a temporary chiller requirement?	Yes, all chiller replacement activities can take place over the weekend.
2	Please confirm that a Level 2 QC/SSHO is required of this contract since there are no specifications?	Yes, a Level 2 QC/SSHO is required.
3	Can QC/SSHO/Superintendent be the same individual?	Yes, QC/SSHO/Superintendent can be the same individual.
4	Will a QC & Site Specific AP Plan be required to be submitted under this contract?	Yes, a QC & Site Specific AP Plan is required.

(End of Summary of Changes)