

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE	PAGE 1	OF PAGES 3
2. AMENDMENT/MODIFICATION NO. 0002		3. EFFECTIVE DATE 03/27/2026		4. REQUISITION/PURCHASE REQ. NO. 7495214		5. PROJECT NO. (If applicable)
6. ISSUED BY CG MCAS Cherry Point FACILITIES, ROICC B-87, 748 Roosevelt Blvd. PSC BOX 8006 CHERRY POINT, NC 28533		Code N40085		7. ADMINISTERED BY (If other than item 6.)		Code
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) AMENDMENT MUST BE ACKNOWLEDGED WITH YOUR PROPOSAL				☒	9A. AMENDMENT OF SOLICITATION N400857495214	
					9B. DATED (SEE ITEM 11)	
				☐	10A. MODIFICATION OF CONTRACT/ORDER NO.	
					10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE				

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers ☐ is extended ☒ is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (if required)

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS,
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

- ☐ A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
- ☐ B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).
- ☐ C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
- ☐ D. OTHER: (specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not ☐ is required to sign this document and return **original** to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

7495214 Repair Leaking Domestic Hot-Water and Cold-Water Lines Bldg 4389, Marine Corps Air Station Cherry Point, NC

The purpose of this amendment is to answer pre-award PPIs.

The cut off for pre-award PPIs will continue to be 27 March 2026 at 12:00 PM local time.

The proposal due date of 03 April 2026 at 12:00 PM local time remains unchanged.

All other contract terms and conditions remain unchanged.

See attached.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR (Same as Item 8) _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)	16C. DATE SIGNED

RFI Responses:

The SOW states that the contractor must inspect and install proper cathodic protection as necessary. During the site visit on 3/23/2026 there was no cathodic protection identified on any of the existing water pipes in the three areas we observed the leaks. However, the leaks appeared to be weeping at solder joints that have failed on either 90° elbows or coupling joints. The water piping did not appear to be corroded; however, it was green at the joints from where the solder joints were not cleaned after being soldered, which is typical when piping is not wiped clean after the solder is heated and cooled down. Being these leaks are due to failed solder joints and not pipe corrosion, will we still be required to provide cathodic protection?

Response:

No valves require replacement

If cathodic protection is required, please specify locations, quantity of piping, and the required method so costs can be accurately included.

Response:

Not Required

Amendment 0001 states work will continue during an after-hours shutdown. Please define the shutdown window (start/end times).

Response:

Weekdays between 1700 and 0600 or weekends.

After repairs, what testing will be required? Should the system be tested with street pressure? Being this is an existing building, we want to make sure we don't overpressure the piping and possibly cause more leaks down the line during a shutdown period. Also, who is responsible for verification and acceptance?

Response:

Testing with street pressure will be adequate.

Is chlorination required after repairs?

Response:

No

Who is responsible for turning off the water supply and draining the systems? Will this be done by the hospital maintenance department, or will the contractor be required to shutdown the water and drain system?

Response:

The NHCCP Facilities Department will assist the contractor in securing the water so that the work can be accomplished. The contractor will be responsible for draining the system.