

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE		PAGE OF PAGES	
				1		7	
2. AMENDMENT/MODIFICATION NO. 0006		3. EFFECTIVE DATE 12-FEB-2026		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO. (If applicable)	
6. ISSUED BY NAVFACSYS COM MID-ATLANTIC CONTRACTING CORE 9324 VIRGINIA AVENUE NORFOLK VA 23511-3095		CODE		7. ADMINISTERED BY (If other than item 6)		CODE	
				See Item 6			
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X		9A. AMENDMENT OF SOLICITATION NO. N40085-25-R-2663	
				X		9B. DATED (SEE ITEM 11) 11/03/2025	
						10A. MOD. OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer ☒ is extended, ☐ is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15 and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) Q1075 SOF Operations Building Addition and Renovation, Naval Air Station Oceana, Dam Neck Annex, Virginia Beach, Virginia Contract POC: Demetrice Jenkins, demetrice.jenkins2.civ@us.navy.mil SEE SF 30 BLOCK 14 CONTINUATION PAGE Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
				TEL: _____ EMAIL: _____			
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
(Signature of person authorized to sign)				BY			
				(Signature of Contracting Officer)			

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

The following have been added by full text:

AMENDMENT 0006

The purpose of this amendment is to incorporate the following:

1. Provide a proposal due date extension
2. Provide Pre-Proposal Inquiries (PPI) Responses
3. Provide Amendment 0006 Continuation Sheet (attached separately)
4. Provide Revised Drawings (attached separately)
5. Provide Revised Specification Sections (attached separately)

-
1. The proposal due date is extended from 18 February 2026 to 27 February 2026 at 02:00PM EST.
-

2. Pre-proposal Inquiries

PPI#	Reference			Question	Response
	Page	Section	Paragraph		
6				Under spec section 01 30 02.00 22 Page 2 it mentions the AV option is \$657,700.00. However the bid form shows \$672,800.00. Which is correct?	See Amendment 0006, continuation sheet Section 01 30 02.00 22 DESIGN, PROCUREMENT, AND INSTALLATION OF AUDIOVISUAL EQUIPMENT. \$672,800.00 is the correct amount. The specification will be amended to reflect the revised total.
13	Bid Price Schedule	Line Items 0002, 0003, and 0004	HAR	The Bid Price Schedule provided with the Solicitation came pre populated with the HAR listed at 5% and the totals already filled in. Typically, these lines are left blank for the contractor to complete with their bid. Please provide a revised Bid Price	The Government intends to evaluate all proposing contractors based on 5% HAR.

				Schedule with these lines blank or confirm that the government intends to evaluate all proposing contractors based on this 5% HAR amount listed.	
19	Bid Price Schedule	Line Item 0004, Option Item No. 3	HAR?	The Bid Price Schedule does not provide blank lines for the insertion of the general contractor's HAR percentage amount or the correct final total for ESS. Please correct.	There is no HAR for ESS.
28	TY103, TY104	08 71 00	Hardware Sets	Drawings TY103 and TY104 show X-10 locks at doors 208, 218B and 222. Door Hardware Sets 7 and 13.1 in specification section 08 71 00 list several other doors requiring x-10 locks. Please clarify the correct quantity and location of x-10 locks and provide amended TY drawing sheets and/or hardware schedules.	See Amendment 0006 continuation sheet. AE601 and specifications have been updated (File name: AE601 DOOR SCHEDULE).
32	AE111	07 60 00		Roof plan AE111 calls for the slope of the area B new addition to match that of the existing portion of the building to the North. Demolition drawing AD107 calls for the removal of the two existing scuppers, downspouts, and conductor heads, and for an expansion joint to be placed at the new addition in area B. Is the intent to leave the scupper openings in place to allow water to flow? Is there any other sheet metal that is required at those openings? Please provide specific and accurate details.	See Amendment 0006, continuation sheet. AD107 and AE111 have been updated (File names: AD107 ROOF DEMOLITION PLAN and AE111 EXTERIOR ELEVATIONS).
33	AE111/AE503	07 60 00		Keynote 89 on AE111 calls for a building expansion joint to be placed between the new addition in area B and the existing structure. Detail B1/AE503 shows the new roof at a higher elevation than the existing roof. Please provide more information regarding the flow of water between the existing and new roofs at area B.	See Amendment 0006, continuation sheet. AE111 has been updated (File name: AE111 EXTERIOR ELEVATIONS).

34	GI011/GI012	07 84 00		Life safety drawings show that the elevator shaft, portions of the electrical room walls, and portions of the new walls for the additions are not fire rated. No walls on the second floor are shown as fire rated. Please confirm the fire-rated walls as shown on the life safety drawings are correct.	See Amendment 0006, continuation sheet. Life Safety sheets have been updated (File Name: GI011 and GI012_0100 Life Safety).
49	General			Should imported structural backfill material and compaction be included in CLIN0001E unit price?	This is addressed in the bid price schedule under Additional Line Items and Bid Notes.
50	General			Should imported structural backfill material and compaction be included in CLIN0001H unit price?	This is addressed in the bid price schedule under Additional Line Items and Bid Notes.
53	General			Please confirm all AV and Security components, including infrastructure, conduit, boxes and pathways are included in CLINS 0003 and 0004.	Infrastructure, conduit, boxes and pathways are included in the base bid.
54				Please list the vendor/s that currently services HVAC Control system for the base.	There are no particular vendors that serve this portion of Dam Neck Annex.
56				1. General (GC): (a) What is the estimated completion date? (b) May we exclude composite cleaning of others' trash? (c) May we exclude blocking? (d) May we exclude joint sealants? (e) May we exclude motorization/electrical? (f) f. May we exclude shades at: i. Level 01? ii. Doors, door sidelites, door transoms, storefronts, interior glazing? (g) According to the drawings, I am seeing [DRWS1] shades at approximately [Qty 17 @ 48x60"]. Attached is my Floor Plan OST. Please confirm this is accurate.	Bid as specified.

58	3,4	28 31 70	1.3.1 A	Specification section calls for the existing Siemens MXL panel to be "migrated" to a Siemens Desigo FC2025. This model fire panel is proprietary to only one vendor in the area. The Siemens Cerberus Pro FC922/24 has all of the same capabilities and compatibility as the FC2025, and is not limited to one vendor. It is the exact same panel. Is it permissible to provide a Siemens Cerberus Pro FC-922 in lieu of the FC2025?	Bid as specified.
67	AE302			Detail A1/AE302 does not show a waterproof membrane between the architectural precast panel and backfill on the exterior of the building. Please confirm waterproofing is not required in this scenario.	See Amendment 0006, continuation sheet. Sheet AE302 revised (File Name: AE302 WALL SECTIONS).
80		01 45 00	1.5.1.2	Specification section 01 45 00 1.5.1.2 states the QC Qualifications as, "An individual with a minimum of 10 years combined experience in the following positions: Project Superintendent, QC Manager, Project Manager, Project Engineer or Construction Manager on similar size and type construction contracts which included the major trades that are part of this Contract. The individual must have at least two years experience as a QC Manager." Other recent NAVFAC projects of similar size, scope and complexity have allowed an individual with five years construction experience and a bachelor's degree or higher in an applicable engineering or architecture degree program and at least two years experience as a QC to suffice as well. Please confirm that this alternative experience level can suffice for this project.	The specification is accurate as written. Bid as specified.

81	Drawing Sheet PL102	11 00 00	Vehicle Storage Lifts	Upon reviewing product data on the Bendpak HD-973PX, there is a requirement for a power supply and compressed dry air supply. The power supply is detailed on EP101, however, there are no details or notes on compressed air connections for the vehicle lifts on sheet PL102. From the manufacturer's product data, each vehicle lift has a Pushbutton Air Valve that requires a supply of compressed dry air (75-125psi @ 3cfm), the connection to the valve is made via a straight expander fitting. Please provide a revised PL102 that details a compressed air connection point at each vehicle lift.	See Amendment 0006, continuation sheet. Sheets PL102 and PL104 revised (File Name: PL102 and PL104).
90		08 11 13		Hollow metal door specification mentions blast resistant doors at exterior openings. Per the door schedule, a few of the exterior openings also require STC ratings. Blast resistant doors cannot also be STC rated. (1) Are exterior doors required to be blast resistant? (1a) If so, does this supersede STC ratings? (2) Please verify the following for blast resistant rating: (2a) What is the required explosive charge weight? (2b) What is the required level of protection?	See Amendment 0006 Continuation Sheet: Section 08 11 13 STEEL DOORS AND FRAMES. Doors are required to swing outward to meet the minimum requirements of UFC 4-010-01; doors are not required to be blast rated. Doors are to be STC rated as scheduled and specified.

3. Amendment 0006 Continuation Sheet is provided with this amendment (attached separately).

4. Revised Drawing Attachments are provided with this amendment (attached separately).

See separately attached revised PDF files labeled as follows:

GI011 and GI012_0100 Life Safety
AD107 ROOF DEMOLITION PLAN
AE202 EXTERIOR ELEVATIONS
AE302 WALL SECTIONS
AE601 DOOR SCHEDULE
PL102 and PL104

AE704 CURTAIN WALL & STOREFRONT DETAILS
AE111 EXTERIOR ELEVATIONS

5. Revised Specification Sections are provided with this amendment (attached separately).

See separately attached revised PDF files labeled as follows:

13 49 20.00 10 RFI EMI SHIELDING
08 71 00 Door Hardware Sets_251202
13 49 20.00 10 RFI EMI SHIELDING

(End of Summary of Changes)