

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT		BPA NO.	1. CONTRACT ID CODE	PAGE 1	OF 2	PAGES
2. AMENDMENT/MODIFICATION NUMBER 0001		3. EFFECTIVE DATE 04-07-2026	4. REQUISITION/PURCHASE REQ. NUMBER		5. PROJECT NUMBER (if applicable)	
6. ISSUED BY Department of Veterans Affairs Regional Procurement Office West (RPOW) 3237 Peacekeeper Way Building 200 Suite 204 McClellan Park CA 95652		CODE 36C24W	7. ADMINISTERED BY (If other than Item 6) Department of Veterans Affairs Regional Procurement Office West (RPOW) 3237 Peacekeeper Way Building 200 Suite 204 McClellan Park CA 95652		CODE 36C24W	
8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code) To all Offerors/Bidders			(X)	9A. AMENDMENT OF SOLICITATION NUMBER 36C24W26Q0137		
			☒	9B. DATED (SEE ITEM 11) 04-01-2026		
			☐	10A. MODIFICATION OF CONTRACT/ORDER NUMBER		
				10B. DATED (SEE ITEM 13)		
CODE		FACILITY CODE				

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

- ☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended, ☒ is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
- (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
☐	
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
☐	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☒ is not, ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

The purpose of this amendmnet is to answer vendor questions.

See page two.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)		16B. UNITED STATES OF AMERICA _____ (Signature of Contracting Officer)	
15C. DATE SIGNED		16C. DATE SIGNED	

VENDOR QUESTIONS

Question 1. Should the system be able to hear the tags across the whole floor vs only hearing the tags when at exits? The VAMCs wherein our elopement prevention systems are operating, have required full coverage on the floors to ensure staff are notified instantly when a tagged patient's battery needs replacing and/or if the patient attempts to remove their tag (e.g., full coverage allows for an instant tamper alert to staff). Most instances of elopement occur when patient batteries expire and/or they remove their band outside the range of a covered exit.

Answer 1. Yes, the system will need tamper monitoring and battery monitoring for the bracelets. Coverage area on each floor is about 15,000 sqft.

Question 2. Will the system need to integrate with you existing access control system (mag-locked doors) or will maglocks need to be installed.

Answer 2. Provide and install new mag-locks for the eight doors. Current doors do not have mag-locks. The locking system must be NFPA compliant.

Question 3. Would you like the system to integrate with your elevator controls (e.g., lock elevator cab if an elopement-risk patient enters).

Answer 3. Elevators in this area are already access controlled, no interlock necessary.