

D/B/B – Q-1075 SOF Bldg Additions

Dam Neck, Va

CN Comm. 8435

DOOR HARDWARE SETS

General Note(s):

- Refer to Door Schedule for identification of fire & smoke barrier ratings.
- All door hardware identified as stainless steel (SS) to be type 316, to include fasteners, clips, anchors, accessories, etc.
- All doors identified as fire resistant and / or smoke barrier rated to have hardware approved for said rating as part of labeled assembly.
- Sound attenuation sealing components to be part of the hardware manufacturers / suppliers tested assembly with associated supporting shop drawings and test reports.
- All components, accessories, trim, wiring or harnesses required to make the door assembly operational to be provided as part of the total opening solution, whether or not these parts are explicitly identified in these Hardware Sets.
- Coordinate door hardware design intent with door details in drawing set.

Qty	Description	Finish	ANSI/BHMA #
-----	-------------	--------	-------------

HDW-1 – Exterior Door – Entrance Door - STC 45 (min)

Door(s): 107B; 112B; 121B; 122D; 123B; 124B;124C

1.5 pr	Hinge 4 1/2" x 4 1/2" (NRP)	US32D	A5111
1 ea	Mortise Lockset – fail secure (un-secure side)	US32D	F04
1 ea	Electric strike	US32D	-
1 ea	Card reader w/ PIN pad (un-secure side)	-	-
1 ea	High security switch (HSS) – recess mounted	-	-
1 ea	Closer	Alum	C02011
1 set	Gasket weatherstripping (head & jamb) – frame mounted	Alum/Neo	R3C253
1 set	Gasket weatherstripping (head & jamb) – door mounted	Silicone	R0E117
1 ea	Door Drip at door head	Alum	R3Y976
1 ea	Door bottom w/ Rain Drip	Alum/Neo	R3C513
1 ea	Threshold	Alum	J35229

Note(s):

- Lockset to be heavy duty (316) SS with lever handles.

D/B/B – Q-1075 SOF Bldg Additions

Dam Neck, Va

CN Comm. 8435

- Card reader finish to be manufacturer's standard, mount at strike side of door at 48" AFF.
- HSS to meet or exceed UL 634 Level 1 High Security Standard. This HSS to be integrated into existing security alarm system.
- Card reader(s) & HSS to be government provided under separate contract.
- Gasket weatherstripping, door bottom, and threshold assemblies to be delegated design as part of the door hardware manufacturer's opening system solution.
- Threshold type to be 3" deep (min) x 1/2" high (max) x full width of door(s) between frame, panic latching exit saddle type with thermal break & neoprene seal.

HDW-2.0 – Exterior Door – Utility Room Door - STC 45 (min)

Door(s): 120, 125

3 pr	Hinge 4 1/2" x 4 1/2" (NRP)	US32D	A5111
1 ea	Mortise Lockset (active leaf)	US32D	F07
1 ea	Dummy handle (in-active leaf)	US32D	-
1 ea	Strike installed on in-active leaf for lockset latching	US32D	-
1 ea	Closer (active leaf only) w/ hold open function	Alum	C02011
1 ea	Astragal (T-type)	Alum	R3Y607
1 pr	Flush bolts	US32D	L05081
1 ea	Dustproof strike	US32D	L05021
2 ea	High security switch (HSS) – recess mounted	-	-
1 ea	Card reader w/ PIN pad (un-secure side)	-	-
1 set	Gasket weatherstripping (head & jamb) – frame mounted	Alum/Neo	R3C253
1 set	Gasket weatherstripping (head & jamb) – door mounted	Silicone	R0E117
1 ea	Door Drip at door head	Alum	R3Y976
2 ea	Door bottom w/ Rain Drip	Alum/Neo	R3C513
1 ea	Threshold	Alum	J35229

Note(s):

- Lockset to be heavy duty (316) SS with lever handles.
- HSS to meet or exceed UL 634 Level 1 High Security Standard. This HSS to be integrated into existing security alarm system.
- HSS to be government provided under separate contract.
- Threshold type to be 3" deep (min) x 1/2" high (max) x full width of door(s) between frame, panic latching exit saddle type with thermal break & neoprene seal.

D/B/B – Q-1075 SOF Bldg Additions

Dam Neck, Va

CN Comm. 8435

HDW-3 – Exterior Door – Overhead Coiling Door

Door(s): 104B; 112C; 123C; 124D; 124E

-	Guide rails & brackets (including hardware)	Galv Stl	-
-	Heavy duty rollers	US32D	-
2 ea	Slide bolt lock (each end)	US32D	-
1 ea	Push button operator	-	<i>By Manuf</i>
1 ea	High security switch (HSS) – surface mounted	-	-
1 set	Gasket weatherstripping (head & jamb seal) – frame mounted	-	<i>By Manuf</i>
1 ea	Bottom seal (bulb type)	Neoprene	<i>By Manuf</i>

Note(s):

- The entire hardware package is the responsibility of the overhead door manufacturer, except for the HSS which will be coordinated with the government.
- HSS to meet or exceed UL 634 Level 2 High Security Standard. This HSS to be integrated into existing security alarm system.
- HSS to be government provided under separate contract.
- Hardware that is not prefinished to be (G90) galvanized steel or 316 stainless steel.

HDW-4 – Interior Door – Overhead Coiling Door

Door(s): 112D; 122B (Fire rated); 122C (Fire Rated)

-	Guide rails & brackets (including hardware)	Galv Stl	-
-	Heavy duty rollers	US32D	-
1 ea	Push button operator	-	-
1 ea	High security switch (HSS) – surface mounted	-	-
1 set	Gasket weatherstripping (head & jamb seal) – frame mounted	-	<i>By Manuf</i>
1 ea	Bottom seal (bulb type)	Neoprene	<i>By Manuf</i>

Note(s):

- The entire hardware package is the responsibility of the overhead door manufacturer, except for the HSS which will be coordinated with the government.
- HSS to meet or exceed UL 634 Level 1 High Security Standard. This HSS to be integrated into existing security alarm system.
- HSS to be government provided under separate contract.
- Hardware that is not prefinished to be (G90) galvanized steel or 316 stainless steel.

D/B/B – Q-1075 SOF Bldg Additions

Dam Neck, Va

CN Comm. 8435

HDW-5 – Interior Door – Aluminum Entrance System Door (vestibule door)

Door(s): 101B

1 ea	Continuous hinge	US28	A31111G
2 ea	Mortise Lockset w/ panic device – fail secure (un-secure side)	US32D	F04
1 ea	Card reader w/ PIN pad (un-secure side)	-	-
2 ea	Electric strike	US32D	-
2 ea	High security switch (HSS) – surface mounted	-	-
2 ea	Closer	Alum	C02021
1 set	Gasket weatherstripping (head & jamb)	-	<i>By Manuf</i>
1 ea	Door bottom w/ Rain Drip	Alum/Neo	R3C513
1 ea	Threshold	Alum	J35229

Note(s):

- Lockset to be heavy duty (316) stainless steel with exterior lever handle and interior panic device.
- HSS to meet or exceed UL 634 Level 1 High Security Standard.
- Card reader(s) & HSS to be government provided under separate contract.
- Balance of door hardware, not shown herein, to be responsibility of aluminum entrance manufacturer / supplier.
- Threshold type to be 3" deep (min) x 1/2" high (max) x full width of door(s) between frame, panic latching exit saddle type with thermal break & neoprene seal.

HDW-6 – Exterior Door – Aluminum Entrance System Door

Door(s):

2 ea	Continuous hinge	US28	A31111G
2 ea	Mortise Lockset w/ panic device	US32D	F01
2 ea	Closer	Alum	C02021
2 ea	Threshold	Alum	J32131

Note(s):

- Lockset to be heavy duty (316) stainless steel with exterior lever handle and interior panic device.
- Balance of door hardware, not shown herein, to be responsibility of aluminum entrance manufacturer / supplier.
- Threshold type to be 3" deep (min) x 1/2" high (max) x full width of door(s) between frame, saddle type.

D/B/B – Q-1075 SOF Bldg Additions

Dam Neck, Va

CN Comm. 8435

HDW-7 – Interior Door – Controlled Area Entry - STC 45 (min); Conference Room – STC 50 (min)

Door(s): 208; 218B; 222

1.5 pr	Hinge 4 1/2" x 4 1/2" (NRP)	US32D	A5111
1 ea	Mortise lockset w/ panic device – fail secure (un-secure side)	US32D	F04
1 ea	Card reader w/ PIN pad (un-secure side)	-	-
1 ea	Card reader w/o PIN pad (secure side)	-	-
1 ea	Electric strike	US32D	-
1 ea	High security switch (HSS) – surface mounted	-	-
1 ea	Closer	Alum	C02011
1 set	Gasket weatherstripping (head & jamb) – frame mounted	Alum/Neo	R3C253
1 set	Gasket weatherstripping (head & jamb) – door mounted	Silicone	R0E117
2 sets	Gasket weatherstripping (head & jamb) – door mounted – <i>STC 50 doors ONLY</i>	Silicone	R0E117
1 ea	Door bottom (automatic)	Alum/Neo	R3C300
1 ea	Threshold	Alum	J35229

Note(s):

- Lockset to be heavy duty with exterior lever handle and interior panic device and to be GSA approved pedestrian door lock meeting Federal Specification FF-L-2890B, Type III. Lockset to have integral electromechanical combination lock meeting Federal Specification FF-L-2740. Strike type to be surface mounted and coordinated with manufactures offerings.
- Omit panic device at in-swing doors, to be lever handles both sides – doors: 214A; 215A; 216A; 229A.
- Card reader(s) finish to be manufacturer's standard, mount at strike side of door at 48" AFF.
- HSS to meet or exceed UL 634 Level 2 High Security Standard. This HSS to be integrated into existing security alarm system.
- Card reader(s) & HSS to be government provided under separate contract.
- Gasket weatherstripping, door bottom, and threshold assemblies to be delegated design as part of the door hardware manufacturer's opening system solution.
- Threshold type to be 3" deep (min) x 1/2" high (max) x full width of door(s) between frame, panic latching exit saddle type with thermal break & neoprene seal.

HDW-7.1 – Interior Door – Controlled Area Egress Door (Exit Only) - STC 45 (min)

Door(s): 218A

1.5 pr	Hinge 4 1/2" x 4 1/2" (NRP)	US32D	A5111
1 ea	Mortise Lockset (exit only) w/ panic device	US32D	F31
1 ea	Card reader w/o PIN pad (secure side)	-	-
1 ea	High security switch (HSS) – surface mounted	-	-
1 ea	Closer	Alum	C02011

D/B/B – Q-1075 SOF Bldg Additions

Dam Neck, Va

CN Comm. 8435

1 set	Gasket weatherstripping (head & jamb) – frame mounted	Alum/Neo	R3C253
1 set	Gasket weatherstripping (head & jamb) – door mounted	Silicone	R0E117
1 ea	Door bottom (automatic)	Alum/Neo	R3C300
1 ea	Threshold	Alum	J35229

Note(s):

- Lockset to be heavy duty with interior panic device with no exterior trim.
- Card reader(s) finish to be manufacturer's standard, mount at strike side of door at 48" AFF.
- HSS to meet or exceed UL 634 Level 2 High Security Standard. This HSS to be integrated into existing security alarm system.
- Card reader(s) & HSS to be government provided under separate contract.
- Gasket weatherstripping, door bottom, and threshold assemblies to be delegated design as part of the door hardware manufacturer's opening system solution.
- Threshold type to be 3" deep (min) x 1/2" high (max) x full width of door(s) between frame, panic latching exit saddle type with thermal break & neoprene seal.

HDW-8 – Interior Door – Suite Entry Door - STC 45 (min)

Door(s): 102; 103; 104A; 105; 107A; 111; 112A; 114A; 114B; 121A; 123A; 124A; 201; 206A; 207A; 207B; 228

1.5 pr	Hinge 4 1/2" x 4 1/2" (NRP for reverse swing doors)	US32D	A5111
1 ea	Mortise Lockset – fail secure (un-secure side)	US32D	F04
1 ea	Card reader w/ PIN pad (un-secure side)	-	-
1 ea	High security switch (HSS) – surface mounted	-	-
1 ea	Closer	Alum	C02011
1 set	Gasket weatherstripping (head & jamb) – frame mounted	Alum/Neo	R3C253
1 set	Gasket weatherstripping (head & jamb) – door mounted	Silicone	R0E117
1 ea	Door bottom (automatic)	Alum/Neo	R3C300
1 ea	Threshold	Alum	J35229

Note(s):

- Lockset to be heavy duty with lever handles.
- Card reader(s) finish to be manufacturer's standard, mount at strike side of door at 48" AFF.
- HSS to meet or exceed UL 634 Level 1 High Security Standard. This HSS to be integrated into existing security alarm system.
- Card reader(s) & HSS to be government provided under separate contract.
- Gasket weatherstripping, door bottom, and threshold assemblies to be delegated design as part of the door hardware manufacturer's opening system solution.
- Threshold type to be 3" deep (min) x 1/2" high (max) x full width of door(s) between frame, panic latching exit saddle type with thermal break & neoprene seal.

D/B/B – Q-1075 SOF Bldg Additions

Dam Neck, Va

CN Comm. 8435

HDW-9 – Interior Door – Office Door - STC 45 (min)

Door(s): 202; 203; 209; 210A; 211; 219; 220; 221; 230; 231; 232; 233

1.5 pr	Hinge 4 1/2" x 4 1/2"	US32D	A5111
1 ea	Mortise Lockset – fail secure (un-secure side)	US32D	F04
1 ea	Card reader w/ PIN pad (un-secure side)	-	-
1 ea	High security switch (HSS) – surface mounted	-	-
1 set	Gasket weatherstripping (head & jamb) – frame mounted	Alum/Neo	R3C253
1 set	Gasket weatherstripping (head & jamb) – door mounted	Silicone	R0E117
1 ea	Door bottom (automatic)	Alum/Neo	R3C300
1 ea	Threshold	Alum	J35229

Note(s):

- Lockset to be heavy duty with lever handles.
- Card reader(s) finish to be manufacturer's standard, mount at strike side of door at 48" AFF.
- Doors 202; 203; 230; 231; 232; and 233: HSS to meet or exceed UL 634 Level 1 High Security Standard. This HSS to be integrated into existing security alarm system.
- Doors 209; 210A; 211; 219; 220; and 221: HSS to meet or exceed UL 634 Level 2 High Security Standard. This HSS to be integrated into existing security alarm system.
- Card reader(s) & HSS to be government provided under separate contract.
- Gasket weatherstripping, door bottom, and threshold assemblies to be delegated design as part of the door hardware manufacturer's opening system solution.
- Threshold type to be 3" deep (min) x 1/2" high (max) x full width of door(s) between frame, panic latching exit saddle type with thermal break & neoprene seal.

HDW-9.1 – Interior Door – Conference Room & Training Room Door - STC 50 (min)

Door(s): 224; 229*

1.5 pr	Hinge 4 1/2" x 4 1/2"	US32D	A5111
1 ea	Lockset – fail secure (un-secure side)	US32D	F04
1 ea	Card reader w/ PIN pad (un-secure side)	-	-
1 ea	High security switch (HSS) – surface mounted	-	-
1 set	Gasket weatherstripping (head & jamb) – frame mounted	Alum/Neo	R3C253
2 set	Gasket weatherstripping (head & jamb) – door mounted	Silicone	R0E117
1 ea	Door bottom (automatic)	Alum/Neo	R3C300
1 ea	Threshold	Alum	J35229

Note(s):

- Lockset to be heavy duty with lever handles.
- Card reader(s) finish to be manufacturer's standard, mount at strike side of door at 48" AFF.

D/B/B – Q-1075 SOF Bldg Additions

Dam Neck, Va

CN Comm. 8435

- HSS to meet or exceed UL 634 Level 2 High Security Standard. This HSS to be integrated into existing security alarm system.
- Card reader(s) & HSS to be government provided under separate contract.
- Gasket weatherstripping, door bottom, and threshold assemblies to be delegated design as part of the door hardware manufacturer's opening system solution.
- Threshold type to be 3" deep (min) x 1/2" high (max) x full width of door(s) between frame, panic latching exit saddle type with thermal break & neoprene seal.
- *Door 229 HSS to meet or exceed UL634 Level 1 High Security standard.

HDW-10 – Interior Door –Wellness Room Door

Door(s): 106

1.5 pr	Hinge 4 1/2" x 4 1/2"	US32D	A5111
1 ea	Lockset	US32D	F02
1 ea	Closer	Alum	C02011
1 ea	Occupancy indicator	-	-
3 ea	Silencer (frame mounted on strike side)	Rubber	-L03011
1 ea	Mop plate	US32D	J103
1 ea	Kick plate	US32D	J102
1 ea	Resilient transition – <i>doors 119A ONLY</i>	-	<i>See drawings</i>

Note(s):

- Lockset to be heavy duty with lever handles.
- Occupancy indicator may be standalone piece of hardware or integrated into door lockset, must identify "VACANT" in green or "OCCUPIED" in red.
- At PRC flooring: Threshold type to be 2" deep x 1/2" high (max) x full width of door(s) between frame, marble 'flat bar' type. Marble threshold to be provided & installed by flooring supplier / installer.
- At RFT flooring: Threshold type to be 3" deep x 1/2" high (max) x full width of door(s) between frame, saddle type.

HDW-11 – Interior Door – Corridor / Stair without Card Reader

Door(s): 212

1.5 pr	Hinge 4 1/2" x 4 1/2"	US32D	A5111
1 ea	Mortise Lockset (non-locking) w/ panic device	US32D	F01
1 ea	Closer	Alum	C02011
3 ea	Silencer (frame mounted on strike side)	Rubber	L03011
1 ea	Threshold	Alum	J32191

Note(s):

- Lockset to be heavy duty with exterior lever handle and interior panic device.

D/B/B – Q-1075 SOF Bldg Additions

Dam Neck, Va

CN Comm. 8435

- Threshold type to be 3" deep x 1/2" high (max) x full width of door(s) between frame, saddle type.

HDW-11.1 – Interior Door – Corridor / Stair with Card Reader

Door(s): 109; 122A; 227

1.5 pr	Hinge 4 1/2" x 4 1/2"	US32D	A5111
1 ea	Mortise Lockset (non-locking) w/ panic device	US32D	F01
1 ea	Closer	Alum	C02011
3 ea	Silencer (frame mounted on strike side)	Rubber	L03011
1 ea	Card reader w/ PIN pad (un-secure side)	-	-
1 ea	High security switch (HSS) – surface mounted	-	-

- Lockset to be heavy duty with lever handles.
- Card reader finish to be manufacturer's standard, mount at strike side of door at 48" AFF.
- HSS to meet or exceed UL 634 Level 1 High Security Standard. This HSS to be integrated into existing security alarm system.
- Card reader(s) & HSS to be government provided under separate contract.
- Threshold type to be 3" deep x 1/2" high (max) x full width of door(s) between frame, saddle type.
- *Doors 206B and 223 do not need a threshold, mop plate, or kickplate

HDW-12 – Interior Door – Restroom Door

Door(s): 117A; 117B; 216; 217

1.5 pr	Hinge 4 1/2" x 4 1/2"	US32D	A5111
1 ea	Door pull w/ backplate	US32D	J401 / J407
1 ea	Door push plate	US32D	J304
1 ea	Closer	Alum	C02011
2 set	Gasket weatherstripping (head & jamb) – door mounted	Silicone	R0E117
1 ea	Mop plate	US32D	J103
1 ea	Kick plate	US32D	J102
1 ea	Threshold (by floor finish supplier)	Marble	-

Note(s):

- Threshold type to be 2" deep x 1/2" high (max) x full width of door(s) between frame, marble 'flat bar' type. Marble threshold to be provided & installed by flooring supplier / installer.

D/B/B – Q-1075 SOF Bldg Additions

Dam Neck, Va

CN Comm. 8435

HDW-13 – Interior Door – Storage / Utility with Card Reader

Door(s): 113; 115; 116; 205; 206B*, 215, 223*; 226

1.5 pr	Hinge 4 1/2" x 4 1/2"	US32D	A5111
1 ea	Mortise Lockset	US32D	F07
3 ea	Silencer (frame mounted on strike side)	Rubber	-L03011
1 ea	Mop plate	US32D	J103
1 ea	Kick plate	US32D	J102
1 ea	Threshold	Alum	J32191
1 ea	Card reader with PIN pad	-	-
1 ea	Electric strike	US32D	-
1 ea	High security switch (HSS) – surface mounted	-	-

Note(s):

- Lockset to be heavy duty with lever handles.
- Threshold type to be 3" deep x 1/2" high (max) x full width of door(s) between frame, saddle type.
- Card reader finish to be manufacturer's standard, mount at strike side of door at 48" AFF.
- HSS to meet or exceed UL 634 Level 1 High Security Standard. This HSS to be integrated into existing security alarm system.
- Card reader(s) & HSS to be government provided under separate contract.
- Threshold type to be 3" deep x 1/2" high (max) x full width of door(s) between frame, saddle type.
- *Doors 206B and 223 do not need a threshold, mop plate, or kickplate

HDW-14 – Interior Door – Utility Room Door

Door(s): 108

3 pr	Hinge 4 1/2" x 4 1/2" (NRP)	US32D	A5111
1 ea	Mortise Lockset (active leaf)	US32D	F07
1 ea	Dummy handle (in-active leaf)	US32D	-
1 ea	Strike installed on in-active leaf for lockset latching	US32D	-
1 ea	Astragal (T-type)	Alum	R3Y607
1 pr	Flush bolts	US32D	L05081
1 ea	Mop plate	US32D	J103
1 ea	Kick plate	US32D	J102
1 ea	Dustproof strike	US32D	L05021
1 ea	Card reader w/ PIN pad (un-secure side)	-	-
1 ea	High security switch (HSS) – surface mounted	-	-

D/B/B – Q-1075 SOF Bldg Additions

Dam Neck, Va

CN Comm. 8435

Note(s):

- Lockset to be heavy duty with lever handles.