

1. Pre- proposal Inquiry Responses

PPI #	Page	Section	Paragraph	Question	Response
10	B-102			Can a top bedrock elevation plan, similar to the one given on sheet B-102, be provided for the area around existing building 524 and proposed operations building?	Refer to boring logs shown on drawings and bid accordingly.
11				We are unable to locate the Geotech report. Can you please provide the document?	Geotechnical report will not be provided - please bid per drawings and specifications.
12		Electrical		Regarding the Build America Buy America Act (BABA), please confirm the products in this design and that are specified comply with all BABA requirements or otherwise please: 1. Identify all General Applicability Waivers related to any products, categories of products or manufactured products specified for this project. 2. Name all project level waivers that have been proposed and/or awarded for this project.	Yes, the design conforms to BABA. No waivers have been proposed.
13		Electrical		Because this facility is owned by the United States Federal Government, and is utilized as a Weapons Magazine Facility, we understand that Unified Facilities Criteria ("UFC) 3-520-01 and Unified Facilities Guide Specifications (UFGS) Section 26 05 19.10.10 shall apply for purposes of competitive bidding and project execution. To ensure that the project is bid and constructed in accordance with the applicable regulations and requirements, please confirm that UFC 3-520-01 and	UFC 3-520-01 applies to this project. UFGS Section 26 05 19.10.10 does not apply to this project. All work must be performed in accordance with the plans and specifications.

				UFGS Section 26 05 19.10.10 shall apply to this project. Specifically, please confirm that bidders are permitted to utilize the type(s) of material(s) described in UFC 3-520-01 and Section 26 05 19.10.10 applicable to their scope of work despite any potentially contradictory provisions in the design plans and specifications.	
14		Electrical		Is there a plan holders list or interested contractors list for this project? I didn't see anything posted on the Sam.gov website with this information.	Please see Attachment K - P1102 Site Visit Log for an interested vendors list. An interested vendors list is also available on sam.gov under the subject solicitation.
15				During the Sources Sought Phase several Sources Sought were posted to Sam.gov for specialty items: 1) 30 Interior finish items; 2) Contech stormwater management products; 3) Fire alarm radio transmitter - STAR software by Kingfisher Co.; 4) Electronic Security System; 5) Geobrugg's TECO rock fall system. Can the responders to each sources sought be provided to offerors?	The requested information is unable to be provided.
16		Attachment H		Ref. Attachment H Bid Price Schedule - This document appears to contain language that will determine the scope of work (Rock, Bid Notes, etc.). Will this document become part of the final contract?	Attachment H - P1102 Price Proposal Form will become part of the final contract.