

SECTION 13 49 20.00 10

RFI/EMI SHIELDING
10/07

PART 1 GENERAL

1.1 SUBMITTALS

Government approval is required for submittals with a "G" or "S" classification. Submittals not having a "G" or "S" classification are for Contractor Quality Control approval. Submittals not having a "G" or "S" classification are for information only. When used, a code following the "G" classification identifies the office that will review the submittal for the Government. Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-03 Product Data

EM Shield Window Film; G

Installation; G

PART 2 PRODUCTS

2.1 SYSTEM REQUIREMENTS

2.1.1 General

Provide shielded window film that meets or exceeds minimum attenuation decibel (dB) levels specified. The EM shielding system includes, but is not limited to, the following:

- a. EM shield window film.

2.2 MATERIALS AND EQUIPMENT

2.2.1 Standard Products

Provide materials and equipment which are the standard products of a manufacturer regularly engaged in the manufacture of such products and essentially duplicate items that have been in satisfactory use for at least 2 years prior to bid opening.

2.3 EM SHIELDING EFFECTIVENESS

Provide EM shielded enclosure complete with all filters, doors, and/or waveguides with the following minimum EM shielding effectiveness attenuation. Use minimum magnetic field attenuation of 20 dB at 14 kHz increasing linearly to 50 dB at 200 kHz. Use minimum electric field and plane wave attenuation of 50 dB from 14 kHz to 1 GHz.

PART 3 EXECUTION

3.1 EXAMINATION

After becoming familiar with all details of the work, verify dimensions in the field, and advise the Contracting Officer of any discrepancy before

performing the work.

3.2 INSTALLATION

3.2.1 Manufacturer's Services

Provide the services of a manufacturer's representative who is experienced in the installation, adjustment, and operation of the window film specified.

3.2.2 Surface Preparation

Clean and prepare contacting surfaces to ensure contact with existing glazing.

-- End of Section --