

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE		PAGE OF PAGES	
				1		22	
2. AMENDMENT/MODIFICATION NO. 0008		3. EFFECTIVE DATE 10-MAR-2026		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO. (If applicable)	
6. ISSUED BY NAVFACSYS COM MID-ATLANTIC CONTRACTING CORE 9324 VIRGINIA AVENUE NORFOLK VA 23511-3095		CODE		7. ADMINISTERED BY (If other than item 6) See Item 6		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X		9A. AMENDMENT OF SOLICITATION NO. N40085-25-R-2663	
				X		9B. DATED (SEE ITEM 11) 11/03/2025	
						10A. MOD. OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE				FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer ☒ is extended, ☐ is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15 and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)							
Q1075 SOF Operations Building Addition and Renovation, Naval Air Station Oceana, Dam Neck Annex, Virginia Beach, Virginia Contract POC: Demetrice Jenkins, demetrice.jenkins2.civ@us.navy.mil SEE SF 30 BLOCK 14 CONTINUATION PAGE							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
				TEL: _____ EMAIL: _____			
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA BY		16C. DATE SIGNED	
(Signature of person authorized to sign)				(Signature of Contracting Officer)			

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

The following have been added by full text:

AMENDMENT 0008

The purpose of this amendment is to incorporate the following:

1. Provide a proposal due date extension
2. Provide Amendment 0008 Continuation Sheet (attached separately)
3. Updates to General Requirements (Time of Completion and Liquidated Damages)
4. Provide updated Wage Determination
5. Provide Pre-Proposal Inquiries (PPI) Responses

-
1. The proposal due date is extended from 13 March 2026 to 17 March 2026 at 02:00PM EDT.
-

2. Amendment 0008 Continuation Sheet is provided with this amendment (attached separately).
-

3. Updates to General Requirements:

The following sections have been updated:

Time for Completion:

In accordance with FAR 52.211-10 Commencement, Prosecution, and Completion of Work, the deadline for completion of this task order (including Bid Options) shall be **1,200 calendar days** (including 15 calendar days for submission and approval of bonds and insurance). Consistent with FAR 52.211-10, completion of the entire work ready for use must occur prior to the aforementioned date. The time stated for completion shall include final cleanup of the premises.

Liquidated Damages:

In accordance with FAR 52.211-12 Liquidated Damages, if the Contractor fails to complete the work within the time specified in the task order, the Contractor shall pay liquidated damages to the Government for each calendar day of delay until the work is completed or accepted. See associated liquidated damages per phase below:

Phase	Number of Days	Liquidated Damages
<u>Base Bid + All Options</u>	<u>1,200 Calendar Days</u>	<u>\$1,526.88</u>

-
4. Updated Wage Determination

"General Decision Number: VA20260167 01/30/2026

Superseded General Decision Number: VA20250167

State: Virginia

Construction Type: Building

County: Virginia Beach* County in Virginia.

*INDEPENDENT CITY OF VIRGINIA BEACH

BUILDING CONSTRUCTION PROJECTS (does not include single family homes or apartments up to and including 4 stories).

Modification Number Publication Date

0 01/02/2026

1 01/30/2026

ASBE0024-006 10/01/2024

Rates Fringes

ASBESTOS WORKER/HEAT & FROST

INSULATOR - MECHANICAL (Duct,

Pipe & Mechanical System

Insulation).....\$ 40.77 20.17+a

a. PAID HOLIDAYS: New Year's Day, Martin Luther King Day, Memorial Day, Independence Day, Labor Day, Veterans' Day, Thanksgiving Day, the day after Thanksgiving and Christmas Day provided the employee works the regular work day before and after the paid holiday.

BOIL0045-003 01/01/2025

Rates Fringes

BOILERMAKER.....\$ 38.97 27.39

BRVA0008-001 05/01/2022

Rates Fringes

BRICKLAYER.....\$ 22.44 10.23

ELEV0052-005 01/01/2025

Rates Fringes

ELEVATOR MECHANIC.....\$ 52.06 38.435+a+b

a. PAID HOLIDAYS: New Year's Day, Memorial Day, Independence Day, Labor Day, Veterans' Day, Thanksgiving Day, the Friday after Thanksgiving Day and Christmas Day.

b. VACATIONS: 6% men under 5 years based on regular hourly rate and 8% men over 5 years based on regular hourly rate for all hours worked.

ENGI0147-019 06/01/2025

Rates Fringes

POWER EQUIPMENT OPERATOR

Cranes 90 tons & over
capacity; Tower & Climbing
Cranes with Controls 100
ft. above ground.....\$ 40.99 18.05
Cranes under 90 tons.....\$ 39.99 18.05

IRON0028-006 05/01/2023

Rates Fringes

IRONWORKER, RIGGER.....\$ 30.22 11%+14.24

IRON0028-007 05/01/2024

Rates Fringes

IRONWORKER, STRUCTURAL AND
ORNAMENTAL.....\$ 31.00 18.28

* PLUM0110-008 11/01/2025

Rates Fringes

PIPEFITTER (Includes HVAC
Pipe, Unit and Temperature
Controls Installations).....\$ 36.92 18.25
PLUMBER.....\$ 36.92 18.25

SUVA2013-052 01/11/2016

Rates Fringes

CARPENTER, Includes
Acoustical Ceiling
Installation, Drywall
Hanging, and Form Work.....\$ 17.93 4.41

CAULKER.....\$ 18.49 1.33

CEMENT MASON/CONCRETE FINISHER...\$ 17.13 0.00

ELECTRICIAN, Includes Low
Voltage Wiring and Alarm
Installation.....\$ 22.94 1.94

GLAZIER.....\$ 19.36 4.68

IRONWORKER, REINFORCING.....\$ 27.18 4.13

LABORER: Mason Tender - Brick...\$ 13.48 3.27

LABORER: Mason Tender -
Cement/Concrete.....\$ 12.96 3.12

LABORER: Pipelayer.....\$ 12.40 1.96

LABORER: Common or General, Including Demolition.....	\$ 12.90	0.96
OPERATOR: Backhoe/Excavator/Trackhoe.....	\$ 19.25	2.72
OPERATOR: Bobcat/Skid Steer/Skid Loader.....	\$ 18.95	4.03
OPERATOR: Bulldozer.....	\$ 18.07	3.50
OPERATOR: Forklift.....	\$ 19.40	7.00
OPERATOR: Loader.....	\$ 21.28	3.17
OPERATOR: Roller.....	\$ 16.25	4.88
PAINTER (Brush and Roller).....	\$ 18.00	0.00
PAINTER: Spray.....	\$ 18.10	5.43
ROOFER.....	\$ 17.50	2.20
SHEET METAL WORKER, Includes HVAC Duct Installation.....	\$ 19.24	2.80
SPRINKLER FITTER (Fire Sprinklers).....	\$ 18.91	4.67
TILE FINISHER.....	\$ 23.40	0.00
TILE SETTER.....	\$ 27.80	10.25
TRUCK DRIVER: Dump Truck.....	\$ 15.50	0.75

WELDERS - Receive rate prescribed for craft performing
operation to which welding is incidental.

=====

Note: Executive Order (EO) 13706, Establishing Paid Sick Leave for Federal Contractors applies to all contracts subject to the Davis-Bacon Act for which the contract is awarded (and any solicitation was issued) on or after January 1, 2017. If this contract is covered by the EO, the contractor must provide employees with 1 hour of paid sick leave for every 30 hours they work, up to 56 hours of paid sick leave each year. Employees must be permitted to use paid sick leave for their own illness, injury or other health-related needs, including preventive care; to assist a family member (or person who is like family to the employee) who is ill, injured, or has other health-related needs, including preventive care; or for reasons resulting from, or to assist a family member (or person who is like family to the employee) who is a victim of, domestic violence, sexual assault, or stalking. Additional information on contractor requirements and worker protections under the EO is available at <https://www.dol.gov/agencies/whd/government-contracts>.

Note: Executive Order 13658 generally applies to contracts subject to the Davis-Bacon Act that were awarded on or between January 1, 2015 and January 29, 2022, and that have not been renewed or extended on or after January 30, 2022. Executive Order 13658 does not apply to contracts subject only to the Davis-Bacon Related Acts regardless of when they were awarded. If a contract is subject to Executive Order 13658, the contractor must pay all covered workers at least \$13.30 per hour (or the applicable wage rate listed on this wage determination, if it is higher) for all hours spent performing on the contract in 2025. The applicable Executive Order minimum wage rate will be adjusted annually. Additional information on contractor requirements and worker protections under Executive Order 13658 is available at www.dol.gov/whd/govcontracts.

Unlisted classifications needed for work not included within the scope of the classifications listed may be added after award only as provided in the labor standards contract clauses (29CFR 5.5 (a) (1) (iii)).

The body of each wage determination lists the classifications and wage rates that have been found to be prevailing for the type(s) of construction and geographic area covered by the wage determination. The classifications are listed in alphabetical order under rate identifiers indicating whether the particular rate is a union rate (current union negotiated rate), a survey rate, a weighted union average rate, a state adopted rate, or a supplemental classification rate.

Union Rate Identifiers

A four-letter identifier beginning with characters other than ""SU"", ""UAVG"", ?SA?, or ?SC? denotes that a union rate was prevailing for that classification in the survey. Example: PLUM0198-005 07/01/2024. PLUM is an identifier of the union whose collectively bargained rate prevailed in the survey for this classification, which in this example would be Plumbers. 0198 indicates the local union number or district council number where applicable, i.e., Plumbers Local 0198. The next number, 005 in the example, is an internal number used in processing the wage determination. The date, 07/01/2024 in the example, is the effective date of the most current negotiated rate.

Union prevailing wage rates are updated to reflect all changes over time that are reported to WHD in the rates in the collective bargaining agreement (CBA) governing the classification.

Union Average Rate Identifiers

The UAVG identifier indicates that no single rate prevailed for those classifications, but that 100% of the data reported for the classifications reflected union rates. EXAMPLE: UAVG-OH-0010 01/01/2024. UAVG indicates that the rate is a

weighted union average rate. OH indicates the State of Ohio. The next number, 0010 in the example, is an internal number used in producing the wage determination. The date, 01/01/2024 in the example, indicates the date the wage determination was updated to reflect the most current union average rate.

A UAVG rate will be updated once a year, usually in January, to reflect a weighted average of the current rates in the collective bargaining agreements on which the rate is based.

Survey Rate Identifiers

The ""SU"" identifier indicates that either a single non-union rate prevailed (as defined in 29 CFR 1.2) for this classification in the survey or that the rate was derived by computing a weighted average rate based on all the rates reported in the survey for that classification. As a weighted average rate includes all rates reported in the survey, it may include both union and non-union rates. Example: SUFL2022-007 6/27/2024. SU indicates the rate is a single non-union prevailing rate or a weighted average of survey data for that classification. FL indicates the State of Florida. 2022 is the year of the survey on which these classifications and rates are based. The next number, 007 in the example, is an internal number used in producing the wage determination. The date, 6/27/2024 in the example, indicates the survey completion date for the classifications and rates under that identifier.

?SU? wage rates typically remain in effect until a new survey is conducted. However, the Wage and Hour Division (WHD) has the discretion to update such rates under 29 CFR 1.6(c)(1).

State Adopted Rate Identifiers

The ""SA"" identifier indicates that the classifications and prevailing wage rates set by a state (or local) government were adopted under 29 C.F.R 1.3(g)-(h). Example: SAME2023-007 01/03/2024. SA reflects that the rates are state adopted. ME refers to the State of Maine. 2023 is the year during which the state completed the survey on which the listed classifications and rates are based. The next number, 007 in the example, is an internal number used in producing the wage determination. The date, 01/03/2024 in the example, reflects the date on which the classifications and rates under the ?SA? identifier took effect under state law in the state from which the rates were adopted.

WAGE DETERMINATION APPEALS PROCESS

1) Has there been an initial decision in the matter? This can be:

- a) a survey underlying a wage determination
- b) an existing published wage determination
- c) an initial WHD letter setting forth a position on a wage determination matter
- d) an initial conformance (additional classification and rate) determination

On survey related matters, initial contact, including requests for summaries of surveys, should be directed to the WHD Branch of Wage Surveys. Requests can be submitted via email to davisbaconinfo@dol.gov or by mail to:

Branch of Wage Surveys
Wage and Hour Division
U.S. Department of Labor
200 Constitution Avenue, N.W.
Washington, DC 20210

Regarding any other wage determination matter such as conformance decisions, requests for initial decisions should be directed to the WHD Branch of Construction Wage Determinations. Requests can be submitted via email to BCWD-Office@dol.gov or by mail to:

Branch of Construction Wage Determinations
Wage and Hour Division
U.S. Department of Labor
200 Constitution Avenue, N.W.
Washington, DC 20210

2) If an initial decision has been issued, then any interested party (those affected by the action) that disagrees with the decision can request review and reconsideration from the Wage and Hour Administrator (See 29 CFR Part 1.8 and 29 CFR Part 7). Requests for review and reconsideration can be submitted via email to dba.reconsideration@dol.gov or by mail to:

Wage and Hour Administrator
U.S. Department of Labor
200 Constitution Avenue, N.W.
Washington, DC 20210

The request should be accompanied by a full statement of the interested party's position and any information (wage payment data, project description, area practice material, etc.) that the requestor considers relevant to the issue.

3) If the decision of the Administrator is not favorable, an interested party may appeal directly to the Administrative Review Board (formerly the Wage Appeals Board). Write to:

Administrative Review Board
U.S. Department of Labor
200 Constitution Avenue, N.W.
Washington, DC 20210.

=====

END OF GENERAL DECISION"

5. Pre-proposal Inquiries

PPI#	Reference			Question	Response
	Page	Section	Paragraph		
1				FAR 252.204-7017 Prohibition on the Acquisition	PROHIBITION ON THE ACQUISITION OF COVERED DEFENSE TELECOMMUNICATIONS EQUIPMENT OR SERVICES—REPRESENTATION (MAY 2021) The Offeror is not required to complete the representation in this provision if the Offeror has represented in the provision at 252.204-7016 , Covered Defense Telecommunications Equipment or Services—Representation, that it “does not provide covered defense telecommunications equipment or services as a part of its offered products or services to the Government in the performance of any contract, subcontract, or other contractual instrument.” (a) Definitions. “Covered defense telecommunications equipment or services,” “covered mission,” “critical technology,” and “substantial or essential component,” as used in this provision, have the meanings given in the 252.204-7018 clause, Prohibition on the Acquisition of Covered Defense Telecommunications Equipment or Services, of this solicitation. (b) Prohibition. Section 1656 of the National Defense Authorization Act for Fiscal Year 2018 (Pub. L. 115-91) prohibits agencies from procuring or obtaining, or extending or renewing a contract to procure or obtain, any equipment, system, or service to carry out covered missions that uses covered defense telecommunications equipment or services as a substantial or essential component of any system, or as critical technology

				as part of any system. (c) Procedures. The Offeror shall review the list of excluded parties in the System for Award Management (SAM) at https://www.sam.gov for entities that are excluded when providing any equipment, system, or service to carry out covered missions that uses covered defense telecommunications equipment or services as a substantial or essential component of any system, or as critical technology as part of any system, unless a waiver is granted. (d) Representation. If in its annual representations and certifications in SAM the Offeror has represented in paragraph (c) of the provision at 252.204-7016 , Covered Defense Telecommunications Equipment or Services—Representation, that it “does” provide covered defense telecommunications equipment or services as a part of its offered products or services to the Government in the performance of any contract, subcontract, or other contractual instrument, then the Offeror shall complete the following additional representation: The Offeror represents that it ☐ will ☐ will not provide covered defense telecommunications equipment or services as a part of its offered products or services to DoD in the performance of any award resulting from this solicitation. (e) Disclosures. If the Offeror has represented in paragraph (d) of this provision that it “will provide covered defense telecommunications equipment or services,” the Offeror shall provide the following information as part of the offer: (1) A description of all covered defense telecommunications equipment and services offered (include brand or manufacturer;
--	--	--	--	--

					product, such as model number, original equipment manufacturer (OEM) number, manufacturer part number, or wholesaler number; and item description, as applicable). (2) An explanation of the proposed use of covered defense telecommunications equipment and services and any factors relevant to determining if such use would be permissible under the prohibition referenced in paragraph (b) of this provision. (3) For services, the entity providing the covered defense telecommunications services (include entity name, unique entity identifier, and Commercial and Government Entity (CAGE) code, if known). (4) For equipment, the entity that produced or provided the covered defense telecommunications equipment (include entity name, unique entity identifier, CAGE code, and whether the entity was the OEM or a distributor, if known). (End of provision)
8	Bid Price Schedule	Line Item 0001E	Contaminated Soil Media	Line Item 0001E is requesting a unit price to include contaminant (including, but not limited to, petroleum, PFAS, PAHs, and metals) impacted soil media. Testing, treatment, handling and disposal costs can vary greatly for each contaminant, especially "PFAS" and "metals". It is unreasonable to simply list "PFAS" and "metals" because there are numerous types of PFAS and heavy metal contaminants. It is also unreasonable to state "including, but not limited" since the costs vary greatly depending on the contaminant. We	Site characterization results are provided as an Attachment to the specifications via Amendment 0006 (Section 01 57 19, Enthalpy Analytical Test Report). It is the contractors responsibility to review and share these results with the offsite disposal facility to identify a facility that is willing to receive the waste and determine an accurate cost. It is also the construction contractors responsibility to minimize the generation of surplus soils required to be disposed offsite. No allowance will be provided.

				cannot price a single unit price for this description. Please turn this unit price into a government provided allowance on the price proposal form for bidding purposes due to the high price volatility for contaminant soil impacted media?	
9	Bid Price Schedule	Line Item 0001F	Dewatering Effluent	Line Item 0001F is requesting a unit price to include contaminant (including, but not limited to metals, petroleum, PAHs, and PFAS) construction dewatering effluent. Testing, treatment, handling and disposal costs can vary greatly for each contaminant, especially "PFAS" and "metals". It is unreasonable to simply list "PFAS" and "metals" because there are numerous types of PFAS and heavy metal contaminants. It is also unreasonable to state "including, but not limited" since the costs vary greatly depending on the contaminant. We cannot price a single unit price for this description. Please turn this unit price into a government provided allowance on the price proposal form for bidding purposes due to the high price volatility for construction dewatering effluent?	Site characterization results are provided as an Attachment to the specifications via Amendment 0006 (Section 01 57 19, Enthalpy Analytical Test Report). It is the contractors responsibility to review, compare against effluent discharge criteria/Navy policy provided in specifications, and develop a treatment train that will work with the anticipated means and methods to develop an accurate cost and volume. It is also the construction contractors responsibility to minimize the need for dewatering when working within the site. No allowance will be provided.

18	Bid Price Schedule	General Bid Note g.	FF&E, ESS, A/V Vendor Performance Bond Cost	General Bid Note g. states, "If Line Items 0002, 0003, and/or 0004 are exercised, additional bonding and consent of surety is required. Consequently, the Performance Bond must reflect 100 percent of the aggregate amount of all items." This amount is for the general contractor's performance bond to the government. Please confirm that the subcontractor or vendor's performance bond amount to the general contractor will be included in the BVD Cost evaluation total (government's estimated price" and not expected to be in the general contractor's HAR amount.	Confirmed. The subcontractor or vendor performance bond amount to the GC will be included in the Cost evaluation total.
23	Attachment K	SOF Access		There does not appear to be a significant amount of information in the Solicitation about access inside the secure compound at Dam Neck. Attachment K for I.D. Requirements is for the NNSY, not NAS Oceana, Dam Neck Annex. Also, there appears to be no mention of escorts, a secondary badging process, or other special considerations for working within the secure compound. Please provide detailed access requirements for this specific jobsite location to include working hours, badging, US Citizenship, etc.	See Amendment 0003 Continuation Sheet, Specifications 01 14 00 1.4.3 SOCOM Special Security Requirements.

24	Drawing F-001			General Note 13 on Drawing Sheet F-001 states "As-Built sprinkler drawings from the original building construction may be obtained from the government." Please provide.	These drawings will not be provided. See Amendment 0008 Continuation Sheet, Drawings section, note revisions to sheet F-001.
25	Drawing IF102	01 14 00	1.2 d.	Drawing IF102 as well as the work restrictions specification note that the walk-in cooler in room 111 (open storage) will remain in operation during the entire construction period and that the contractor must conduct operations to maintain activity access. If available, please provide additional information and specifications for this equipment related to the overall dimensions, electrical connections, other utility connections and access entry locations.	The walk-in cooler in room 111 is now to be demolished. See Amendment 0008 Continuation Sheet, Drawings section, various revised notes.
26	Drawing GI101	01 11 00		Drawing notes and specifications related to the electrical phasing states that work shall be performed so disconnection and reconnection of the electrical service will provide minimal disruption to the power to the building. Is there a maximum allowable days for electrical outage duration? Or do all outages need to be conducted on off hours and/or weekends so that there is no impact to normal building operations during construction. Some outages may require multiple days complete, will this be allowed? Or do provisions for temporary generators need to be accounted	Electrical outages with a span of less than 1 hour may be completed during normal business hours. Outages with longer durations must be completed after hours or on weekends. Outages must not span longer than a weekend. Per specification section 01 14 00, any interruption to utility services must be requested in writing a minimum of 15 days in advance. All outages must be approved by the Contracting Officer.

				for?	
29	Existing Elevator			Will the existing elevator be available for contractor use during the phase 4 second floor renovation? Please provide full specifications for the existing elevator.	The elevator will be available for contractor use during Phase 4. Full specifications are not available.
31	AE111	07 52 00	2.1	Roof plan AE111 calls for new walk pads and roofing on existing portions of the building. Please provide product used on existing portions of the building so that that any warranty on the existing system remains in place. If existing warranties are still active, please provide copies of the warranty cards.	This information is not available.
35	AE105/106			Keynote 122 on drawings AE105 and AE106 calls for RF window shield film to be provided at existing windows within controlled areas. No specifications are included for RF shielding criteria. Please provide.	See Amendment 0006 and Updated specification section (13 49 20.00 10 RFI/EMI SHIELDING).
37	Existing Elevator			Plans call for new electrical and security work associated with the existing to remain elevator. Please provide information for elevator manufacturer/installer and any as-built documentation related to the elevator for	Bid as specified.

				coordination.	
39	General			Does this project have US Citizenship requirements for access to site or working on the site?	See Amendment 0003 Continuation Sheet, Specifications 01 14 00 1.4.3 SOCOM Special Security Requirements.
41	General			After award, the Contracting Officer will provide a NTP to the awardee. What is the approximant duration between issuing the award and issuing the NTP?	Notice to proceed is the same date as the contract award date.
47	General			Does the existing roof system have a warranty? If yes please provide that information so the Prime can get a certified installer for new work.	This information is not available.
57				2. Specification 122413; 1. Installation. May we exclude installation of window treatments into concrete/masonry/steel substrates?	Bid as specified.
68		07 84 00		Firestopping specification dictates the qualifications of the system installer but does not reference the requirement for the installer to be a first tier to the general contractor. Please verify that the installer is not required to be a first tier to the general contractor.	A single qualified firestopping contractor or installer for the entire project is required as specified in Amendment 0003 continuation sheet, 07 84 00 Firestopping, 1.5.1 Firestopping Installer Qualifications.

70		General Requirements	Phasing, BOD, and Liquidated Damages	The RFP states that there are Liquidated Damages in the amount of 2,009.06 per calendar day, however, this section states that the Liquidated Damages (LDs) are associated with each of the four phases. There is also no mention of separate Beneficial Occupancy Dates (BOD) per phases. Please confirm that a BOD letter will be issued upon the turnover of each phases and also state the allocated LDs amount associated with each phase as well.	See Amendment 0008, Liquidated damages and Time of Completion have been updated.
76		01 57 19	Pace Analytical Report	The Pace Analytical report dated 9/5/2019 provided at the end of Specification section 01 57 19 provides information for borings of unknown locations. The report also does not report any PFAS. Does the Government have a more extensive environmental report? If so, please provide.	Site characterization results are provided as an Attachment to the specifications via Amendment 0006 (Section 01 57 19, Enthalpy Analytical Test Report).
77		01 57 19	Pace Analytical Report	The Pace Analytical report dated 9/5/2019 provided at the end of Specification section 01 57 19 does not detect / report any PFAS. There are no local certified landfills that will take soils containing PFAS and out of town certified landfills are very expensive and should not overburden the unit prices when the Pace report does not detect PFAS. Please consider deleting "assume PFAS is present" from specification 01 57 19 and from the required unit prices, and handle PFAS as an unforeseen	Site characterization results are provided as an Attachment to the specifications via Amendment 0006 (Section 01 57 19, Enthalpy Analytical Test Report).

				condition?	
78		01 57 19	1.5.1.1.5.3	Specification 01 57 19, section 1.5.1.1.5.3 requires a minimal treatment system for groundwater dewatering. Due to the lack of environmental analysis of groundwater contaminants in the bid documents, please confirm for bidding purposes, that the specified treatment system will be adequate treatment for discharging into the site stormwater system, and groundwater will not require off-site disposal?	Site characterization results are provided as an Attachment to the specifications via Amendment 0006 (Section 01 57 19, Enthalpy Analytical Test Report).
81	Drawing Sheet PL102	11 00 00	Vehicle Storage Lifts	Upon reviewing product data on the Bendpak HD-973PX, there is a requirement for a power supply and compressed dry air supply. The power supply is detailed on EP101, however, there are no details or notes on compressed air connections for the vehicle lifts on sheet PL102. From the manufacturer's product data, each vehicle lift has a Pushbutton Air Valve that requires a supply of compressed dry air (75-125psi @ 3cfm), the connection to the valve is made via a straight expander fitting. Please provide a revised PL102 that details a compressed air connection point at each vehicle lift.	See Amendment 0006, continuation sheet. Sheets PL102 and PL104 revised (File Name: PL102 and PL104).

82	Drawing Sheets GI101 - GI103		Phasing Plans	The RFP states the time for completion shall be 912 calendar days with 15 calendar days for submission and approval of bonds and insurance. Phase 1 as described in the contract documents consists of the relocation of existing mechanical and electrical services but also includes the installation of new mechanical equipment as well. While the sourcing, procurement, and delivery of the temporary mechanical equipment may not be a significant issue for this phased schedule, the lead time for the new mechanical equipment is anticipated to be a severe impact to this being the first phase of the project. Until the project award date is established and equipment can be released (post negotiations, contracts, submittals, shop drawings, approvals, etc.) the impact from lead times is simply unknown at this time. Please confirm that the 912 calendar day clock will not begin at contract award and will start with a Notice to Proceed issued once these equipment lead times can be confirmed and the actual schedule can be confirmed based on this information, post contract award.	See Amendment 0008 Continuation sheet, specification section 01 14 00, 1.2 SPECIAL SCHEDULING REQUIREMENTS. Phases 1 and 2 shall be completed concurrently and have a combined BOD of 600 days from award. This should alleviate long lead issues.
----	---------------------------------------	--	---------------	---	---

83	Drawing Sheets GI101 - GI103		Phasing Plans	The Phasing Plans for Phases 2 (with a few exceptions) and 3 both state that FF&E, AV, and ESS must be procured, on site, and installed complete during each phase. The price proposal general bid notes states in item b., "The Government reserves the unilateral right to award Line Items 0002, 0003, and 0004 to the Contractor at the proposed price within 365 calendar days after the contract award and in accordance with all bid notes." To maintain the 912 calendar day duration along with the Phasing Plan provided, these three planned modifications will need to be awarded within 90 calendar days of contract award to allow sufficient time for the procurement, fabrication, delivery, and installation timeframes. Please confirm these modifications will be awarded with 90 calendar days.	Planned modifications will be awarded to allow sufficient time to meet Phased BOD timeframes.
84	Drawing Sheets GI101 - GI103		Phasing Plans	The Phasing Plans and Specifications contain very high-level language pertaining to partial BOD letters and acceptance by the government of each completed phase. There is also no specific mention of life safety / fire alarm acceptance and coordination at each phase. There will be portions of the each system that cannot be fully TAB's, commissioned, and brought on line until the complete project is finished. Please confirm that NAVFAC	Bid as specified.

				mechanical acceptance and NAVFAC life safety approvers have reviewed this phasing plan and are on board with the phased occupancies required. Delays and costs associated with prolonged NAVFAC acceptance and approvals per phase will be have to be considered changed conditions.	
85	1	01 14 00	Project Phasing	1.2 Special Scheduling Requirements - this section states the minimum calendar days for written notification for the Activity to remove government equipment from existing spaces between phases or other activities. There is no mention of any "tools down" or "blackout periods" for government transitions between phases. Please confirm that there are no periods within the 912 calendar day duration time for project completion for the government to transition between phases.	See Amendment 0008 Continuation sheet, specification section 01 14 00, 1.2 SPECIAL SCHEDULING REQUIREMENTS. Tools down periods have been addressed.
89	AE704	Detail C3		Storefront jamb detail C3/AE704 shows 5/8" gypsum board on 2-1/2" metal studs. Please confirm if gypsum and metal studs are required. There is no indication on the floor plans to add the gypsum and metal studs on the Lobby wall or extending to the precast exterior as shown by the detail. Please clarify attachment detail of storefront to precast at this condition.	See Amendment 0006, Sheet AE704 revisions.

96	Amendment 0003	01 14 00	Continuation Sheet	The continuation sheet provided with Amendment 0003 states durations for each of the four project phases and an update to the total construction duration. Phase 1 BOD states that it is to be complete 180 calendar days from "Notice to Proceed". Please confirm if the date for this "Notice to Proceed" is the same date as the Contract Award Date, or if the Government intends to issue a Notice to Proceed at an agreeable date post award, to be coordinated between the Government and the Contractor.	Notice to proceed is the same date as the contract award date.
97	Amendment 0003	01 14 00	Continuation Sheet	The continuation sheet provided with Amendment 0003 states durations for each of the four project phases and an update to the total construction duration. Please confirm that there is not a Government transition period between phases wherein the Contractor is to be "tools down".	See Amendment 0008 Continuation sheet, specification section 01 14 00, 1.2 SPECIAL SCHEDULING REQUIREMENTS. Tools down periods have been addressed.
101				Spec. Section 09 29 00: Please confirm that it is the intent that Level 5 finish is only required at locations/walls where wall covering will be installed.	See Amendment 0006 continuation sheet, specification section 09 29 00 Gypsum Board.

(End of Summary of Changes)