



- ① EXISTING CIRCUITS FEED OUT OF THE CUTLER HAMMER MCC TO BE RE-FED FROM NEW PANELBOARD HDP-A. REFER TO ELEVATIONS AND NEW FLOOR PLAN. REMOVE MCC AFTER NEW PANEL IS INSTALLED AND ALL CIRCUITS HAVE BEEN TRANSFERRED.
- ② EXISTING CIRCUITS FEED OUT OF THE FEDERAL PACIFIC MCC TO BE RE-FED FROM NEW PANELBOARD HDP-7. REFER TO ELEVATIONS AND NEW FLOOR PLAN. REMOVE MCC AFTER NEW PANEL IS INSTALLED AND ALL CIRCUITS HAVE BEEN TRANSFERRED.
- ③ EXISTING PANEL TO REMAIN AND PROTECTED DURING CONSTRUCTION. PANEL TO BE RE-FED FROM NEW SWITCHGEAR. NEW 3RD FLOOR MECHANICAL ROOM (2ND FLOOR ROOF).
- ④ EXISTING PANEL TO REMAIN AND PROTECTED DURING CONSTRUCTION. PANEL TO BE RE-FED FROM NEW SWITCHGEAR. REFER TO NEW ONE-LINE DIAGRAM.



- ① RE-CONNECT EXISTING CIRCUITS THAT WERE FED FROM MCC-A TO NEW DISTRIBUTION PANEL. MATCH EXISTING WIRE SIZE AND TRIP SETTINGS. REFER TO PANEL SCHEDULES AND ELEVATIONS FOR MORE DETAILS.
- ② RE-CONNECT EXISTING CIRCUITS THAT WERE FED FROM MCC-7 TO NEW DISTRIBUTION PANEL. MATCH EXISTING WIRE SIZE AND TRIP SETTINGS. REFER TO PANEL SCHEDULES AND ELEVATIONS FOR MORE DETAILS.
- ③ RE-FEED PANEL FROM NEW SWITCHGEAR. REFER TO NEW ONE-LINE DIAGRAM.

3900 NCTR ROAD, JEFFERSON, ARKANSAS 72079

E1230