

APPENDIX A
Building Inspection List

ATTACHMENT 1

Table 1. Kitchen Hood Systems

Type of System: Wet Chemical System

Buildings	Type/Model	Cylinder Size	Fuse Links	Pull Stations
47	Pyro-Chem PCL-600	6.0 gal	3	1
141	Pyro-Chem PCL-300	3.0 gal	3	1
	Pyro-Chem PCL-460	4.6 gal	3	1
	Pyro-Chem PCL-460	4.6 gal	3	1
78	Ansul R-102	1.5 gal	1	1
1500	Ansul R-102	1.5 gal	1	1

ATTACHMENT 2

Table 2. Communication Rooms

Type of System: FM-200 Systems

Control Panel:

Fike (Bldgs. 362, 363 SIPR Room)

Pyro-Chem (Bldgs. 52, 53, 79, 96, 97, 513)

Buildings	Cylinders	Pull Stations	Photo Detectors	Ion Detectors	Heat Detectors	Abort Buttons	Bells	Horns	Horn/ Strobes	Strobes
52	1	1	1	1	—	1	1	—	1	—
96	1	1	2	2	—	1	1	—	1	—
97	2	1	3	3	—	—	1	—	1	—
362	2	1	1	1	—	1	1	—	1	2
363	2	—	1	1	—	—	—	—	—	—
513	1	1	3	3	—	1	1	—	1	—
53	2	2	0	0	4	2	0	—	4	—
79	4	2	0	0	2	2	0	0	4	

ATTACHMENT 3 – 3A

Table 3. Production Facilities

Table 3A. Building 128

Type of Systems:

HFC-227 System (Dyno Cells, Control Rooms);

FM-200 System (M1 Test Cell, NDT Machine)

Control Panel: Fike

Building 128	Cylinders	Pull Stations	Photo Detectors	Ion Detectors	Heat Detectors	Abort Buttons	Bells	Horns	Horn/ Strobes	Strobes
Dyno Cell 1	1	1	—	—	2	1	—	1	1	1
Control Room 1	1	2	1	1	—	1	—	1	1	3
Dyno Cell 2	1	1	—	—	2	1	—	1	1	1
Control Room 2	1	2	1	1	—	1	—	1	1	3
Dyno Cell 3	1	1	—	—	2	1	—	1	1	1
Control Room 3	1	2	1	1	—	1	—	1	1	1
Dyno Cell 4	1	1	—	—	2	1	—	1	1	—
Dyno Cell 5	1	1	—	—	2	1	—	1	1	1
M1 Test Cell	2	1	—	—	4	1	2	—	2	—
NDT Machine	—	—	—	—	—	—	—	—	—	—

ATTACHMENT 3 – 3B

Table 3. Production Facilities

Table 3B. Building 410

Type of Systems:

FM-200 System (Control Room of Test Cell 2);

CO2 System (All Test Cells)

Control Panel:

Ansul (Test Cells);

Chemetron (Control Room #2)

Building 410	Cylinders	Pull Stations	Photo Detectors	Ion Detectors	Heat Detectors	Abort Buttons	Bells	Horns	Horn/ Strobes	Strobes
Control Room 2	1	2	2	2	—	2	—	—	2	1
Test Cell 2	See Note	1	—	—	3	—	1	—	1	2
Test Cell 3	See Note	1	—	—	3	—	1	—	1	1
Test Cell 4	See Note	1	—	—	3	—	1	—	1	1
Test Cell 5	See Note	1	—	—	3	—	1	—	1	1
Test Cell 6	See Note	2	—	—	3	—	1	—	1	2
Test Cell 7	See Note	2	—	—	3	—	1	—	1	2
Test Cell 8	See Note	2	—	—	3	—	1	—	1	2
Test Cell 9	See Note	2	—	—	3	—	1	—	1	2
Test Cell 10	See Note	2	—	—	3	—	1	—	1	2
Test Cell 11	See Note	1	—	—	—	—	—	—	—	2
Test Cell 12	See Note	1	—	—	—	—	1	—	1	2
Test Cell 13	See Note	1	—	—	3	—	1	—	1	2
Test Cell 14	See Note	1	—	—	3	—	1	—	1	2
Test Cell 15	See Note	1	—	—	3	—	1	—	1	2
Test Cell 16	See Note	1	—	—	3	—	1	—	1	2
Test Cell 17	See Note	1	—	—	3	—	1	—	1	2
Test Cell 18	See Note	1	—	—	3	—	1	—	1	2
Test Cell 19	See Note	1	—	—	3	—	1	—	1	2
Test Cell 20	See Note	2	1	1	2	—	2	—	4	2

NOTE:

Test Cells 2-10: A set of 12 Cylinders – 75 LB CO2 Cylinder with CV98 Valves

Test Cells 11-19: A set of 12 Cylinders – 75 LB CO2 Cylinder with CV98 Valves

Test Cell 20: A set of 12 Cylinders – 100 LB CO2 Cylinder with CV98 Valves

ATTACHMENT 3 – 3C

Table 3. Production Facilities

Table 3C. Building 474

Type of System: FM-200 System

Control Panel: Fike

Building 474	Cylinders	Pull Stations	Photo Detectors	Ion Detectors	Heat Detectors	Abort Buttons	Bells	Horns	Horn/ Strobes	Strobes
Dyno Cell 1	2	2	2	2	2	1	—	—	2	3
Dyno Cell 2	2	2	2	2	2	1	—	—	2	3
Dyno Cell 3	2	2	2	2	2	1	—	—	1	3
Dyno Cell 4	2	2	2	2	2	1	—	—	2	3
Dyno Cell 5	2	2	2	2	2	1	—	—	2	3
Dyno Cell 6	2	2	2	2	2	1	—	—	2	3
Dyno Cell 7	2	2	2	2	2	1	—	—	2	3

ATTACHMENT 3 – 3D

Table 3. Production Facilities

Table 3D. Building 475

Type of System: FM-200 System

Control Panel:

Notifier (Dyno Cells);

Fike (Control Room 405)

Building 475	Cylinders	Pull Stations	Duct Detectors	Ion Detectors	Heat Detectors	Abort Buttons	Bells	Horns	Horn/ Strobes	Strobes
Dyno Cell 401	2	2	2	—	4	2	3	—	3	—
Dyno Cell 402	2	2	4	—	6	2	3	—	3	—
Dyno Cell 403	2	2	2	—	4	2	3	—	3	—
Dyno Cell 404/405	4	2	4	—	6	2	4	—	4	—
Control Rm 405	1	1	—	—	2	1	1	—	1	2
Dyno Cell 406	2	2	2	—	4	2	3	—	3	—
Dyno Cell 407	2	2	2	—	4	2	3	—	3	—
Dyno Cell 408	2	2	4	—	6	2	3	—	3	—
Dyno Cell 409	2	1	—	—	4	1	1	—	1	1
Dyno Cell 410	4	2	2	—	6	2	3	—	3	—
Dyno Cell 411	2	2	2	—	4	2	3	—	3	—

End of Scope of Work

