

Section J – 1606001
Water (Overseas)

ATTACHMENT NUMBER	ATTACHMENT TITLE
J-1606001-01	Definitions and Acronyms
J-1606001-02	References and Technical Documents
J-1606001-03	Water System Description and Inventory
J-1606001-04	Historical Critical Spare Parts Inventory
J-1606001-05	Fire Main Systems Map
J-1606001-06	Unidirectional Flushing Plan Procedures – NAS I
J-1606001-07	Unidirectional Flushing Plan Procedures – NAS II

ATTACHMENT J-1606001-01
DEFINITIONS AND ACRONYMS

Definition/Acronym	Description
ANSI	American National Standards Institute
AWWA	American Waterworks Association
ASME	American Society of Mechanical Engineers
CP	Cathodic Protection
CTO	Certificate to Operate
DoD FGS	Department of Defense Environmental Final Governing Standards
NFPA	National Fire Protection Association
NPDWR	National Primary Drinking Water Regulations
NSDWR	National Secondary Drinking Water Regulations
OEBGD	Overseas Environmental Baseline Guidance Document
OMSI	Operation and Maintenance Support Information
Potable Water (US and territories)	Water that is satisfactory for drinking and cooking.
SOP	Standard Operation Procedure
TREEO	Training, Research and Education for Environmental Occupations
UFC	Unified Facilities Criteria
USEPA	US Environmental Protection Agency
Water Fit for Human Consumption (Overseas)	Water that meets the primary drinking water standards as defined in FGS, OEBGD and CNICINST 5090.1.

ATTACHMENT J-1606001-02
REFERENCES AND TECHNICAL DOCUMENTS

Reference	Title
UFC 3-230-02	Water Supply Systems
UFC 3-430-09	Exterior Mechanical Utility Distribution
UFC 3-440-02N	Water Conservation Operation and Maintenance
CNICINST 5090.1	Navy Overseas Drinking Water Program Ashore
CNIC M-5090.1	Navy Drinking Water Program Ashore Manual
CNIC M-5090.2	Certificate to Operate Criteria and Requirements for U.S. Navy Overseas Navy Drinking Water Systems
CNIC M-5090.3	Operator in Responsible Charge and Assistant Operator in Responsible Charge Training and Certification Program for U.S. Navy Overseas Drinking Water Systems
	Installation Drinking Water Monitoring Plan

ATTACHMENT J-1606001-03
WATER SYSTEM DESCRIPTION AND INVENTORY

Reference Excel file “J-1606001-03 Water System Description and Inventory”

~~Tab a. Water System Description~~

~~Tab b. Instrumentation Description~~

~~Tab c. Pressure Gauges~~

ATTACHMENT J-1606001-04
HISTORICAL CRITICAL SPARE PARTS INVENTORY

Reference Excel file “J-1606001-04 Historical Critical Spare Parts Inventory”

ATTACHMENT J-1606001-05
FIRE MAIN SYSTEMS MAPS

Reference Section C, Annex 0200000 Management and Administration, Spec Item 2.6.2 Dissemination of Information.

NAS 2 - Flight Line Area, Fire Water Lines: 4,024 Linear Feet

NAS 2 - Supply Fuel Area, Fire Water Lines: 2,504 Linear Feet

NAS 2 - Public Works Department Area, Fire Water Lines: 1,534 Linear Feet

NAS 2 - Supply Warehouse, Fire Water Lines: *732 Linear Feet*

NAS 2 - Sigonella Water Service Area: Zone 5

Potable Water Lines: 19,091 Linear Feet

Fire Water Lines: 4,283 Linear Feet

ATTACHMENT J-1606001-06
UNIDIRECTIONAL FLUSHING PLAN – NAS I

Reference .pdf file “J-1606001-06 Unidirectional Flushing Plan – NAS I.pdf”

ATTACHMENT J-1606001-07
UNIDIRECTIONAL FLUSHING PLAN – NAS II

Reference .pdf file “J-1606001-07 Unidirectional Flushing Plan – NAS II.pdf”