

ATTACHMENT J-1502000-08e
PERIODIC INSPECTION AND MAINTENANCE ACTIONS

Updated in accordance with UFC 3-460-03 (Change 2, August 2023)

1. Filters and Separators

- Inspect for external leaks, corrosion, and physical damage – Weekly (UFC 3-460-03 § 6-3.2.2)
- Record differential pressure; replace elements if DP > 15 psi – Weekly (UFC 3-460-03 § 6-3.2.3)
- Verify gasket condition and element seating – Weekly (UFC 3-460-03 § 6-3.2.3)
- Inspect placards, labels, and markings – Monthly (UFC 3-460-03 § 6-3.2.5)
- Drain water/sediment from sumps – Weekly or As Needed (UFC 3-460-03 § 6-3.2.4)

2. Hydrant Pits and Valves

- Inspect pit covers, seals, and internal condition – Weekly (UFC 3-460-03 § 6-2.2)
- Verify valve operation and position indicators – Monthly (UFC 3-460-03 § 6-2.3)
- Lubricate valve stems and mechanical parts – Monthly (UFC 3-460-03 § 6-2.4)
- Confirm electrical grounding continuity – Monthly (UFC 3-460-03 § 6-6.1)
- Clean debris and ensure drain function – Weekly (UFC 3-460-03 § 6-2.2)

3. Cathodic Protection Systems

- Inspect rectifier output and verify voltage/amperage – Monthly (UFC 3-460-03 § 6-7.2.2)
- Record rectifier output and compare to baseline – Monthly (UFC 3-460-03 § 6-7.2.2)
- Measure pipe-to-soil potential at test stations – Quarterly (UFC 3-460-03 § 6-7.2.3)
- Verify continuity of protected structure – Annually or per system design (UFC 3-460-03 § 6-7.2.4)

4. Spill Containment Areas

- Inspect for cracks, corrosion, and ponding – Monthly (UFC 3-460-03 § 6-8.1)
- Clean sumps and drains – Monthly or As Needed (UFC 3-460-03 § 6-8.1)
- Inspect signage and markings – Monthly (UFC 3-460-03 § 6-8.2)
- Verify slope, grading, and drainage performance – Monthly (UFC 3-460-03 § 6-8.3)
- Inspect containment walls, berms, and seals – Monthly (UFC 3-460-03 § 6-8.1)

5. Oil Water Separators (OWS)

- Inspect for sediment buildup, operational integrity – Monthly (UFC 3-460-03 § 6-9.3)
- Check valves, inlet/outlet piping for corrosion/leaks – Monthly (UFC 3-460-03 § 6-9.3)
- Remove floating oil and clean separator components – Monthly or As Needed (UFC 3-460-03 § 6-9.3)
- Record maintenance in environmental log – Monthly (UFC 3-460-03 § 6-9.3)
- Verify compliance with permit requirements – Monthly (UFC 3-460-03 § 6-9.4)