


Statement of Work

Address Update for Westnet First-In Alerting System



Eielson Air Force Base
March 2026



Description of Requirement

1.0 BACKGROUND AND OBJECTIVE

1.1 Background: The Eielson AFB [REDACTED] utilizes the Westnet First-In Alerting System, which is integrated with the Monaco D-21 dispatch platform. Eielson AFB is migrating its emergency response grid from a building-number-based system to a formal street-address-based system. To ensure continuity of emergency services, the Westnet system's core database and run cards must be updated to reflect these new address identifiers.

1.2 Objective: The objective of this contract is for the Original Equipment Manufacturer (OEM), Westnet, to provide the necessary software engineering and on-site technical services to rebuild the First-In Alerting System database with the new address data and ensure the entire system is fully operational and validated.

2.0 SPECIFIC TASKS

The contractor shall perform the following tasks:

- 2.1 System Backup: Prior to any modifications, the contractor shall perform a complete and verified backup of the existing system database.
- 2.2 Remote Database Rebuild: The contractor shall remotely reconfigure the First-In Alerting System Database and associated Run Cards to replace the legacy building numbers with the new, Government-provided street address data.
- 2.3 On-Site Integration (ZIRD Update): Upon completion of the remote work, the contractor shall send one (1) OEM-certified technician to Eielson AFB to perform the final on-site integration, including any necessary Zone Information Reporting Display (ZIRD) updates.
- 2.4 System Verification: The on-site technician shall validate that the updated system is performing as designed and that all network connectivity is stable.

3.0 DELIVERABLES

Deliverable	SOW Para	Frequency / Due Date
System Backup Verification Certificate	2.1	Provided to COR prior to beginning remote database work.
Final Service Report	2.4	Provided on-site at the conclusion of all work.

The Final Service Report shall confirm that the database and run card updates are complete and that the system has passed all final verification checks.

4.0 ACCEPTANCE CRITERIA

Upon completion of all on-site work, the contractor's technician and the Government Point of Contact (POC) will jointly conduct a functional test of the updated Westnet system. Final acceptance is contingent upon the successful completion of all of the following specific tests:

- 4.1 The Westnet system successfully boots up and runs for 15 minutes with no errors or fault codes.
- 4.2 All dispatching consoles correctly display system status.
- 4.3 The system successfully receives a simulated alarm from a remote station and correctly displays the new street address at the main dispatch center.

- 4.4 A dispatcher successfully initiates and transmits a simulated dispatch alert, and the alert correctly displays the new street address at [REDACTED] [REDACTED]

Written acceptance will be documented by the Government POC signing the contractor's Final Service Report on-site.

5.0 SUPPLEMENTAL INFORMATION

- 5.1 The following personnel are representatives for this project:
 - TBD upon contract award
- 5.2 Base Notification - The Contractor shall contact one of the representatives identified above no later than 72 hours before starting site operations so base access can be obtained.
- 5.3 Site Visit - The contractor shall become thoroughly familiar with all details of the work to be performed. The contractor will advise the contracting officer of any discrepancies before performing any work.
- 5.4 Protection of Government Property and Personnel - The contractor shall protect Government and non-Government property and personnel on-base from inconvenience, damage, or injury of any nature.
 - 5.4.1 The contractor shall accomplish the work in accordance with applicable Base Safety and Fire Prevention regulations, Air Force regulations, and such other measures as deemed applicable.
 - 5.4.2 Damages of any nature caused by this work shall be repaired or damaged property replaced at no expense to the Government.
 - 5.4.3 If the contractor does not satisfactorily repair or replace the damaged property, the Government reserves the right to make the necessary corrections.
 - 5.4.4. The contractor shall reimburse the Government for consequential damages and for all materials and labor used for corrections.
- 5.5 The contractor is responsible for the storage and safekeeping of all material to be used in the completion of work.
- 5.6 The contractor shall keep the work area clean of all debris. The contractor shall keep storage areas clean and orderly. The contractor shall dispose of all wastes and not allow them to accumulate.
- 5.7 The contractor shall comply with base regulations regarding Hazardous Materials (HAZMAT) and ensure procedures meet all applicable policies, publications, and protocols in this contract. Provide Bio-environmental engineer service with a Safety Data Sheet (SDS) on all first-time purchase of hazardous items obtained through local sources of supply and obtain approval prior to purchase.
- 5.8 The Government will provide emergency medical treatment and emergency patient transportation service for contractor personnel who are injured or become critically ill while at Eielson AFB. Treated personnel will be responsible for reimbursing the government for the cost of medical treatment and transportation at the current inpatient or outpatient treatment rate.
- 5.9 The contractor shall ensure each employee obtains pass and identification items as applicable for contractor personnel and contractor-owned vehicles. The contractor will maintain a current list of employees.

- 5.10 The list will include employee names along with information required in the REAL ID. (REAL ID compliance information website: <https://www.dhs.gov/real-id> enforcement brief.) This list is required to be provided to the contracting officer and the servicing security forces organization, to include updated copies for any changes during the duration of the contract.