

PROJECT DESCRIPTION

The responsibility of the contractor is to replace chillers at the following BEQ buildings.

- 1.BB-270 75 Ton Chiller and 2- Chilled Water Pumps
- 2.BB-274 70 Ton Chiller and 2- Chilled Water Pumps
- 3.BB275 75 Ton Chiller and 2- Chilled Water Pumps
- 4.HP-121 90 Chiller and 1- Chilled Water Pump

SPECIAL SCHEDULING

The facility/activity will remain in operation during the entire construction period. The Contractor shall conduct his operations so as to cause the least possible interference with normal operations of the facility/activity. The furniture and other objects in the room are to be moved by the contractor.

SUPERVISION

One person may fill the roles of Superintendent, Quality Control Manager, and Safety & Health Officer, if duly qualified for all three positions as defined in the project specification.