



DEPARTMENT OF THE NAVY
COMMANDER
NAVAL FACILITIES ENGINEERING SYSTEMS COMMAND PACIFIC
258 MAKALAPA DRIVE SUITE 100
PEARL HARBOR HI 96860-3134

J&A No. 26-017

**JUSTIFICATION AND APPROVAL
FOR USE OF OTHER THAN FULL AND OPEN COMPETITION**

1. Contracting Activity.

Department of the Navy, Naval Facilities Engineering Systems Command (NAVFAC), Pacific, Joint Base Pearl Harbor-Hickam, Hawaii.

2. Description of the Action Being Approved.

The purpose of this Justification & Approval (J&A) is to include proprietary specifications for the following brand name item in Solicitation Work Order Number 1665555, Fiscal Year 2024 (FY24) Military Construction (MILCON) Project P-012, North Aircraft Parking Ramp at Andersen Air Force Base (AAFB), Guam. The brand name description is essential to the activity's requirements, thereby precluding consideration of a product manufactured by any other company. This J&A covers only the portion of the acquisition that is related to this brand-name specification.

- One (1) Schneider Electric PowerLogic ION8650B, 64MB Memory Meter

3. Description of Supplies/Services.

FY 2024 MILCON Project P-012, North Aircraft Parking Ramp at AAFB is for the following site improvements: aircraft parking apron, taxiway connections, hydrant fueling pits and loops, maintenance yard, utilities (water, firewater, comm, and electric), site grading, drainage, and airfield lighting.

As part of the project, Schneider Electric PowerLogic ION8650B, 64MB Memory Meter will be installed on the new airfield lighting system. One electricity meter will be required. The use of Schneider Electric PowerLogic ION8650B, 64MB Memory Meter is a programmable utility-controlled device that is required for all projects that need a connection to the existing installation's networked facilities control and monitoring system commonly referred to as the Data Acquisition System (DAS) at AAFB. The estimated cost for one (1) Schneider Electric PowerLogic ION8650B, 64MB Memory Meter is [REDACTED] which is [REDACTED] of the total project cost of [REDACTED].

Fiscal Year 2024 (FY24) military construction funds will be utilized to fund the meter requirement. The meter will be acquired by the construction contractor as part of the performance of Project P-012.

The contractor shall be required to commence work within 15 days after the notice to proceed and complete the contract within 1,479 calendar days after the notice to proceed. The Schneider Electric PowerLogic ION8650B, 64MB Memory Meter will be delivered and installed within the 1,479-day construction time.

4. Statutory Authority Permitting Other Than Full and Open Competition.

The statutory authority permitting other than full and open competition is Title 10 U.S.C. 3204(a)(1) and (b)(B)(i) and (ii), as implemented by the Federal Acquisition Regulation (FAR) 6.302-1, "Only one responsible source and no other supplies or services will satisfy agency requirements."

5. Rationale Justifying Use of Cited Statutory Authority.

As explained more fully below, award to another source would result in increased costs to the Government that is not expected to be recovered by competition.

The utilization of the Schneider Electric PowerLogic ION8650B, 64MB Memory Meter is required for the following reasons:

- The Government has a reasonable need for standardization and interoperability of its existing building control systems that will require a connection to the identified installation networked facilities control and monitoring system commonly referred to as the DAS. Applicable United States Government Accountability Office (GAO) Comptroller General decisions have acknowledged the authority of a federal agency to use other than competitive procedures when there is a reasonable need for standardization or interoperability with existing equipment or software, and when it is likely that award to other sources would result in, among other things, substantial duplication of cost to the Government that is not expected to be recovered through competition.
- Advanced Metering Infrastructure (AMI) is an integrated system of utility revenue meters, communications networks, and data management systems that enables automated remote reading of electricity meters. The AMI meters are required to be connected to the base-wide energy and utility monitoring and controls system using the installation's advance metering protocols. The system operates through the DAS, which is responsible for acquiring the meter data from the AMI meters located throughout AAFB. The existing AMI electricity meters and DAS are the ION 8650 meters and the ION Enterprise DAS, both being products/software of Schneider Electric. Unified Facilities Guide Specifications 26 27 14.00 20 Para 2.1 also directs the designer of record to coordinate with the activity to determine if a metering system is installed and provide meters to match. Only one responsible source and no other suppliers or services will satisfy current agency requirements because the existing AMI system can only fully communicate with meters manufactured by Schneider Electric.

- A Business Case Analysis (BCA) was conducted in January 2026 by NAVFAC Pacific to examine the cost impact of replacing all existing Schneider Electric AMI metering systems at AAFB with non-Schneider Electric AMI metering systems in comparison to simply maintaining the existing Schneider Electric AMI system at AAFB (Attachment 1). In summary, the estimated cost to replace all existing Schneider Electric AMI metering systems is approximately [REDACTED] which significantly exceeds the cost of procuring one additional meter at the cost of [REDACTED] and maintaining the current Schneider AMI system at AAFB. This estimate was derived and adjusted by utilizing the Cost Estimator's experience with the system and previous business case analyses utilizing AMI Meters. The cost for the replacement of the entire system will vary based on the market conditions, contractor mark-ups, on-site conditions, and escalations during the time of installation.

NAVFAC Pacific's technical personnel have determined that the contract actions authorized by this J&A will avoid substantial duplication of cost that is not expected to be recovered through competition. Assuming other brand name controllers could be integrated into the DAS at AAFB, to be fully functional, the significant cyber security risks, operational challenges, added costs (including the costs to reprocur the installation's existing inventory), and other disadvantages arising from the use of different brands of controllers outlined above are not expected to be recovered through competition.

6. Description of Efforts Made to Solicit Offers from as Many Offerors as Practicable.

On 19 August 2025, an announcement was published on the System for Award Management (SAM) website, in accordance with Defense Federal Acquisition Regulation Supplement (DFARS) 206.302-1 to identify other potential responsible sources of supply that can provide utility revenue meters with equal performance and listing/approval requirements as the Schneider Electric PowerLogic ION8650B, 64MB Memory Meter. The announcement closed on 03 September 2025 with no responses received. As such, it can be interpreted that the Schneider Electric PowerLogic ION8650B, 64MB Memory Meter is the only meter that is currently compatible with the existing ION enterprise DAS software utilized by AAFB. Therefore, there are currently no known manufacturers of utility revenue meters, other than the Schneider Electric PowerLogic ION8650B, 64MB Memory Meter that can meet the Government's requirements at AAFB.

7. Determination of Fair and Reasonable Cost.

As stated in Paragraph 5, the new non-Schneider Electric Meter components and infrastructure would cost approximately [REDACTED] to procure. This does not include the cost and time to include relocation of existing equipment, upgrade of existing supporting utilities, obtaining Authority to Operate that is required by AAFB, and training of personnel on the non-Schneider Electric system, which would be required to accommodate the new non-Schneider Electric Meter. Therefore, the Contracting Officer

has determined the anticipated cost to the Government of the supplies/services covered by this J&A to be fair and reasonable.

8. Actions to Remove Barriers to Future Competition.

This is a one-time procurement. This J&A applies to the design and construction of FY 2024 MILCON Project P-012, North Aircraft Parking Ramp at AAFB; for which a market survey to ascertain the availability of new technology that may provide other sources to meet the Government's needs has been conducted, as referenced above. Should any other offers for compatible electricity meters be submitted during the source selection process, the Government will consider each as applicable.

CERTIFICATIONS AND APPROVAL


TECHNICAL/REQUIREMENTS CERTIFICATION

I certify that the facts and representations under my cognizance which are included in this justification and its supporting acquisition planning documents, except as noted herein are complete and accurate to the best of my knowledge and belief.



LEGAL SUFFICIENCY REVIEW

I have determined this justification is legally sufficient.



APPROVAL

Upon the basis of the above justification, I hereby approve the solicitation of the proposed procurement(s) described herein using other than full and open competition, pursuant to the authority of 10 U.S.C. 3204 (a)(1) and (b)(B)(i) and (ii).

