

HIGH EFFICIENCY AIR COOLED CHILLER (CH) SCHEDULE

TAG	NOMINAL CAPACITY (TONS)	EFFICIENCY			EVAPORATOR				CONDENSER FANS		COMPRESSOR					HEAT RECOVERY			ELECTRICAL			BASIS OF DESIGN		NOTES
		FULL LOAD (EER)	IPLV (EER)	NPLV (EER)	EWI (°F)	LWI (°F)	GPM	PD (FT H2O)	NO. OF FANS	MOTOR kW PER FAN	QTY	TYPE	NO. OF CIRCUITS	CAPACITY STEPS	REFRIG. TYPE	GPM	EWI /LWI (°F)	PRESS DROP (FT H2O)	VOLTS/ PHASE/ HERTZ	MCA	MOP	MANUF.	MODEL	
CH-1	110	9.6	15.0	14.6	56.0	42.0	173.7	8.0	8	9.8	4	SCROLL	2	4	R410a	32	135/150	3.3	460 / 3 / 60	226.0	250.0	TRANE	CGAM 110	1 - 11
CH-2	110	9.6	15.0	14.6	56.0	42.0	173.7	8.0	8	9.8	4	SCROLL	2	4	R410a	32	135/150	3.3	460 / 3 / 60	226.0	250.0	TRANE	CGAM 110	1 - 11

- NOTES: 1. UNIT PERFORMANCE INDICATED BASED ON 95° AMBIENT AIR TEMPERATURE; 0% GLYCOL MIXTURE IN EVAPORATOR.
2. CHILLER TO BE EQUIPPED WITH A SOUND ATTENUATOR PACKAGE; CHILLER SOUND POWER LEVEL SHALL NOT EXCEED 95 dBA; SOUND PRESSURE LEVEL 68 dBA.
3. CHILLER PHYSICAL DATA: LENGTH = 165.9"; WIDTH = 89"; HEIGHT = 92.5"; OPERATING WEIGHT = 6701 LBS; REFRIGERANT CHARGE = 91.5 LB/CIRCUIT.
4. PROVIDE CHILLER WITH FACTORY INSTALLED HEAT TRACING OF CHILLER COMPONENTS (EVAPORATOR, PIPING, HEAT RECOVERY CONDENSER); PROVIDE SEPARATE 115V1PHASE POWER FEED REQD FOR HEAT TRACE.
5. ELECTRICAL DATA LISTED IS FOR SINGLE POINT POWER CONNECTION.
6. PROVIDE WITH FACTORY PRE-WIRED MOLDED CASE STANDARD INTERRUPTING CAPACITY CIRUIT BREAKER WITH TERMINAL BLOCK POWER CONNECTIONS AND LOCKABLE EXTERNAL OPERATOR HANDLE TO DISCONNECT CHILLER FROM MAIN POWER.
7. PROVIDE ACROSS-THE-LINE STARTER IN UL1005 RATED PANEL; STARTER SHALL BE FACTORY MOUNTED AND PRE-WIRED TO COMPRESSOR MOTORS AND CONTROL PANEL.
8. CHILLER COIL SHALL WITHSTAND 3000 HOUR SALT SPRAY TEST, METAL FINISHES SHALL WITHSTAND 500 HOUR SALT SPRAY TEST IN ACCORDANCE WITH ASTM B117.
9. CHILLER SHALL BE CAPABLE OF OPERATION IN LOW AMBIENT CONDITIONS TO 20 DEGREES F.
10. PROVIDE WITH FLOW SWITCH ON EVAPORATOR TO INDICATE PROOF OF FLOW.
11. PROVIDE WITH LOUVERED PANELS TO COVER THE CONDENSER COIL FOR PROTECTION AGAINST VANDALISM, DEBRIS OR HAIL.

2/4/2015 11:22

PUMP SCHEDULE																
TAG	PUMP TYPE	SERVICE	LOCATION	FLUID TYPE	FLUID TEMP (°F)	GPM	HEAD (FT H2O)	NSPH REQD (FT)	IMPELLER DIAMETER (IN)	MIN EFF. (%)	ELECTRICAL DATA			BASIS OF DESIGN		NOTES
											MTR HP	NOMINAL MOTOR RPM	VOLTS/ PHASE/ HERTZ	MANUF	MODEL	
BP- 1 TO 6	INLINE	PRIMARY HW (BOILER RECIRC)	MECH 1403	WATER	140	SEE BOILER SCHEDULE								TACO	1400-70	1
P-1,2	BASE MOUNTED	SECONDARY HOT WATER	MECH 1403	WATER	140	160	90	7.7	9.75	66.4	7.5	1750	208 / 3 / 60	BELL & GOSSET	1510	1, 2, 4
P-3,4,5	BASE MOUNTED	PRIMARY CHILLED WATER	CHILLER YARD	WATER	42	173.7	30	6.2	6.0	78.4	2	1750	480 / 3 / 60	BELL & GOSSET	1510-2.5AC	1 - 5
P-6,7	BASE MOUNTED	SECONDARY CHILLED WATER	MECH 1304	WATER	42	347.4	70	5.2	8.750	77.1	15	1750	208 / 3 / 60	BELL & GOSSET	1510-3BC	1, 2, 4
P-8,9	INLINE	CONDENSER HEAT RECOVERY	CHILLER YARD	WATER	150	32	75	9.1	4.875	42.8	2	1750	480 / 3 / 60	BELL & GOSSET	90 1AA	1, 2, 5
NOTES: 1. MOTORS SHALL BE PREMIUM EFFICIENCY TYPE.																
2. UNIT SHALL BE SERVED BY VARIABLE SPEED DRIVE.																
3. PUMPS SHALL BE CONFIGURED IN PARALLEL CONFIGURATION WITH 2 PUMPS SIZED FOR FULL LOAD CONDITIONS + 1 SHARED REDUNDANT PUMP.																
4. PROVIDE PUMP WITH FULL SIZE IMPELLER; BALANCE TO THE DESIGN CONDITIONS USING THE VFD.																
5. MOTORS SHALL BE TEFC AND RATED FOR OUTDOOR CONDITIONS.																
24/2015 11:22																

2/4/2015 11:22