

AIR HANDLER SCHEDULE

SYM.	LOCATION FLOOR BLDG.	MFG MODEL	AIR FLOW			CHILLED WATER COIL										ELECTRICAL SUPPLY FAN		OPER. WT. (LBS)	FILTERS MERV 13	REMARKS	
			SUPPLY FAN		OSA CFM	MBH	ENT AIR		LVG AIR		WATER				ROWS						FPI
			CFM	ESP			DB	WB	DB	WB	FLOW	ΔP	ENT	LVG							
AHU 1	MECH RM. SECOND FLOOR	TRANE M-17	7480	3"	1850	256.1	81.1°F	69.2°F	55.0°F	53.2°F	51.3 GPM	3.13'	45°F	55°F	6	-	208-3	10	1655	YES	PROVIDE WITH UV LIGHT AND VFD
AHU 2	MECH RM. SECOND FLOOR	TRANE M-17	6650	3"	1400	244.6	81.1°F	69.2°F	55.0°F	53.3°F	48.9 GPM	2.92'	45°F	55°F	6	-	208-3	10	1558	YES	PROVIDE WITH UV LIGHT AND VFD
AHU 3	MECH RM. THRD FLOOR	TRANE M-17	8170	3"	1400	287.7	81.1°F	69.2°F	55.0°F	53.1°F	57.6 GPM	3.81'	45°F	55°F	6	-	208-3	10	1558	YES	PROVIDE WITH UV LIGHT AND VFD

* COIL SIZE & GPM BASED ON 100% OSA UPON ERV FAILURE. (OSA ENTERING 91°F db - 81°F wb)

ENERGY RECOVERY UNIT-DEDICATED OSA AHU

SYM.	LOCATION FLOOR BLDG.	MFG. MODEL	AIR FLOW				SUMMER						WINTER		PREHEAT COIL										ELECTRICAL				OPER. WT. (LBS)	FILTERS MERV 13	REMARKS
			SUPPLY FAN		EXH FAN	OSA IN		RA		OSA OUT		MBH			ENT AIR		LVG AIR		WATER				ROWS	FPI	VOLTAGE	SUP FAN	EXH FAN				
			CFM	ESP		DB	WB	DB	WB	DB	WB		DB	WB	ENT	LVG	DB	WB	DB	WB	FLOW	ΔP				ENT	LVG	HP			
 ERV 1	MECH RM. ATTIC	COOK OR EQUAL	4850	3/4"	4045	2.0"	91.0	81.0	76.0	50%	76.0	69.2	26°F	53.9°F	71,200	53.9°	39.2°	68.0°	40%	7.1 GPM	2.13'	180	160	TBD	-	208-3	5	5	3650	YES	

CHILLER SCHEDULE

SYM.	MFR. & MODEL No.	SERVICE	LOCATION	TYPE	EVAPORATOR					CONDENSER					POWER			EFFICIENCIES (IPLV)		OPER. WT. (LBS)	REMARKS	
					WATER			PD	CAPACITY	WATER			PD (FT)	FOULING FACTOR	AMBIENT AIR TEMP.	V-PH	MCA	MOCP	KW/TON			EER
					FLOW	IN	OUT			GPM	IN	OUT										
CH 1	TRANE CGAM 70	FIRST FLOOR MECH RM	EXTERIOR	AIR COOLED	157 GPM	54 F	44 F	6.3 FT	65.4 TONS	-	-	-	-	-	95°F	208-3	354.5	400	-	-	4000	PROVIDE WITH FACTORY INSTALLED BUFFER TANK

BOILER

SYM.	MANUFACTURER & MODEL NO.	FLOOR BLDG.	LOCATION	INPUT	OUTPUT	DOE SEASONAL EFF	FUEL	GPM	ENT. WATER TEMP.	LVG. WATER TEMP.	WATER Δ P	OPER. WT.	BURNER ELECTRICAL		BOILER HP	REMARKS
													V-PH	AMPS		
B 1	HYDROTHERM KN-4	FIRST FLOOR MECH RM	MECH RM.	399 MBH	349 MBH	92.7	NAT GAS	25	180°F	180°F	-	1380 LBS.	120-1	5	10.6	PROVIDE BOILER WITH CIRCULATING PUMP 120V-1#-60hz
B 2	HYDROTHERM KN-4	FIRST FLOOR MECH RM	MECH RM.	399 MBH	349 MBH	92.7	NAT GAS	25	180°F	180°F	-	1360 LBS.	120-1	5	10.6	PROVIDE BOILER WITH CIRCULATING PUMP 120V-1#-60hz
B 3	HYDROTHERM KN-4	FIRST FLOOR MECH RM	MECH RM.	399 MBH	349 MBH	92.7	NAT GAS	25	180°F	180°F	-	1360 LBS.	120-1	5	10.6	PROVIDE BOILER WITH CIRCULATING PUMP 120V-1#-60hz

PUMPS

SYM.	MANUFACTURER & MODEL NO.	FLOW RATE	WATER Δ P	RPM	ELECTRICAL		OPER. WT. (LBS)	PUMP EFF.	BLDG FLOOR LOCATION	REMARKS
					VOLTAGE	HP				
HWP 1	BELL & GOSSET 1510 2 1/2BB	157 GPM	80 FT	1750	208-3	10	360	74.88	FIRST FLOOR MECH ROOM	
HWP 2	BELL & GOSSET 1510 2 1/2BB	157 GPM	80 FT	1750	208-3	10	360	74.88	FIRST FLOOR MECH ROOM	STAND-BY
HWP 1	BELL & GOSSET 1510 1 1/2BC	75 GPM	80 FT	1750	208-3	5	210	62.27	FIRST FLOOR MECH ROOM	WITH VFD
HWP 2	BELL & GOSSET 1510 1 1/2BC	75 GPM	80 FT	1750	208-3	5	210	62.27	FIRST FLOOR MECH ROOM	STAND-BY WITH VFD

SUPPLY DIFFUSER SCHEDULE

UNIT NO.	MANUFACTURER	MODEL	NECK SIZE	FRAME TYPE	RANGE C.F.M.	REMARKS
A _H	KRUEGER (OR EQUAL)	51240	6x6	23	0-120	PROVIDE AS 4-WAY DISCHARGE PATTERN UNLESS SHOWN OTHERWISE ON IS AND
B _H			8x8		121-210	
C _H			10x10		211-330	
D _H			12x12		331-470	
E _H			14x14		471-640	
F _H			16x16		641-1000	
G _H		5880	36x16	22	600-1300	DOUBLE DEFLECTION ADJUSTABLE GRILLE W/ ALUMINUM OSD

NOTES:
1. USE SURFACE MOUNT IN GYP. BOARD CEILING FRAME TYPE 1 SUBSCRIPT "H" WHERE SHOWN
DENOTES GYP. BOARD CEILING.

RETURN/EXHAUST REGISTER SCHEDULE

UNIT NO.	MANUFACTURER	MODEL	NECK SIZE	FRAME TYPE	RANGE C.F.M.	REMARKS
AA _H	KRUEGER (OR EQUAL)	5880H (SQUARE)	6x6	23	0-160	3/4" SPACED FIBER GLASS, 35° DEFLECTION
BB _H			8x8		161-280	
CC _H			10x10		281-435	
DD _H			12x12		436-625	
EE _H			14x14		626-855	
FF _H			16x16		856-1110	
GG _H			18x18		1111-1800	
HH _H		5880H (RECTANGULAR)	36x16	22	750-2000	3/4" SPACED FIBER GLASS, 35° DEFLECTION

NOTES:
1. USE SURFACE MOUNT IN GYP. BOARD CEILING FRAME TYPE 1 SUBSCRIPT "H" WHERE SHOWN
DENOTES GYP. BOARD CEILING.
2. ALL RETURN AIR GRILLS FOR FAN POWERED BOXES SHALL BE MINIMUM 18X12 FILTER GRILLE
WITH FILTERS.



CONTRACT NO. 16-007
NAVAL FACILITIES ENGINEERING COMMAND - MID-ATLANTIC
NAVAL COMBUSTION SYSTEMS - WAREHOUSING
WCS CAMP LEJEUNE
FY09 BACHELOR ENLISTED QUARTERS
CAMP JOHNSON P-1011 P-1016
MECHANICAL SCHEDULES

DATE: 01-04-2010
DRAWN BY: JH
CHECKED BY: JH
DESIGNED BY: JH
PROJECT NO.: 16005-09-R-3215
NAVAL ENGINEER: JH
DATE: 01-04-2010
PROJECT NO.: 16005-09-R-3215
M601