

PROJECT DESCRIPTION

The responsibility of the contractor is to replace chillers at the following BEQ buildings.

Replace chillers at the following buildings.

1.HP476 -125 ton Chiller &1 Chilled Water Pump

2.FC66-2-110 Ton Chillers &6 Chiller Water Pumps*Chiller and disconnect sizes should be verified by the contractor.

3.BB137-110-ton Chiller& 1 Chilled water Pump &VFD.

SPECIAL SCHEDULING

The facility/activity will remain in operation during the entire construction period. The Contractor shall conduct his operations so as to cause the least possible interference with normal operations of the facility/activity. The furniture and other objects in the room are to be moved by the contractor.

SUPERVISION

One person may fill the roles of Superintendent, Quality Control Manager, and Safety & Health Officer, if duly qualified for all three positions as defined in the project specification.